


Kennedy/Jenks Consultants

Engineers & Scientists

Pump Station Design: How Low Can You Go?

Renee Campbell

Staff Engineer



Introduction



*Distribution
Requirements*

*Pressure
Reducing
Valves*

Treatment

Pipe Fittings

*Reservoir
Levels*

Conveyance

VFDs

End-Use

*Reservoir
Elevations*

Motors

Electrical

Lighting

Transformers

HVAC

*Operating
Strategy*

*Pump Control
Valves*

*Building
Support*




Hydraulic Energy Calculation



$$\text{○ } HP = \frac{(GPM) \times (Feet)}{3,956 \times Eff}$$

$$kW \cdot hr = 0.746 \times HP \times hr$$

HP = horsepower
GPM = gallons per minute
Eff = efficiency
kW = kilowatt
hr = hour



General Assumptions:

- ▼ Pump efficiency = 80%
- ▼ Pumps run 4,380 hours per year (half time)
- ▼ Cost of electricity \$0.08 per kW-hr

Example:

- ▼ 3,000 gpm pump, 400 feet TDH
- ▼ $HP = (3,000) (400) / 3956 / .80 = \mathbf{380 \text{ HP}}$
- ▼ Energy = $(380) (.746) (4,380)$
= 1,240,000 kW-hr / year
- ▼ $65,500 * \$0.08 = \mathbf{\sim \$100,000}$



Comparison of Two Pump Stations



District A

- ▼ 290 million gallons per year
- ▼ 30,000 customers
- ▼ Upgrading a booster station that handles ~20% of the flow
- ▼ Pumps to distribution system
- ▼ PS Current Energy Cost - \$35,000/year

District B


- ▼ 2.4 billion gallons per year
- ▼ 132,000 customers
- ▼ Upgrading a pump station that handles most of the flow
- ▼ Pumps directly to reservoirs
- ▼ PS Current Energy Cost - \$200,000 /year



Pump Station A




- 4 Pumps Total
- 1,800 gpm
- 380 feet TDH
- ~490 kW-hr/yr



Pump Station A




- 4 Pumps Total
- 1,800 gpm
- 380 feet TDH
- ~490 kW-hr/yr



Pump Station A




- 4 Pumps Total
- 1,800 gpm
- 380 feet TDH
- ~490 kW-hr/yr



Pump Station A




- 4 Pumps Total
- 1,800 gpm
- 380 feet TDH
- ~490 kW-hr/yr



Pump Station A




Energy Reduction



Pump Station A



Pump Station Cost per Year




*15-20%
reduction in
operating
costs*



Pump Station B



- 5 Pumps Total
- 30 MGD
- 350 feet TDH
- ~2.8 MW-hr/yr



Pumping System Options Control Strategies Overview



- ▼ Pump Sizing
 - | Five Small Pumps
 - | Two Large Pumps, Three Small Pumps
 - | Five Large Pumps
- ▼ VFDs vs No VFDs
 - | No VFDs (all 5)
 - | VFDs on just the large pumps (2),
No VFDs on small pumps (3)




Operating Strategy



- ▼ Assumed Operating Strategy for Two Primary Pumps (VFDs) and Three Secondary Pumps (No VFDs)
 - | Primary Pumps would operate first and adjust speed as needed.
 - | Secondary Pumps would turn on successively; Primary pumps would adjust speed.



Pump Curves




Analysis




- ▼ Look at range the range of flow rates
- ▼ Solve for the operating scheme at a particular flow rate
- ▼ Solve for the efficiency at that flow
- ▼ Calculate the power requirement



Pump Curves



Pump Curves



Curve Fits

$$h = aQ^2 + bQ + c$$

$$Q = \frac{-b - \sqrt{b^2 - 4a(c - h)}}{2a}$$

Analysis



▼ An automated solving tool...

```
maxflow = Worksheets("Alt-2 Analysis").Cells(8, 5).Value

'To solve for Q = x, use quadratic equation solution (head = y):
'y = a*x^2 + b*x + c
'x = [-b + sqrt(b^2 - 4*a*(c-y))]/(2*a)

Worksheets("Alt-2 Analysis").Cells(19, 2).Value = syflow
If syflow > maxflow Then
    exceedscap = syflow - maxflow
    syflow = maxflow
End If

'Finds the required system head at the input flow rate using the curve fit coefficients
syhead = sya * syflow ^ 2 + syb * syflow + syc
'Finds the maximum flow each pump set can pump at the system head using the quadratic so
p1maxflow = (-p1b - Sqr(p1b ^ 2 - 4 * p1a * (p1c - syhead))) / (2 * p1a)
p2maxflow = (-p2b - Sqr(p2b ^ 2 - 4 * p2a * (p2c - syhead))) / (2 * p2a)
ps2maxflow = (-ps2b - Sqr(ps2b ^ 2 - 4 * ps2a * (ps2c - syhead))) / (2 * ps2a)

'Pump 1 Operation
'p1op = the required number of p1 pumps
'p1op is by default the number of pumps in the P1 set. If the system flow rate does not
'the 'for loop', that means it exceeds the maximum flow rate and all the P1 pumps must k
p1op = np1
For m = 1 To np1
    If syflow > p1maxflow & (m = 1) And syflow < p1maxflow & m Then
```




Analysis




mgd		Number of Pumps Operating	% Speed	Efficiency	Flow Rate per Pump (gpm)	Velocity in Can (fps)	Velocity in Suction Pipe (fps)	BHP per Pump	Total kVa per PS
5	PS 1 Primary	1	72%	67%	3472	1.91	4.37	289	298
	PS 1 Secondary	0			0	0.00	0.00	0	
	PS 2	0			0	n/a	n/a	0	
10	PS 1 Primary	1	90%	83%	6944	3.82	8.75	472	488
	PS 1 Secondary	0			0	0.00	0.00	0	
	PS 2	0			0	n/a	n/a	0	
15	PS 1 Primary	2	80%	81%	5208	2.87	6.56	375	774
	PS 1 Secondary	0			0	0.00	0.00	0	
	PS 2	0			0	n/a	n/a	0	
20	PS 1 Primary	2	91%	85%	6944	3.82	8.75	497	1026
	PS 1 Secondary	0			0	0.00	0.00	0	
	PS 2	0			0	n/a	n/a	0	
25	PS 1 Primary	2	91%	86%	6687	3.68	8.42	496	1340
	PS 1 Secondary	1	100%	79%	3985	4.74	8.30	321	
	PS 2	0			0	n/a	n/a	0	
30	PS 1 Primary	2	92%	87%	6540	3.60	8.24	514	1704
	PS 1 Secondary	2	100%	81%	3876	4.61	8.07	327	
	PS 2	0			0	n/a	n/a	0	
35	PS 1 Primary	2	94%	87%	6544	3.60	8.24	550	2112
	PS 1 Secondary	3	100%	83%	3739	4.45	7.79	331	
	PS 2	0			0	n/a	n/a	0	
40	PS 1 Primary	2	88%	86%	4884	2.69	6.15	448	1919
	PS 1 Secondary	3	100%	83%	3569	4.25	7.43	337	
	PS 2	1	100%	86%	7301	n/a	n/a	669	
45	PS 1 Primary	2	88%	72%	3758	2.07	4.73	445	1922
	PS 1 Secondary	3	100%	84%	3359	4.00	6.99	341	
	PS 2	2	100%	86%	6828	n/a	n/a	678	
50	PS 1 Primary	2	91%	78%	3327	1.83	4.19	394	1851
	PS 1 Secondary	3	100%	82%	3094	3.68	6.44	352	




Pump Size Comparison



Pump Operation – No VFDs



Pump Operation – Two VFDs



No VFD vs VFDs Comparison



	No VFDs	Two VFDs	All VFDs
Average Power (kW)	830	770	760
Average Efficiency	72%	78%	79%
Total Project Cost	\$550,000	\$1,280,000	\$2,210,000
Pumping Energy Cost	\$503,000	\$471,000	\$465,000
Net Operating Costs (20-Years)	\$9,500,000	\$9,000,000	\$9,100,000
Total Present Worth	\$10,000,000	\$10,200,000	\$11,100,000



Summary



▼ Small Pumping Systems

- | Benefits of replacing with high efficiency motors
- | Benefits of operating at best efficiency point

▼ Large Pumping Systems

- | Analyze different operating scenarios
- | Even a couple percentage points can save \$Ks

