

Water Distribution System Energy Efficiency Optimization

May 10, 2013

Michele Campbell, P.E.

RH2 Engineering




What is Energy Signature?

- Metric for measuring pump energy consumption
- Measured in kWh/MG
- Function of:
 - System demand
 - Discharge HGL
 - Suction HGL
 - Mechanical and electrical equipment efficiency
- No direct correlation to pump/motor efficiency

Energy Signature

$$\text{ES (kWh/MG)} = \frac{\text{Measured Power (kW)} \times 1,000,000}{\text{Measured Flow (gpm)} \times 60}$$

What is Energy Signature?



How is Energy Signature Evaluated?

TAP Booster Pump Station

- Two 50 hp pumps
- Two 125 hp pumps w/VFDs
- 125 hp pumps alternate as lead
- One 125 hp pump is underperforming



Data Collection


- Mechanical Data
 - Suction pressure (booster pumps)
 - Groundwater level (wells)
 - Discharge pressure
 - Flow rate



Data Collection

- Electrical Data
 - Power usage
 - Voltage

- Current
- Power Factor





Data Collection Inaccuracies

Poor pressure gage location




Inadequate length of straight pipe downstream of meter

Data Pump



Data Analysis: Energy Signature




Data Analysis: Energy Signature

<i>NEW CHARGES - 08/12</i>	UNITS	COST PER UNIT	CHARGE
Basic Charge - 3P Sec Delivery	105 kw		67.00
Load Size Charge - 3p Sec Del	105 kw	0.4500000	47.25
Demand Charge Sec - Min 15 Kw	78 kw	4.3900000	342.42
Delivery Charge Secondary	38,880 kwh	0.0058500	227.45
Supply Enrgy Sec 1St 20000 Kwh	20,000 kwh	0.0587100	1,174.20
Supply Enrgy Sec > 20000 Kwh	18,880 kwh	0.0571200	1,078.43
Public Purpose		0.0300000	88.10
Energy Conservation Charge	38,880 kwh	0.0020500	79.70
Low Income Assistance	38,880 kwh	0.0005000	19.44

Description	Annual Baseline	Annual Proposed	Annual Savings	Percent Savings
Energy and Demand Costs (\$)	\$27,754	\$20,584	\$7,170	26%
Energy Consumption (kWh)	333,257	252,044	81,213	24%
Peak Power Demand (kW)	105	73	32	30%


System-Wide Energy Signature Analysis




Bonneville Power Administration Study

- Grant funding provided by Bonneville Power Administration
- Studied 4 water systems of various size
- Visited 87 sites
- Collected data and evaluated 170 different pumps


Optimizing Pump Sequencing for Pressure Zones



Compounding Pressure Zones




Compounding Pressure Zones




City of Renton
Existing System Hydraulic Profile
Bonneville Power Administration
Municipal Water System Control
Optimization Feasibility Study
 Date: JUNE 25, 2012 Filename: BPA\212-004\CAD\REN-HPX.DWG

Legend

VLY 196 Zone	KD 320 Zone	RH 490 Zone	Well Pump
KD 218 Zone	TH 350 Zone	WH 495 Zone	Booster Pump Station
TH 270 Zone	EARL 370 Zone	HLD 565 Zone	Pressure Reducing Station
ETH 300 Zone	SH 370 Zone	RH 590 Zone	Intertie
WH 300 Zone	RH 395 Zone	HLD 435 Zone	Facilities at Same Site
WTH 300 Zone			




Compounding Pressure Zones




Annual System-Wide Energy Savings with Optimum Pump Sequencing

Description	Baseline System-Annual	Proposed System-Annual	Total Annual Savings	Percent Savings
Energy and Demand Costs (\$)	\$337,253	\$299,591	\$37,662	11%
Energy Consumption (kWh)	4,822,452	4,383,681	438,771	9%
Peak Power Demand (kW)	1,745	1,436	309	18%

Annual Cost Savings by Zone



Pressure Optimization



Annual System-Wide Energy Savings with Pressure Optimization

Description	Baseline System-Annual	Proposed System-Annual	Total Annual Savings	Percent Savings
Energy and Demand Costs (\$)	\$61,225	\$56,492	\$4,733	8%
Energy Consumption (kWh)	526,494	485,903	40,491	8%
Peak Power Demand (kW)	3,100	2,773	327	11%

Summary of Potential Savings Found in BPA Study

Water System	Approximate Population Served	Projected Annual Energy Cost Savings (\$)	Projected Annual Energy Cost Savings (%)
1	62,000	\$ 40,333	11.8 %
2	49,000	\$ 57,400	18.9 %
3	38,000	\$ 19,250	31.4 %
4	14,000	\$ 7,287	13.1 %

Implementation

3 options

1. Manual sequencing
2. SCADA and PLCs use to calculate energy signatures and optimum sequences
3. SCADA and PLCs monitor actual real-time energy signatures and changing prioritization

Implementation

1. Manual Sequencing

- No cost
- Operators can change lead/lag pumps in existing SCADA system
- Energy signatures not monitored
- Not optimal

Implementation

2. Using Calculated Energy Signatures

- Moderate cost
- Energy signatures estimated by the PLC
 - If flow, suction, and discharge pressures are monitored by the SCADA system
 - Estimate based on field data
 - Update the HMI at each PLC

Implementation

3. Actual Real-Time Energy Signatures

- Highest first cost
- Data from all 3 power phases to monitor power data digitally
- Communication to the PLC via a serial connection
- Energy signatures vary based on system conditions- prioritization changes as a result
- Monitor pump or motor over time to see if it is in need of maintenance or overhaul prior to failure
- Eligible for incentive/grants

Other Uses for Energy Signature Analysis

- Track pump performance over time
- Identify problems before failure/gets expensive
- Prioritize pump maintenance/overhaul

Questions?

Michele Campbell, P.E.

RH2 Engineering, Inc.

mcampbell@rh2.com

425.951.5394



Energy Signature vs. Wire to Water Efficiency

City of Renton
2011 System Control Optimization
Field Data Collection

760 gpm average measured flow

14 percent average.

40 percent average.

885 gpm measured flow

51 percent average

59 percent average

1,910 average KWH/MG

1,567 average KWH/MG
~20 percent savings

Site - Pump #	Test No.	Electrical Data										Hydraulic Calculations									
		Lag A (amps)	Lag B (amps)	Lag C (amps)	Power Lag A (kW)	Power Lag B (kW)	Power Lag C (kW)	Total Power (kW)	Factor	VFD Only	Head Loss Between Pump and Gauges (ft)	Q (gpm)	TDH (ft)	Wire-to-Water Efficiency	Horsepower (bhp)	Theoretical Head (ft)	Average I (amps)	Measured % of			
Highlands BPS - Pump 1	1	72	66	72	80	11	11	33	0.36	0.70	0.0	1,560	115	103%	44	142	142				
Highlands BPS - Pump 1	2	72	66	71	317	478	15	11	41	0.39	0.70	0.0	1,470	120	81%	55	130	321			
Highlands BPS - Pump 1	3	71	64	70	325	489	167	11	39	0.31	0.79	0.0	1,280	129	80%	52	130	327	39	151%	
Highlands BPS - Pump 2	1	74	65	72	481	210	316	19	50	0.82	0.90	0.16	1,550	131	77%	67	130	70	50	196%	
Highlands BPS - Pump 2	2	73	65	70	480	208	315	19	50	0.82	0.91	0.32	1,390	127	66%	67	150	89	50	182%	
Highlands BPS - Pump 2	3	71	63	70	482	208	315	18	12	0.81	0.91	0.29	1,275	138	69%	68	130	89	50	162%	
Highlands BPS - Pump 3	1	72	65	70	484	487	487	20	18	0.89	0.89	0.92	1,485	136	66%	78	130	89	50	162%	
Highlands BPS - Pump 3	2	70	63	67	481	483	486	21	18	0.89	0.91	0.91	1,260	164	69%	75	130	96	50	182%	
Highlands BPS - Pump 3	3	73	66	71	481	483	485	19	17	0.90	0.90	0.90	1,000	175	65%	68	130	96	50	182%	
Monroe BPS - Pump 1	1	53	52	54	488	487	487	14	14	0.75	0.75	0.75	850	48	16%	60	130	487	48	156%	
Monroe BPS - Pump 1	2	53	53	54	485	485	486	15	15	0.75	0.74	0.95	750	41	13%	60	130	485	48	159%	
Monroe BPS - Pump 1	3	52	51	52	487	486	490	15	14	0.72	0.73	0.96	670	40	11%	60	130	488	48	159%	
Monroe BPS - Pump 2	1	74	74	74	485	485	485	21	21	0.76	0.76	0.76	1,100	123	40%	86	0	74	485	48	136%
Monroe BPS - Pump 2	2	71	73	75	484	485	485	20	20	0.78	0.78	0.78	875	141	39%	80	0	73	485	48	126%
Monroe BPS - Pump 2	3	71	72	72	486	486	489	15	15	0.74	0.74	0.74	1,000	146	41%	82	0	72	485	48	126%
House Way BPS - Pump 1	1	31	31	29	483	481	481	7	7	0.86	0.84	0.84	400	164	54%	31	124	305	85	21%	
House Way BPS - Pump 1	2	28	29	27	486	483	484	6	7	0.84	0.82	0.81	330	164	54%	25	124	484	82	19	
House Way BPS - Pump 1	3	24	25	24	485	483	483	6	6	0.82	0.79	0.78	195	164	50%	24	124	484	80	15	
House Way BPS - Pump 2	1	216	216	211	487	486	486	53	52	0.87	0.86	0.87	10.7	2,000	299	72%	259	214	486	87	156
House Way BPS - Pump 2	2	199	200	196	487	485	485	48	47	0.87	0.86	0.86	4.5	1,320	279	49%	192	198	486	86	144
House Way BPS - Pump 2	3	180	182	177	487	486	485	51	49	0.86	0.85	0.85	2.4	960	273	32%	202	239	180	486	85
House Way BPS - Pump 3	1	214	213	209	484	484	483	53	52	0.87	0.86	0.87	9.5	1,940	296	72%	192	239	212	484	87
House Way BPS - Pump 3	2	211	210	206	484	484	482	52	51	0.87	0.86	0.87	6.4	1,640	288	58%	205	239	209	483	87
House Way BPS - Pump 3	3	194	194	189	487	487	486	47	46	0.85	0.85	0.86	3.9	1,250	279	48%	185	239	192	487	86
Well PW-9	1	93	93	96	480	481	480	23	23	0.89	0.89	0.89	0.3	1,210	164	54%	92	3	94	480	89
Well PW-9	2	91	91	93	480	482	480	22	22	0.89	0.88	0.89	0.2	1,090	185	57%	90	7	92	481	89
Well PW-9	3	89	89	91	481	482	481	22	22	0.88	0.88	0.89	0.2	1,020	194	60%	88	8	90	481	89
Well PW-12	1	228	223	233	470	470	474	56	45	0.82	0.78	0.88	0.0	1,735	288	61%	257	241	228	475	154
Well PW-12	2	228	223	232	472	471	475	56	46	0.81	0.78	0.88	0.0	1,630	317	63%	257	241	228	475	154
Well PW-12	3	228	222	232	471	470	474	56	45	0.81	0.78	0.88	0.0	1,580	333	65%	206	241	227	475	154
South Talbot BPS - Pump 1	1	16	16	16	485	484	3	3	3	0.76	0.76	0.75	0.0	200	162	81%	13	0	16	485	76
South Talbot BPS - Pump 1	2	16	16	16	484	484	483	3	3	0.76	0.76	0.75	0.0	195	177	65%	13	0	16	484	76
South Talbot BPS - Pump 1	3	15	16	16	484	484	482	3	3	0.77	0.77	0.75	0.0	160	201	61%	13	0	16	483	76
South Talbot BPS - Pump 2	1	42	44	43	258	487	229	10	5	0.34	0.45	0.99	0.1	570	166	72%	33	0	42	325	14
South Talbot BPS - Pump 2	2	42	43	43	257	486	229	10	5	0.34	0.45	0.99	0.1	475	173	63%	33	0	42	324	14
South Talbot BPS - Pump 2	3	41	43	42	258	486	229	10	5	0.34	0.44	0.99	0.1	440	180	61%	33	0	42	325	14
Fred Nelson BPS - Pump 1	1	14	14	14	477	478	478	3	3	0.86	0.86	0.86	0.0	250	122	75%	14	0	14	478	86
Fred Nelson BPS - Pump 1	2	14	14	13	478	477	478	3	3	0.86	0.84	0.84	0.0	202	134	72%	13	0	14	478	86
Fred Nelson BPS - Pump 1	3	13	13	13	478	477	478	2	2	0.86	0.86	0.86	0.0	154	143	60%	0	0	14	478	86
Fred Nelson BPS - Pump 2	1	27	27	27	474	475	474	6	6	0.82	0.82	0.82	0.0	158	143	60%	0	0	14	478	86
Fred Nelson BPS - Pump 2	2	23	24	23	478	477	477	5	5	0.79	0.79	0.79	0.0	158	143	60%	0	0	14	478	86
Fred Nelson BPS - Pump 2	3	25	26	25	478	478	477	6	6	0.81	0.80	0.80	0.0	174	137	64%	14	0	14	478	86
Rolling Hills BPS - Pump 1	1	108	102	112	477	479	479	25	25	0.87	0.86	0.86	0.0	1,740	137	64%	94	94	106	478	86
Rolling Hills BPS - Pump 1	2	103	103	106	480	482	483	25	25	0.87	0.88	0.88	0.0	1,740	137	64%	94	94	106	478	86
Rolling Hills BPS - Pump 1	3	96	99	100	481	483	484	24	23	0.86	0.87	0.86	0.0	1,740	137	64%	94	94	106	478	86
Rolling Hills BPS - Pump 2	1	104	112	103	477	478	475	26	26	0.87	0.84	0.85	0.1	2,390	122	72%	102	102	106	477	85
Rolling Hills BPS - Pump 2	2	107	108	102	478	478	476	25	25	0.86	0.84	0.84	0.1	2,390	122	72%	102	102	106	477	85
Rolling Hills BPS - Pump 2	3	102	102	100	482	480	479	24	24	0.86	0.84	0.85	0.1	2,390	122	72%	102	102	106	477	85
Rolling Hills BPS - Pump 3	1	38	36	38	483	485	488	9	9	0.88	0.86	0.85	0.0	1,567	122	72%	102	102	106	485	86
Rolling Hills BPS - Pump 3	2	36	36	38	486	488	490	9	8	0.86	0.86	0.85	0.0	1,567	122	72%	102	102	106	485	86
Rolling Hills BPS - Pump 3	3	34	33	34	485	485	486	8	8	0.86	0.86	0.84	0.0	1,567	122	72%	102	102	106	485	86
Rolling Hills BPS - Pump 4	1	41	42	40	487	485	487	10	10	0.86	0.86	0.86	0.0	1,567	122	72%	102	102	106	486	86
Rolling Hills BPS - Pump 4	2	39	39	37	487	485	488	9	9	0.86	0.86	0.86	0.0	1,567	122	72%	102	102	106	487	86
Rolling Hills BPS - Pump 4	3	36	36	35	483	479	484	9	8	0.85	0.85	0.85	0.0	1,567	122	72%	102	102	106	482	86



Single Pump	Energy Signature (kWh/MG) ¹	Two-Pump Combo	Energy Signature (kWh/MG) ¹
T2 - 1 ¹	1,617	T2 - 1, T2 - 2	2,561
T2 - 2 ¹	1,594	T2 - 1, WR 1	3,885
WR 1 ²	2,289	T2 - 1, WR 3	3,543
WR 3 ²	1,894	T2 - 1, WR 4	4,182
WR 4 ²	2,556	T2 - 1, 264	3,514
264	1,967	T2 - 1, 222 F	3,082
222 F ²	1,105	T2 - 2, WR 1	3,857
		T2 - 2, WR 3	3,513
		T2 - 2, WR 4	4,164
		T2 - 2, 264	3,523
		T2 - 2, 222 F	3,064
		WR 1, WR 3	4,188
		WR 1, WR 4	4,816
		WR 1, 264	4,198
		WR 1, 222 F	3,715
		WR 3, WR 4	4,471
		WR 3, 264	3,834
		WR 3, 222 F	3,372
		WR 4, 264	4,465
		WR 4, 222 F	4,013
		264, 222 F	3,366

(1) The energy signatures of the Tank 2 BPS pumps include the energy signature of the 222nd Wellfield - Well E, which is required to indirectly supply the 770 Zone when the Tank 2 BPS is operating. The energy signature of the Tank 2 BPS Pump 1 is 698 kWh/MG and the energy signature of the Tank 2 BPS Pump 2 is 675 kWh/MG.

(2) The Witte Road Wellfield wells alternate as the lead supply pumps during the summer months, and the 222nd Wellfield - Well F is the lead supply pump in the winter months.

T2 Prefix = Tank 2 BPS

WR Prefix = Witte Road Wellfield

264 Prefix = 264th Street Well

222 Prefix = 222nd Place Wellfield


Existing pump sequence for each pump combination (see footnote 2)

Most efficient energy signature for each pump combination

Existing pump sequence and most efficient energy signature for each pump combination



Optimizing Pump Sequencing for Pressure Zones



Description	Annual Baseline	Annual Proposed	Annual Savings	Percent Savings
Energy and Demand Costs (\$)	\$61,225	\$46,708	\$14,518	24%
Energy Consumption (kWh)	526,494	456,667	69,827	13%
Peak Power Demand (kW)	3,100	1,942	1,158	37%

Example Well Pump Vibration Data

