



PNWS AWWA, Spokane, WA  
May 10, 2013

# Case Study: Reducing Electricity Costs with a New Reservoir

## Will Crandall Reservoir and Pump Station Project

Tyler Wubbena, City of Hillsboro




# Acknowledgements

- Kevin Hanway, City of Hillsboro
- Brad Phelps, CH2M HILL
- Jeff Stallard, CH2M HILL
- Ward-Henshaw Construction
- Raito Inc.
- City of Hillsboro Staff

# Outline


- Project Background
- Storage Requirements
- Water Quality
- Power Components
- Construction
- Extended Storage Validation
- Next Phases

# Project Background



# Project Background: Hillsboro Water System

- 2 Existing Reservoirs: 5.6 MG and 15 MG
- 9 PRV Connection Points
- MDD of 19 MGD




# Project Background


- CMGC Project Delivery
  - 10 MG Partially-Buried Water Tank
  - 15 MGD Booster Pump Station
  - 800 kW Generator
  - 88 kW Hydro Turbine
  - Rechlorination
  - Mixing System
- 
- 24<sup>th</sup> Street Reservoir – Rechlorination and Mixing System





# Site Features




# Tank Operation: Current Fill and Draw Cycles




# Storage Requirements: Fill and Draw Concepts



Desire to modify current operation  
and operate fill/draw cycles less  
frequently



# Tank Operation: Modified Fill and Draw Cycle



# Water Quality

---


# Water Quality

- Additional storage  $\Rightarrow$  Longer residence time
- Maintaining chlorine residual with long residence times in reservoirs
  - Field tests to evaluate rechlorination
- CFD to evaluate mixing & sampling
- Incorporation of tablet chlorinator into the reservoir and pump station design


# Water Quality: Field Tests

- Laboratory SDS tests
  - Existing reservoirs
  - One PRV supply point
- Screening evaluation
  - Rechlorination
  - DBP production


# Water Quality: 1<sup>st</sup> Street PRV Lab Testing



# Water Quality: Evergreen Reservoir Lab Testing



# Rechlorination: Promotes Longer Holding Times



## • Operation Scenario – 32 day Cycle

- 4 days fill
- 8 days hold
- 1 day rechlorination
- 8 days hold
- 4 Days Pump
- Repeat

- $\frac{1}{4}$  Pumping Cycles =  $\frac{1}{4}$ <sup>th</sup> Pumping Cost
- $\frac{1}{2}$  the Pumping Rate
- $\frac{1}{4}$ <sup>th</sup> the Pumping Power Consumption Offset by Hydroplant
- Increased Cost of Rechlorination (about \$10k per year)

# Water Quality: Benefits for Rechlorination

- Review of Fill/Draw Operation
  - Lab analysis indicated possibility to hold stored water for extended time periods
- Benefits
  - Reduced Operational Pumping Costs
    - Less Pumping
    - Pumping Costs at Evergreen - \$58k/year (2009)
  - Able to pump water from tanks when needed
  - Control over detention time in 24<sup>th</sup> Ave Reservoir
- *Note: This is not a common operational scenario or practice*

# Water Quality: Recommendations

- Recommend City implement the operational scenario of rechlorination which would include
  - Additional testing during the first year of rechlorination operations
    - Seasonal variations/field influences may require adjustment to operation
- Extensive sampling and analysis system developed for Crandall Reservoir
  - Reagent-less chlorine analyzer

# Power Components

---

# Power Components

- Utility Power Connection
- Backup Generator
  - Power for pump station
  - PGE DSG participation
- Micro Hydro
  - Converting head on inlet to reservoir
- Solar Panels (future)
- LED lights
  - Power saving

# Power Components: Backup Generator

- 800 kW generator
  - Oversized for needs at pump station
- Supply power to pump station **AND** backfeed the power utility (PGE)
  - Parallel switching device
- PGE can operate generator remotely
  - PGE can meet peak power requirements for FERC
  - PGE can defer construction of another peak power supply

# Power Components: PGE

- City has first right of refusal for generator use during an emergency
- Generator is exercised under full load during monthly testing
- Win-Win for City
  - PGE pays all maintenance
  - PGE pays all fuel
  - Monitored 24 hours/day

# Power Components: MicroHydro

- Turbine that converts excess available head to power
- Supply pressure from JWC at delivery point: 125 psi – 130 psi
  - System pressure reduced to 60 – 80 psi at PRV connection points
  - Only 20 psi needed to fill reservoir
- Use MicroHydro when reservoir is filled
- Power generated is supplied to the grid
  - Net metering agreement with PGE

# Power Components: MicroHydro

- Driver
  - Strong renewable energy goals
  - Sustainability goals
- Off-the-shelf pump technology
- Single 88 kW horizontal Francis unit






# Power Components: Solar Panels

- Planned as part of future activities at the site
- City has experience with solar panels at Evergreen Reservoir site (100 kW) and multiple other locations
- Note: Solarworld is 3 miles from the project site and a water customer of the City

# Power Components: Solar Panels



- Array of panels on reservoir and on site

# Power Components

- City has the opportunity to generate power 3 different ways at their Crandall reservoir site
  - Diesel backup power generation partnership with PGE DSG program
  - Microhydro offsets pumping costs at Crandall
  - Future solar panels provide a passive power generation opportunity

# Design & Construction

---


# Construction: Evergreen Reservoir Subsurface Conditions

- Evergreen Reservoir project found liquifiable soils to 32' below ground surface (bgs)
  - Mitigation was additional excavation to 27' bgs, and import fill



# Construction: Crandall Reservoir Subsurface Changes

- Siting study (2007) found liquifiable soils at 80' bgs.
  - An increase in **48'** of liquifiable soils from Evergreen Reservoir located **16,000'** feet away.
- Final Design (2010) at Crandall Reservoir site found liquifiable soils at 120' bgs.
  - A **40'** increase in depth of liquifiable soils – **750'** away.




# Demonstration of Liquifiable Soils




# Foundation Improvement Alternatives

- Foundation Improvement Options Investigated were:



Piles



Deep Soil Mixing



Jet Grouting

# Advantages of CDSM

- Lowest Cost
- Least impact (vibratory and acoustically) to surrounding neighbors
- More “green” method of construction as compared to piles



08/28/2012



# Weather: 2012 Record Wet Spring

CH2M Asst PM, Jeff Stallard:  
Project Weather Expert



# Construction: Current Progress



Date: April 24, 2013

# Construction: 1 Year Previous



Date: April 2012



# Construction: Current Progress



05/03/2013



05/03/2013

# Construction: Current Progress



# Extended Reservoir Storage Validation

---

# Extended Storage: 24<sup>th</sup> Street Reservoir

- Extended storage testing at 24<sup>th</sup> Street Reservoir
- Extended Storage Test Periods 2, 3, and 4 weeks
- Test periods repeated for seasonal WQ variations
- SCADA monitoring of Cl<sub>2</sub>, UV 254, and pH
- Periodic sampling of THM and HAA<sub>5</sub>

# Extended Storage: 24<sup>th</sup> Street Reservoir

- Trial 1 (March 19 to April 1)
- No rechlorination

	3/19/2013	3/25/2013	4/1/2013	MCL
HAA5	0.0420	0.0408	0.0370	<b>0.0600</b>
TTHMs	0.0432	0.0412	0.0470	<b>0.0800</b>
TOC (by lab)	0.89	0.63	0.57	
Cl2 (by colorimeter)	0.69	0.6	0.52	

# Extended Storage: 24<sup>th</sup> Street Reservoir

- Initial extended storage results appear promising
- Correlate UV<sub>254</sub> monitoring with DBP formation potential
- Document seasonal raw WQ influences on test results
- Keep below MCLs for TTHM and HAA<sub>5</sub>

# Next Phases



- Construction Continues
- Wrapping of reservoir (May)
- Leak testing June
- Pump Station finishing (July)
- Startup (Sept)
- Landscaping (Sep-Oct)
- Commissioning (Late Fall)
- Extended storage validation (2014)

# Questions?



Thank you

Tyler Wubbena  
City of Hillsboro

