

# Modeling Water Supply Reliability following a major earthquake

Anne Symonds, PE AECOM

David Myerson, PE SFPUC

AECOM – AGS, A Joint Venture

# Agenda

- AWSS and Background
- Level Of Service (LOS) Goals
- Modeling
  - Ignitions and Demands
  - SynerGEE
  - GIRAFFE
- Project Development and Assessment
- Program Recommended to SFPUC
- Next Steps

# AWSS and Background

San Francisco  
Following the  
1906  
Earthquake  
and Fires




# AWSS Overview

- Separate high pressure water system originally constructed in 1910 -1913
  - 77 Miles of 10 inch and larger Cast Iron Pipe
  - Two Salt Water Pump Stations
  - Three gravity storage facilities fed by domestic system
- Total system consists of high pressure pipe, cisterns, suction connections, saltwater pumps, fireboats, reservoir and storage tanks
- Pipe construction with extra thick walls
- Double lead and restrained joints
- Limited connections



Image Source: [www.flickr.com](http://www.flickr.com)

# AWSS System Map



# AWSS Operations

- Over time has been extended to cover more of the City, now 135 miles, 80% cast iron pipe
- Used by the San Francisco Fire Department (SFFD) and owned and maintained by the SFPUC City Distribution Division (CDD)
- Normally operates in three pressure zones
- Designed to allow one pressure zone with pressures up to 340 psi

# Modeling Process

# AWSS Capital Planning Study (CS-199)

- Goal:
  - To maximize the likelihood that the AWSS will effectively provide required fire fighting capabilities after a major seismic event.
- Recommended LOS Objectives:
  - “AWSS will reliably provide water to supply the “probable fire demands” after a M7.8 San Andreas earthquake”
    - Each fire response area will be XX% reliable in supplying probable demands.
    - AWSS will be YY% reliable in supplying probable demands City-wide.




# Modeling Overview

- Modeling objective:
  - To determine the amount of water the AWSS can deliver given a set of demands
- Hydraulic and reliability modeling to determine project hydraulic benefits
- Tools used:
  - SynerGEE
  - GIRAFFE (Cornell University)
  - EPANET
  - ArcGIS
  - R script


# Estimating Fire Demands

# Fire Demand Formulation




# 1

## Delineation of Fire Response Areas




- Based on SFFD Response Districts
- Further refined based on fire density

## 2 Ignition Location Selection



- **Red** – Block with Highest Occurrence of Ignitions
- **Blue** – Top 5 Demands per FRA

## Fireflow Magnitudes



- Stochastic set of ignitions (1000 iterations)
- 60-minute 3<sup>rd</sup> quintile selected as representative demand set
- “Suppression” accounted for by removing all fires at first minute

## 4

# Model Demand Locations




- Demand node highlighted in blue
- Location based on nearest network node to locations found in step 2

# Estimating System Reliability



# Hydraulic Model (SynerGEE) AWSS Existing Condition Model




- 6,274 junctions
- 6,312 pipe segments
- 178 valves
- 10 pumps
- 5 tanks
- Model reviewed and calibrated with flow test data

# SynerGEE Model Results



# EPANET Model (Converted from SynerGEE)




# Graphical Iterative Response Analysis for Flow Following Earthquakes (GIRAFFE)

# GIRAFFE Overview

- Developed at Cornell University by Tom O'Rourke and colleagues
- Uses open source EPANET engine
- Deterministic and probabilistic simulations
- 5 modules:
  - System Definition [Input]
  - Seismic Damage [Input]
  - Earthquake Demand Simulation [Module]
  - Hydraulic Network Analysis [Computation]
  - Results Compilation [Output]

# GIRAFFE GUI (Windows XP)




# GIRAFFE Model Inputs

## – Pipeline Fragilities

- Based on PGV values by block
- PGV estimated from regressions between block centroid distance to San Andreas fault and grouped by shear wave velocity ( $V_{s30}$ )

## – System Information File (EPANET file)

# GIRAFFE Process Flow






# GIRAFFE Model Controls


- Simulation type:
  - Deterministic (single)
  - Monte Carlo Fixed
  - Monte Carlo Unfixed
- Convergence Criteria
- Break/Leak Ratio
- Leak type probabilities
- Random seed generator

# GIRAFFE Output

- Pipe break/leak list
- System damage file
- Serviceability result
- Information by time-step for:
  - Nodes
  - Pipes
  - Pump stations
  - Valves
  - Tanks
- Output summary



# Solution to Output Limitation




# Sensitivity Analyses Performed

- Demand location and magnitudes
- Fireboat assumption
- Partial demands
- Infirm zones


# Cistern, Suction Connection, Alternate Water Modules

## 5


# Modeling Summary



# Cisterns




# Suction Connections



- Green: existing suction connection
- Red: proposed suction connection (Alternative C only)



# Alternate Water Sources



# Reliability Scoring

# Model Results Terminology

- Reliability:
  - Available supply / demand requested
  
- Citywide reliability:
  - Average of each Fire Response Area's reliability

# Reliability Score Calculation

- Example FRA
- FRA demand: 5,000 gpm
- Total water available: 4,170
  - HPS contribution: 3,850 gpm (average from 15 iterations)
  - Cistern contribution: 320 gpm (average over 1000 sets)
  - Suction connection contribution: 0 gpm
  - Alternative water contribution: 0 gpm
- FRA reliability: 83% (4,170/5,000)

# Reliability Score Context

- System tested at 3<sup>rd</sup> quintile demands with 46 simultaneous ignitions
- Considers initial fire department response but doesn't model response or resources required
- HPS evaluated with an aggregated demand for each FRA while other water sources are evaluated by block
- Reliability index scores are a relative representation of system performance

# Alternative Programs and Assessment

# Alternative Program Development

- Developed 3 Program Alternatives each composed of multiple projects
  - Alternatives A & B: new pipe extensions and water supply and some cisterns
  - Alternative C: all cisterns
- Performed Pairwise comparison of the Alternatives
- Recommended Preferred Alternative for further consideration

# Program Alternative Scoring

Alternative		Ranking		
		1	2	3
Evaluation Criteria	Delivery Reliability	B	A	C
	Firefighting Capability	A/B tie		C
	Cost	B	A	C
	Schedule	A/B tie		C
	Operations and Maintenance	B	A	C
	Insurance Premiums	A/B/C tie		
	Environmental / Community Impacts	B	A	C
	<b>Final Ranking</b>	<b>B</b>	<b>A</b>	<b>C</b>



# Next Steps

# Next Steps for AWSS

- Evaluation of other potential combinations of systems to meet potential fire demands
  - Improvements to Potable Water system
  - Construction of Multiuse or hybrid pipes
- Evaluation of relative risk of event
- Construction of projects funded by 2010 ESER bond
- Recommendations for future bond election

# Thank You

Anne.Symonds@aecom.com

dmyerson@sfgwater.org

Aaron.Lee@aecom.com

