

May 7, 2014



WATER DISTRIBUTION SYSTEM PRESSURE MANAGEMENT

Ryan Withers, P.E.
RH2 Engineering, Inc.

PRESSURE OPTIMIZATION

- Water loss through cracked water main
- 1/2 - inch diameter hole in pressurized water main
- Bernoulli's Equation

$$\frac{P_1}{\gamma} + z_1 + \frac{V_1^2}{2g} = \frac{P_2}{\gamma} + z_2 + \frac{V_2^2}{2g}$$

$$Q = c_d A \sqrt{(2g)(H)}$$

PRESSURE OPTIMIZATION

- $Q = 54$ gpm at 105 psi
- $Q = 52$ gpm at 100 psi
- 2 gpm difference
 - 2,800 gallons per day
 - 1.05 MG per year



FACILITY SET POINTS


- How are pump set points determined?
- How are reservoir fill and draw levels determined?

BONNEVILLE POWER ADMINISTRATION STUDY


- Grant funding provided by Bonneville Power Administration
- Studied 4 water systems of various sizes
- Visited 87 sites
- Collected data and evaluated 170 different pumps



PRESSURE OPTIMIZATION



PUMP CURVE ANALYSIS



POWER BILL ANALYSIS



SUMMER 2006 AND 2007 BILLING COMPARISON

	Summer 2006		Summer 2007	
Customer Charge		\$ 24.90		\$ 27.20
Energy Charge	20,000 KWHS @ \$.068036 Per KWH	\$ 1,360.72	20,000 KWHS @ \$.074782 Per KWH	\$ 1,495.64
Energy Charge	116,600 KWHS @ \$.054888 Per KWH	\$ 6,399.94	93,760 KWHS @ \$.060754 Per KWH	\$ 5,696.30
Demand Charge	50 KW @ \$.00 Per KW	\$ 0.00	50 KW @ \$.00 Per KW	\$ 0.00
Demand Charge	159.28 KW @ \$5.24 Per KW	\$ 834.63	155.44 KW @ \$5.54 Per KW	\$ 861.14
Reactive Power Charge	66,360 KVRH @ \$.00253 Per KVRH	\$ 167.89	46,400 KVRH @ \$.00265 Per KVRH	\$ 122.96
Electric Conservation Program Charge	136,600 KWHS @ \$.001406 Per KWH	\$ 192.06	136,600 KWHS @ \$.001406 Per KWH	\$ 190.89
Power Cost Adjustment	136,600 KWHS @ \$.008066 Per KWH	\$ 1,101.82	113,760 KWHS @ \$.00 Per KWH	\$ 0.00
Wind Power Production Credit	136,600 KWHS @ \$.000650CR Per KWH	\$ 88.79CR	113,760 KWHS @ \$.001415CR Per KWH	\$ 160.97CR
Current Electricity Charges		\$ 9,993.17		\$ 8,233.16



RH2'S EVALUATION



RH2 analyzed the existing Asbestos Cement pipe to determine true condition and load carrying capacity.

CONSTRUCTION EQUIPMENT LOADS

Caterpillar 14M Motor Grader

<http://www.cat.com/cmms/images/C201836.pdf>

Has 6 tires (1 tandem rear axle, 1 front axle)

Max Gross Vehicle Weight

Total	65,998 lbs.		
Front Axle	21,912 lbs.	Front Axle Single Wheel Load =	10,956 lbs.
Tandem Rear Axle	44,086 lbs.	Tandem Single Wheel Load =	11,022 lbs.
Tandem Axle Wheelbase	65 in.		
Front Tires to Rear Axle Wheelbase	258 in.		
Width between Tire Center Lines	93 in.		

Caterpillar 385C L Hydraulic Excavator

<http://www.cat.com/cmms/images/C400866.pdf>

Has 2 tracks

Approx. Operating Weight 192,000 lbs.

Ground Track Length	16.83 ft.	Track Load =	5,704 lbs./ft. track length
Track Width	30 in.		
Width between Track Center Lines	9 ft.		

DESIGN EXTERNAL LOAD LIMITS


Pg. 23 AWWA C401-93 - Figure 14B 6" Class 100 AC Pipe			
Operating Water Pressure:		100 psi	
Reduced Water Pressure (1):		60 psi	
Reduced Water Pressure (2):		40 psi	
Design External Load Limits (lbs. per lineal ft. of pipe):			
At operating pressure	At 60 psi pressure	At 40 psi pressure	No water in pipe
1,150	2,600	3,150	4,000

Pg. 24 AWWA C401-93 - Figure 14C 8" Class 100 AC Pipe			
Operating Water Pressure:		100 psi	
Reduced Water Pressure (1):		60 psi	
Reduced Water Pressure (2):		40 psi	
Design External Load Limits (lbs. per lineal ft. of pipe):			
At operating pressure	At 60 psi pressure	At 40 psi pressure	No water in pipe
1,500	2,800	3,200	4,000

Pg. 25 AWWA C401-93 - Figure 14D 10" Class 100 AC Pipe			
Operating Water Pressure:		100 psi	
Reduced Water Pressure (1):		60 psi	
Reduced Water Pressure (2):		40 psi	
Design External Load Limits (lbs. per lineal ft. of pipe):			
At operating pressure	At 60 psi pressure	At 40 psi pressure	No water in pipe
1,900	3,100	3,600	4,400



LOAD BEARING CAPACITY



Conclusion:
Some pipes
were overloaded
and had to be
replaced.

TECHNIQUES

Initiating pressure management techniques in your system

- Start small – focus on one pressure zone
- Review pressure and fire flow requirements in zone
- Closed zones
 - Perform hydraulic analyses
- Zones with storage
 - Perform storage analysis calculations and hydraulic analyses
- Adjust pump set points in small increments, preferably starting during low demand periods (typically night) to reduce system pressures



SUMMARY

- Small pressure reductions are a cost effective method to reduce water loss
- Pressure management can reduce the potential for AC main breaks
- Pressure management can reduce pumping and treatment costs

Ryan Withers, P.E.
RH2 Engineering, Inc.
rwithers@rh2.com
425.951.5334



QUESTIONS?
