



CITY OF  
WALLA WALLA



**Challenge Testing Slow Sand  
Filtration with Raw Wastewater  
and Concentrated  
Cryptosporidium  
Pierre Kwan, PE**



01 INTRODUCTION

02 2013 WINTER SPIKING TEST

03 2014 WINTER SPIKING TEST

04 CONCLUSIONS



# 01 Introduction

# City of Walla Walla Mill Creek WTP

- First constructed in 1920s
  - Sedimentation only
- Last major expansion in 1998
  - LT1ESWTR compliance
  - Added ozonation system after sed basins
- 24 MGD capacity
- Mill Creek surface water
- Groundwater from four wells



## LT2ESWTR Compliance

- *Cryptosporidium* removal credit
  - Ozonation credit is temperature dependent
  - Mill Creek water can be very cold (snowmelt fed)
  - <1.0-log credit during winter
- Treatment evaluation
  - Reviewed many processes
  - Selected slow sand filtration
    - Low cost
    - No new chemicals
    - No backwash
    - Simplicity

## Pilot Testing

- Filter sand parameters
  - Uniformity coefficients
  - Effective sizes
  - Metal leaching
  - Loading rates
- Roughing filters
- Floating covers
- Pre-ozonation



## Concerns

- Cold water
- Low levels of raw water coliform
  - Difficult to show 2-log removal
- Loading rates
  - Lower rates = bigger filters = higher construction costs



# LT2 Compliance and Pilot Testing

- Slow sand pilot
  - 2010 – 2014
  - Four winters
  - WSDOH guidelines
- Spiking tests in winters of 2013 and 2014





# *Cryptosporidium* & Coliform Testing

- Winter testing
- Spiked influent
- Inactivated, intact *Crypto* oocysts
  - Nominal 500 oocysts/L
- Primary wastewater effluent
  - Nominal 500 cfu/100 mL coliform



# ***Cryptosporidium* & Coliform Testing**

- Weekly *Cryptosporidium* sampling and analysis
  - 50 L samples instead of 10 L samples
  - Bio-Vir in California
  - 7-10 calendar day turnaround
  
- Daily coliform sampling and analysis
  - Did not want to be done at City's labs
  - Walla Walla Regional Testing Services
  - 24-hour turnaround




# 02 2013 Winter Results

# Winter 2013 Spiking Test


Filter	Sand	Effective Size (mm)	Uniformity Coefficient	Nominal Filter Depth (inches)	Roughing Filter?
2	Jones (Umatilla)	0.27	2.59	36	Yes
3	Jones (Umatilla)	0.27	2.59	18	No
4	Emmett (Boise)	0.17	2.25	36	No

- March 19 – May 7, 2013
- Loading Rate 0.05 gpm/SF, later increased to 0.10 gpm/sf

# Pathogen Log Removal – 0.05 gpm/sf



# Pathogen Log Removal – 0.10 gpm/sf



## 2013 Summary

- Coliform removal  $\neq$  *Cryptosporidium* removal
- Coliform is surrogate because of analysis cost and speed
- LT2ESWTR 2.0-log *Cryptosporidium* removal is met at  $<2.0$ -log coliform removal
- Under-reporting performance



## DOH Response

- Mild winter
- Water temperature wasn't really cold
- 10.1 deg C average

Temperature (deg C)	Rate
$\geq 5.0$	0.10 gpm/sf, max
$< 5.0$	0.05 gpm/sf, max
Any	0.02 gpm/sf, min.



## I Didn't Like The Answer

- 0.05 gpm/sf = very big filters
- Still plenty of land but higher construction costs
  
- Re-Test
- Wait until next January
- Hope that Mother Nature and Old Man Winter cooperates



03

2014 Winter Results

# 2014 Spiking Test


Filter	Sand	Effective Size (mm)	Uniformity Coefficient	Nominal Filter Depth (inches)	Roughing Filter?
1	Jones	0.17	2.01	44	Yes
2	Jones	0.17	2.01	32	Yes


- January 13 – February 27
- Loading Rate at 0.07 gpm/sf, later to 0.1 gpm/sf





## Differences

- Jones identified large area of very fine sands at quarry
- Sand washed by Jones using their industrial equipment
  - Exact same procedure for full-scale procurement
  - Previous sands washed by City
- Thicker sand filters
  - 44" instead 36"











## 2014 Testing Summary

- Coliform removal  $\neq$  *Cryptosporidium* removal
- No real difference between tall column and short column
- Cold water temperatures
- Problematic testing
  - Ice formation
  - No headloss measurements

## DOH Response

- Cold winter...
- Didn't sample at the absolute coldest water temperatures

Temperature (deg C)	Rate
$\geq 5.0$	0.10 gpm/sf, max
<i>3.0 – 5.0</i>	<i>0.07 gpm/sf, max</i>
$< 3.0$	0.05 gpm/sf, max
Any	0.02 gpm/sf, min.



# 04 Spiking Test Conclusions

# Conclusions

- Relying on coliform surrogate under-reports performance
  - $>2.0$ -log coliform removal probably means  $>2.0$ -log *Cryptosporidium* removal → LT2 compliance
  - $<2.0$ -log coliform removal can still mean  $>2.0$ -log *Cryptosporidium* removal → still achieves LT2 compliance
- Strong water temperature dependency
  - Biologically active filters

# Acknowledgements



**City of Walla Walla – Frank Nicholson, Tom Krebs,  
Mike Neher, Curt Skifstad**

**HDR – Teresa Peterson, Al Vetrovs, David Kuhns**



CITY OF  
WALLA WALLA



Challenge Testing Slow Sand Filtration  
with Raw Wastewater and Concentrated  
Cryptosporidium  
Pierre Kwan, PE

[Pierre.Kwan@hdrinc.com](mailto:Pierre.Kwan@hdrinc.com)

206.826.4735