



Retrofitting Aeration Treatment into a 1930s Pump Station

Pierre Kwan
HDR – Seattle, WA
HDR





01 Background

02 Design Issues and Constraints

03 Start-Up and Commissioning

04 Summary




01

Background

Background

- Facility was constructed in 1939
- Part of the Franklin Roosevelt's Works Progress Administration
- 16.7 MGD with 0.5 MG clearwell
- Sends groundwater up to north and west end of the system
- Supplied by six wells



Background

- Usage has decreased over the decades
 - Groundwater use declined as Green River supply developed
- Currently a back-up system
 - Used infrequently
 - Planned shutdown of reservoirs
 - Emergencies
- Water treated with a tablet chlorinator



Project Goal

- South Tacoma Wellfield groundwater requires additional treatment
 - Low pH → corrosive to copper and brass plumbing
 - Radon
- Goal is to provide cost-effective improved water quality with minimum disruption





02

Design Issues and Constraints

Design Issue #1 – Location

- Pump station located in an urban residential area
- Surrounded on three sides by homes
- Concerns about chemical deliveries
- Limited available free space



Design Issue #2 – Structure

- Facility was finished in a time without seismic standards
- Concrete floor is very thin for today's standards
- Supporting beams are widely spaced



Design Issue #3 – Power Supply

- Main power supply is medium voltage 4160V for the pumps
- Available 480V power was limited
- Existing transformers were below-ground and very old.



Design Issue #4 – Record Drawings

- Complete set of pump station drawings were from 1939
- Several modifications have been made that were not fully documented



Evaluation

- Two alternatives: caustic soda and aeration
- Caustic soda
 - Highly effective
 - Requires chemical delivery and storage
 - Complexity of chemical feed control
- Aeration
 - Effective depending on water CO₂ content
 - No chemicals
 - No chemical control strategy needed
- Aeration was selected

Evaluation

- Started with in-depth review of all systems
- Structural analysis
 - Floors
 - Support columns
 - Exterior walls
- Review of power systems
- Analyzed control panels

Aeration Design

- Diffused aeration inside clearwell
- Same system as wastewater aeration basins
- Baffle wall to help channelize flow over diffuser heads



Equipment Placement

- Pump station had an old storage room filled with old files
- Removed all files
- Placed blower in the room



Equipment Placement

- One wall of the storage room is actually the back of medium voltage control panels
- Control panels and equipment had to be placed away from panels



Aeration Blower

- Blower design was crucial
- Weak floor means:
 - Must minimize equipment weight
 - Must minimize equipment vibration
- Selected centrifugal blower
 - Only location was to place blower directly over a beam



Ancillary Systems

- Air supply
 - Blower air to diffusers
 - Cooling air
- Ductwork placed in main pump room
- Intake and exhaust louvers matched into existing building openings.



Ancillary Systems

- Intake silencer
 - Was originally indoors
 - Silencer could not be accommodated
 - Placed outdoors
- Only visible modification to the building structure





03

Start-Up and Commissioning

pH and Well Use

- System generally worked
- Finished water pH was 7.5
- Problem was with one well
 - Well 3A
 - Raw water pH is 7.2
 - Treated water pH is 7.3
 - Reordered to be used last now
- Additional testing is ongoing





04 **Summary**

Lessons Learned

- Retrofitting can be readily accomplished
- Spend the time to do a careful site investigation
 - Don't depend on record drawings alone
- Careful structural evaluation is always needed
 - Old concrete may not be adequate for new loads
- Attention to electrical systems is important

Acknowledgements

Tacoma Water

Kim DeFolo

Craig Downs

Mike Kelley

Brian Smith

Chris McMeen

Glen George

John Luu

Craig Carrara

Rob Walker

Mike Duffy

Duc Vuong

Vanessa Mitchell

HDR

Allen Fitz

Alex Mockos

Al Vetrovs

Doug Prindle

Isabel Rincon

Matt McFadden

Donn Hogan

Karl Sutton

Katie Pardee

Bill Newell

Lynda Bramlett

S&B Inc.

Confluence Engineering



Pierre Kwan
HDR – Seattle
206-307-7362
pierre.kwan@hdrinc.com

