

Building and Calibrating the New Bellevue Water System Model

Ed Wicklein, Carollo Engineers

Doug Lane, City of Bellevue

Aurelie Nabonnand, Carollo Engineers


PNWS - AWWA

May 1, 2015



City of Bellevue Service Area

- 2014 population
140,000+
(~180,000 by 2040)
 - 2014 employment
136,000+
(~214,000 by 2040)
 - Bellevue plus portions of
7 other municipalities
 - Regional Supply (SPU)



Water System Assets


- 600+ miles of pipe
- 64+ pressure zones
- 26 reservoirs (plus share of 4 outside service area)
- 23 pump stations
- 13 inlet stations
- 144 pressure reducing valve (PRV) stations

Bel-Red Inlet




Bellevue Previously Used EPA-NET for Hydraulic Analysis

- Model results did not match field
- Manual iteration of each fire flow location
- Limited model capabilities



The City Needs an Integrated “all-pipe” Model of System

- East model previously developed
- New models for West and South:
 - Should be easily maintainable
 - Will be used for the ongoing WSP update
 - Will be used to aid in proposed redevelopment





Bellevue Provided Existing Data for Model Development of West and South Operating Areas

- EPA-NET models
- GIS data on system parts
 - Pipes, hydrants, key infrastructure locations
- Operational data
 - Pump controls
 - PRV, altitude valve, and throttle control valve settings
 - Tank information
- Existing demands by customer meter

Bellevue Collected New Data for Model Development

- Hydrants tests, including PRV conditions for many of the tests
- Static long-term pressure fluctuations
- The city conducted winter and summer diurnal pattern studies for 6 customer classes
 - Hotels, schools, retail, commercial, single-family residential, multi-family residential

Custom Diurnal Patterns For Customer Classes



Example of Fire Hydrant Tests Summary


- Hydrant tests performed by the City

 City of Bellevue, Washington Utilities Department		Fire Hydrant Flow Test Report Recorded by: D. Lane → Date: 10/29/2013 → Day: Tuesday → Weather: Clear → Temp: 50 F → Flow Hydrant ID/Address: 100502 → Water System Operators: Tom, Adam, Rick, Scott → Others Present: Doug → Fire Flow Tested? Y <input checked="" type="checkbox"/> N <input type="checkbox"/> Time Start: 1:05 Stop: 1:15 → Flush Conducted? Y <input checked="" type="checkbox"/> N <input type="checkbox"/> Time Start: 1:15 Stop: 2:15 → Downstream Drainage System Ownership: <input checked="" type="checkbox"/> COB <input type="checkbox"/> Private <input type="checkbox"/> Other → Downstream Drainage Facilities: <input checked="" type="checkbox"/> Catch Basins <input type="checkbox"/> Curbs <input type="checkbox"/> Swale <input type="checkbox"/> <input type="checkbox"/> Detention Pond <input type="checkbox"/> LID <input type="checkbox"/> Other → Waterways: → <input type="checkbox"/> Other → <input type="checkbox"/> Erosion Potential? Y <input type="checkbox"/> N <input checked="" type="checkbox"/> Comments: → Notes/Photographs: Pre-test site set-up →  Water collected in driveway (no damage) →  One port open →  Peak flow (two ports open) →  Catch basin on west side of street at peak →  Water flowing down east side of street at peak → 
--	--	---




GIS Cleaned, Organized and Formatted

- Junctions created, elevation from 2-foot contours
- Piping connectivity checked



Example of connectivity issues



Table

W_PipesAsBuilt

OBJECTID *	Shape *	ASSETNUM	PressureZone	LOCATION	INFOSSOURC	FILECOMME	WFETCLIA	VERIFIEDDA	ACAD_HAN	MATERIAL_	Maintenan	Diameter_	Autocad_	LocationI	Pipepressu	Liningstat	Createuse	WModelno	Filenumbe	Datecreat	Class_co	Gislength	
1	Polyline	421024	CL0335	<Null>	ASB	<Null>	WLINE	<Null>	1EA	DI	<Null>	4	WA-DIST-EX	<Null>	<Null>	<Null>	COBUTLADM	0	<Null>	01/28/2005 1	DIST	257	
									74F	AC		1	6	WA-DIST-EX	<Null>	<Null>	<Null>	COBUTLADM	0	<Null>	01/28/2005 1	DIST	351
									D69	AC		1	6	WA-DIST-EX	<Null>	<Null>	<Null>	COBUTLADM	0	<Null>	01/28/2005 1	DIST	134
									D6C	DI		1	8	WA-DIST-EX	<Null>	<Null>	<Null>	COBUTLADM	0	<Null>	01/28/2005 1	DIST	139
									D6D	AC			6	WA-DIST-EX	<Null>	<Null>	<Null>	COBUTLADM	0	<Null>	01/28/2005 1	DIST	32
									D6E	AC			6	WA-DIST-EX	<Null>	<Null>	<Null>	COBUTLADM	0	<Null>	01/28/2005 1	DIST	28

Initial GIS Data

Table


Pipelines_AsBuilt

FID	Shape *	OBJECTID	ASSETNUMBER	Source	Junc_From	Junc_To	ID	Length	Calc_Length	Diameter	ROUGHNESS	MINORLOSS	YR_INST	ZONE	Materia	Notes	DESCRIPT
0	Polyline	1	421024	W_PipesAsBuilt	COB1000001	COB2000001	C01000001	225	253.617789	4	0	0	1902	CL0335	DI		7580 NE 28TH PL
1	Polyline	2	133474	W_PipesAsBuilt	COB1000002	COB2000002	C01000002	351	355.776373	6	0	0	1948	CL033	AC		1605 73RD AVE NE
2	Polyline																2203 EVERGREEN POINT RD
3	Polyline																
4	Polyline																73RD PL NE AND 74TH PL NE
5	Polyline																NE 18TH ST AND RAMBLING LN
6	Polyline																
7	Polyline	8	111046	W_PipesAsBuilt	COB1000012	COB2000012	C01000012	18	200.442494	6	0	0	1964	CL033	AC		

Formatted GIS data imported in InfoWater


Site Configurations Added

- Pump stations, reservoirs, inlets, and interties from site configuration drawings and as-built drawing



Facility Data Input in InfoWater

- Example: pump station required information



Model#SC12C-5 Serial #4838A				1793 R.P.M.			
GPM	HEAD	HP	EFF.				
0	468.26	32.80	52.80				
200	426.20	37.00	59.31				
300	418.76	43.53	72.87				
350	411.34	46.12	78.82				
400	401.28	49.33	82.17				
500	371.41	55.13	85.07				
600	318.78	57.96	83.33				
700	256.02	59.20	76.45				
800	188.46	58.70	64.86				
900	109.94	56.48	44.24				

Certified By Date

Somerset Inlet pumps to Somerset 2

	Pump come on point	Pump shut off point	GPM Output
Pump 1	7	8.5	800
Pump 2	0	0	1500
Pump 3	0	0	1500
Pump 4	5.5	8	1200


Somerset 2 pumps to Forest Hills

Pump 1		1100
Pump 2		1100
	17	17.5
		850

City Provided Control Setpoints


INLET GATES & PUMP STATION

The flow rate at the inlet valve controls the dynamic head.




Model Loading

- Demand geocoding in GIS and allocation
- Demands provided by parcel land use type and allocated to the nearest model junction in the appropriate pressure zone
 - Demands are actual current demands
 - City input necessary to determine which zone to allocate the parcel to for certain areas




Example parcel where it is unclear which pressure zone it serves



West and South Hydraulic Model with SPU Supply

- 40 pressure zones
- 202 PRVs (108 stations)
- 9 Altitude valves
- 19 Storage tanks
- 1 Hydropneumatic tank
- 45 Pump (16 stations)
- 8 SPU inlets



Initial Model Checks

- System pressures comparison used to locate major errors in model creation
- Facility characteristics from pumps, sources, valves were used to identify problems in system operations

The screenshot shows a Windows application window titled "Engineering Validation Manager". The main area is a grid table with columns: "Check Rule", "ID", "Warning Message", "Warning Level", and "Valid Value Range". The "Warning Message" column contains error descriptions, and the "Warning Level" column shows values like 1, 2, or 3. A large orange arrow points to the row where the message "Two or more nodes are located too closely" is listed. The bottom of the window has buttons for "Add Results to Domain", "Validate", "Options", and "Close".


Check Rule	ID	Warning Message	Warning Level	Valid Value Range
1	ER-1001	Size difference among all connected pipes exceeds the exp	2	50% <= Value <= 200%
2	ER-2001	Link vertices are coincident with the vertices of another link	3	
3	ER-2002	Link has non-existing U/S or D/S node	1	
4	ER-1101	Node Elevation is blank	1	
5	ER-1102	Node Elevation outside expected range	3	0 <= Value <= 2000
6	ER-1103	Node Demand outside expected range	3	Value <= 104
7	ER-1104	Node Demand Pattern does not exist	1	
8	ER-1105	Two or more nodes are located too closely	1	Value <= 1
9	ER-1106	Node is located close to a link (the link may have to be split)	3	Value <= 3
10	ER-1201	Tank Type is not specified	2	
11	ER-1202	Tank Type is not valid	1	0 <= Value <= 1
12	ER-1203	Tank Initial level is inadequate	2	
13	ER-1204	Tank Minimum level is greater than or equal to Maximum lev	1	
14	ER-1205	Cylindrical Tank Volume outside expected range	3	0.5 <= Value <= 100
15	ER-1206	Cylindrical Tank Diameter outside expected range	3	5 <= Value <= 300
16	ER-1207	Cylindrical Tank Minimum Volume outside expected range	3	0 <= Value
17	ER-1208	Variable Area Tank refers to an existing volume-depth curve	1	
18	ER-1209	Variable Area Tank has inadequate volume-depth curve	3	
19	ER-1301	Reservoir Type is not specified	2	
20	ER-1302	Reservoir Type is not valid	1	0 <= Value <= 1
21	ER-1303	Fixed Head Reservoir Head outside expected range	3	0 <= Value <= 2000
22	ER-1304	Variable Head Reservoir had invalid pattern	1	
23	FR-1401	Pump Type is not specified	2	
24	ER-1402	Pump Type is not valid	1	0 <= Value <= 3



Model ready
for Calibration


Fire Hydrant Calibration Criteria

- Review of AWWA M32 and the 1999 ECAC calibration recommendations: M32 master planning static calibration goals from hydrant test data:
 - HGL predicted should be within +/- 10 feet (**+/- 4.3 psi**) of measured values.



Model Calibration With Field Data

- 70 hydrant tests
- Numerous residual pressure recorders
- SCADA telemetry




Fire Hydrant Calibration

- Demands set to test time using diurnal pattern
- Pumps and tanks set from SCADA
- Parameters adjusted to match field results
 - PRV settings mainly to match static conditions
 - Pump curves
 - Tank elevations
 - Hazen-Williams C factors on pipes mainly to match residual conditions
 - Try to hold C factors constant within every pressure zone


City of Bellevue, Washington Utilities Department		Fire Hydrant Flow Test Report Recorded by <u>B. Roberg</u>
Project Name: <u>WOA Model Calibration W-1</u>		
Flow Hydrant ID/Address: <u>101117</u>		
Water System Operators: <u>Bob H. Adam</u>		
Others Present: <u>Doug, Ben</u>		
Test Time		
Fire Flow Tested? Y <input checked="" type="checkbox"/> N <input type="checkbox"/>	Time Start: <u>9:46</u>	Stop: <u>9:55</u>
Flush Conducted? Y <input checked="" type="checkbox"/> N <input type="checkbox"/>	Time Start: <u>9:55</u>	Stop: <u>10:50</u>
Visual Condition of Water: <u>Cloudy After test before flush</u>		
Downstream Drainage System Ownership: <u>COB</u> <input type="checkbox"/> Private <input checked="" type="checkbox"/> Other Medina		Downstream Conditions (Prior to Test): Sediment? <u>Y</u> <input type="checkbox"/> N <input checked="" type="checkbox"/> Comments:
Downstream Drainage Facilities: <u>Catch Basin(s)</u> <input type="checkbox"/> Curbs <input type="checkbox"/> Swale <input type="checkbox"/> <u>Detention Pond</u> <input type="checkbox"/> LID <input type="checkbox"/> Other <input type="checkbox"/> <u>Waterways</u> : <u>Lake Washington</u>		Standing Water? <u>Y</u> <input type="checkbox"/> N <input checked="" type="checkbox"/> Comments:
Other:		
Hydrant Flow		
Dechlorination Method: <u>Vita-D-Chlor</u> Quantity Used/ # Tablets: <u>Kept canister full</u>		
Hydrant Port 1: Dia: <u>-</u> psi: <u>550 gpm</u> Ports Open: 1 <input checked="" type="checkbox"/> 2 <input type="checkbox"/> N/A <input type="checkbox"/>		
Hydrant Port 2: Dia: <u>-</u> psi: <u>0 gpm</u> Total Flow: <u>550 gpm</u>		
Static Pressure 1: <u>126 psi</u> Residual Pressure 1: <u>98 psi</u> Static/Residual Location 1: <u>BO 124368</u>		
Static Pressure 2: <u>99 psi</u> Residual Pressure 2: <u>76 psi</u> Static/Residual Location 2: <u>101122</u>		
Location Pressure Measurements		
Sewer <input type="checkbox"/> Sheet Flow <input type="checkbox"/> Other <input checked="" type="checkbox"/> <u>set sign to contain flow at catch</u>		
Static and Residual Pressure Test Results		
Follow-Up:		
Pressure Lower Than Expected?: Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A <input type="checkbox"/>		Potential Backflow: Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A <input type="checkbox"/>
Drainage Problems Observed: Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A <input type="checkbox"/>		Cleanup Needed: Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A <input type="checkbox"/>
Comments: _____		

Hydrant Test Results Summary For All Tests




EPS Run

- Necessary adjustments for EPS run
 - Time step
 - Pump controls
 - Altitude valves headloss curves




EPS Run – Altitude Valves

- Altitude valves modeled as float valves and require headloss vs flow type curve.
- Typical curve is adjusted to match SCADA data provided by the City.




EPS Inlet Results Summary for MDD

Reservoir Group Graphs




EPS Tank Results Summary for MDD

Tank Group Graphs



Subsequent work by the City

- Continual updates
- Added East Operating Area (now entire system)
- Automatic fire flow analysis (all 6,000 hydrants at once)
- Water age mapping
- What-ifs and alternatives analysis



System-Wide Water Age Simulation

Model Development Summary

- A new all pipes integrated model was developed for Bellevue's water service area
- The model is well calibrated for static and EPS making it a good tool for:
 - Fire flow analyses
 - System operations
 - Future projections
 - Water quality



Questions on Building and Calibrating the New Bellevue Water System Model

ewicklein@carollo.com

dlane@bellevuewa.gov

PNWS - AWWA

May 1, 2015