

# **Bellevue Utilities Asset Management Approach**

**Pacific Northwest Section  
American Water Works Association**

**Bill Heubach  
Martin Chaw  
Kipp Fockler**


**April 29, 2015**

# Bellevue, Washington



# Service Area


- Bellevue
- Beaux Arts, Clyde Hill, Hunts Point, Medina, Yarrow Point and unincorporated areas
- 135,000 residents
- Three Utilities
  - Water
  - Wastewater
  - Stormwater (COB)



# Water Utility

- 619 miles of watermain
- 30,000 plus saddles and services
- 25 reservoirs
- 23 pump stations
- 142 PRV's and 13 Inlets
- Approximately 300 commercial meters
- 41,000 Meter Connections


# Watermain Inventory



# Wastewater Utility

- Pipelines
  - 525 miles of sewer main
  - 130 miles of stubs
  - 19.4 miles of lake line
  - 5.8 miles of force main
- 36 pump stations
- 10 flush stations
- 13449 manholes

# Sewer Main Materials



# Lake Lines







# Stormwater Utility

- Stormwater conveyance
  - 400 miles of stormwater Pipe (CCTV and defect repair)
  - 86 (?) miles of ditches
  - A couple hundred steam culverts
- 19188 catch basins and 2283 manholes
- 118 oil/water separators
- 11 regional detention ponds


# Stormwater Pipe Data Collection



## Pipe Age vs. Length



# Asset Construction Cost - \$3.5 Billion



# Asset Management


- Optimizing of the cost of
  - acquiring,
  - operating,
  - maintaining,
  - renewing and
  - replacing infrastructure assets...
- While meeting service levels expected by the community and required by regulators...
- At an acceptable level of risk

# Asset Management Program Goal – Good Stewardship of the Community’s Investment in Utility Services

- Cost Effective Allocation of Resources
- Facilitate More Informed Decision Making
- Long Range Planning

# EPA Framework

## Asset Management Ten Core Processes




# Asset Management Five Core Objectives


1. Determine state of the assets
2. Determine what customer service levels are required
3. Determine asset criticality
4. Determine the strategies that provide the required level of service at the lowest life cycle cost
5. Determine the funding strategy



# Asset Management Team



# Asset Management Ten Core Processes



# CMMS - Maximo

The screenshot displays the Maximo CMMS web application interface. The browser address bar shows the URL: <http://spumaximo01.maximo.ca/fevents/loadapp.js?ac=assetBusinessUnit:1806&conf>. The page title is "Assets" and the breadcrumb navigation indicates "EPU Production Instance - MainP".


The main content area features a table of assets. The table has the following columns: Asset, Description, Location, Description, Assigned Crew (Vehicles), Serial#, CCEFFID, and AMI. The table contains 20 rows of asset data, all of which are "WATER MAIN" assets.

| Asset  | Description    | Location | Description                           | Assigned Crew (Vehicles) | Serial# | CCEFFID | AMI |
|--------|----------------|----------|---------------------------------------|--------------------------|---------|---------|-----|
| 302749 | 8" WATER MAIN  | 21885    | 4000-4009 56TH AVE SW, 90196          |                          |         |         |     |
| 76946  | 8" WATER MAIN  | 1521     | 3600-3799 36TH AVE S, 90144           |                          |         |         |     |
| 40686  | 8" WATER MAIN  | 28738    | 5300-5499 S FOUNTAIN ST, 90178        |                          |         |         |     |
| 89428  | 8" WATER MAIN  | 12388    | 4522-4699 E LAUREL DR NE, 90195       |                          |         |         |     |
| 77487  | 8" WATER MAIN  | 29187    | 10400-10599 21ST AVE SW, 90148        |                          |         |         |     |
| 914628 | 12" WATER MAIN | 332_WTR  | MAP 332 - WATER MAINS & APPURTENANCES |                          |         |         |     |
| 956528 | 8" WATER MAIN  | 628_WTR  | MAP 628 - WATER MAINS & APPURTENANCES |                          |         |         |     |
| 76256  | 4" WATER MAIN  | 38528    | 8600-8625 41ST AVE SW, 90136          |                          |         |         |     |
| 57385  | 8" WATER MAIN  | 22563    | 2000-2899 15TH AVE S, 90144           |                          |         |         |     |
| 52528  | 8" WATER MAIN  | 7592     | 100-299 N 75TH ST, 90163              |                          |         |         |     |
| 48950  | 8" WATER MAIN  | 27650    | 6700-6899 40TH AVE S, 90118           |                          |         |         |     |
| 16668  | 8" WATER MAIN  | 6832     | 8500-8599 27TH AVE NE, 90115          |                          |         |         |     |
| 54181  | 8" WATER MAIN  | 24928    | 6200-6399 17TH AVE SW, 90106          |                          |         |         |     |
| 305914 | 12" WATER MAIN | 28549    | 8500-8599 14TH AVE S, 90100           |                          |         |         |     |
| 17416  | 8" WATER MAIN  | 11846    | 6000-6499 25TH AVE NE, 90115          |                          |         |         |     |
| 80003  | 8" WATER MAIN  | 11895    | 1300-1399 NE 63RD ST, 90115           |                          |         |         |     |
| 72866  | 4" WATER MAIN  | 10628    | 6200-6299 22ND PL NE, 90115           |                          |         |         |     |
| 80615  | 8" WATER MAIN  | 5814     | 11300-11499 38TH AVE NE, 90125        |                          |         |         |     |
| 21191  | 8" WATER MAIN  | 7531     | 2000-2899 NW 75TH ST, 90117           |                          |         |         |     |
| 12805  | 8" WATER MAIN  | 30943    | 13800-13899 16TH AVE SW, 90166        |                          |         |         |     |


At the bottom of the page, there is a "Show MapEngine" button and a "Select Records" link. The Windows taskbar at the bottom shows the system time as 11:47 AM on 3/27/2015.

# Asset Inventory – Data Augmentation


ASSET REGISTRY DATA FOR PIPELINES



# Integrated Data Management



# Asset Management Ten Core Processes



# Water Utility Condition Assessment

- Field observation (e.g., main observation reports)
- Failure tracking
- Laboratory testing



# Condition Assessment – Staff Observations

## Water Main and Service/Saddle Observation Report

(circle appropriate answer or fill in blank)

### GENERAL INFORMATION

Name of Observer: Brown, James Date: May 23, 2010  
 Address: 12204 SE 54<sup>TH</sup> Grid: G-15

Notes: \_\_\_\_\_

Pipe Depth: less than 3 ft.  3 feet more than 3 ft. \_\_\_\_\_

Observation includes an existing service line connection: Yes  No  (If yes, fill out reverse side)

Observation is associated with a facility failure or break: Yes  No  (If yes, fill out reverse side)

### PIPE INFORMATION

Diameter: 4"  6" 8" 10" 12" 14" 16" 18" 24" Other \_\_\_\_\_

Material: AC (Simplex? Yes No  Unknown) DI CI PVC Other \_\_\_\_\_

If pipe is DI, is exterior covered with plastic? Yes - bagged Yes - wrapped No

If pipe is metal, is the interior lined? Unknown Yes - mortar Yes - composite No

### CONDITION INFORMATION

Was a Tapping Coupon saved and labeled with the address on this report: Yes  No

If pipe is AC, surface condition is:  Hard  Pucky  Soft  Other Pipe in Good Condition

If pipe is metal, any external corrosion: None Slight Moderate Extensive

If pipe is metal, any internal corrosion: Unknown None Slight Moderate Extensive

### SOIL INFORMATION

Type:  Sand  Feat  Clay  Loam  Hard Pan  Cinder  Pit Run  Gravel

Other \_\_\_\_\_

Moisture: Unknown (due to pipe break)  Dry  Wet  Saturated

If this main observation included a service line connection and/or is associated with a facility failure, Please fill out the appropriate information on the reverse side of this report.

Water Main Observation Report - Page 2

### SERVICE LINE AND SADDLE INFORMATION – if observed

Service Line Diameter: ¾-inch 1-inch 1 ½-inch 2-inch 3-inch Other \_\_\_\_\_

Service Line Material: Carbon HDPE PVC galvanized copper Other \_\_\_\_\_

If service line is metal, any corrosion or pitting: None Slight Moderate Extensive

Notes: \_\_\_\_\_

Saddle Strap Material: Cor-ten Stainless Steel Other \_\_\_\_\_

Saddle Strap Corrosion: None Slight Moderate Extensive

Saddle photographed and the photo labeled with the address on this report: Yes No

Saddle replaced: Yes No

Notes: \_\_\_\_\_

### FAILURE INFORMATION – if applicable

Failed Facility: Service Line Saddle Main

Failure Type: Crack – Circumferential Crack – Longitudinal Crack – Other

Hole – Small (Leak) Hole – Large (Burst)

Joint – Separation Joint – Gasket

Failure Cause: Dig-up Settlement Roots Land Slide Earthquake

Poor Construction Poor Repair Reduced Pipe Strength Corrosion

Pressure Surge Unknown Other \_\_\_\_\_

Repair Method: Clamp Replacement Other \_\_\_\_\_

Notes: \_\_\_\_\_




# Condition Assessment: Wastewater Utility Assets



# Wastewater System CCTV Condition Assessment

- Approximately 60 miles per year
  - Special needs
  - Programmatic
- Pipelines videoed on 5, 10 or 20 year intervals based on pipeline risk (failure probability multiplied by failure consequences)



# Sewer Video Plan Approach

|    | A        | B     | C            | D          | E        | F        | G        | H           | I |
|----|----------|-------|--------------|------------|----------|----------|----------|-------------|---|
| 1  | AssetNum | Basin | VideoCategor | LastVideo  | VideoDue | Diameter | Material | InstallDate |   |
| 2  | 196937   | 4     | Collection   | 6/15/2004  | 2024     | 8        | CON      | 1959        |   |
| 3  | 196938   | 4     | Collection   | 9/17/2003  | 2023     | 8        | CON      | 1959        |   |
| 4  | 196939   | 4     | Collection   | 7/1/2004   | 2024     | 8        | CON      | 1959        |   |
| 5  | 196940   | 4     | Collection   | 9/17/2003  | 2023     | 8        | CON      | 1959        |   |
| 6  | 196941   | 4     | High Risk    | 6/11/2004  | 2014     | 8        | CON      | 1950        |   |
| 7  | 196942   | 4     | Collection   | 5/7/2008   | 2028     | 8        | CON      | 1960        |   |
| 8  | 196943   | 4     | Collection   | 5/9/2008   | 2028     | 8        | CON      | 1959        |   |
| 9  | 196944   | 4     | Collection   | 10/7/1997  | 2017     | 8        | CON      | 1959        |   |
| 10 | 196945   | 4     | Collection   | 11/18/2013 | 2033     | 8        | CON      | 1959        |   |
| 11 | 196946   | 4     | Collection   | 5/7/2008   | 2028     | 8        | CON      | 1960        |   |
| 12 | 196947   | 4     | High Risk    | 10/29/2009 | 2019     | 8        | CON      | 1959        |   |
| 13 | 196948   | 4     | Collection   | 9/30/2008  | 2028     | 6        | CON      | 1950        |   |
| 14 | 196949   | 4     | Collection   | 6/6/2008   | 2028     | 8        | CON      | 1959        |   |
| 15 | 196950   | 4     | High Risk    | 3/15/2006  | 2016     | 8        | CON      | 1950        |   |
| 16 | 196951   | 4     | High Risk    | 3/18/2006  | 2016     | 8        | CON      | 1950        |   |
| 17 | 196952   | 4     | Collection   | 5/13/2004  | 2024     | 8        | CON      | 1959        |   |
| 18 | 196953   | 4     | High Risk    | 8/19/2011  | 2021     | 8        | CON      | 1950        |   |
| 19 | 196954   | 4     | Collection   | 10/6/1997  | 2017     | 8        | CON      | 1959        |   |
| 20 | 196955   | 4     | Collection   | 10/15/1997 | 2017     | 8        | CON      | 1961        |   |
| 21 | 196956   | 4     | Collection   | 9/20/2005  | 2025     | 8        | CI       | 1965        |   |
| 22 | 196957   | 4     | Collection   | 6/13/2007  | 2027     | 8        | CON      | 1959        |   |
| 23 | 196958   | 4     | Collection   | 5/13/2004  | 2024     | 8        | CON      | 1959        |   |
| 24 | 196959   | 4     | Collection   | 6/17/2004  | 2024     | 8        | CON      | 1959        |   |
| 25 | 196960   | 4     | Collection   | 9/17/2003  | 2023     | 8        | CON      | 1959        |   |
| 26 | 196961   | 4     | Collection   | 9/22/2003  | 2023     | 8        | CON      | 1959        |   |
| 27 | 196962   | 4     | Collection   | 5/9/2008   | 2028     | 8        | CON      | 1959        |   |
| 28 | 196963   | 4     | Collection   | 6/18/2004  | 2024     | 8        | CON      | 1959        |   |
| 29 | 196964   | 4     | Collection   | 9/30/2003  | 2023     | 12       | PVC      | 1985        |   |
| 30 | 196965   | 4     | Collection   | 3/10/2004  | 2024     | 8        | PVC      | 1970        |   |
| 31 | 196966   | 4     | Collection   | 3/10/2004  | 2024     | 8        | PVC      | 1970        |   |
| 32 | 196967   | 4     | Collection   | 10/11/2007 | 2027     | 8        | CON      | 1959        |   |
| 33 | 196968   | 4     | Collection   |            | 2014     | 6        | CON      | 1959        |   |
| 34 | 196969   | 4     | Collection   | 5/6/2002   | 2022     | 8        | CON      | 1959        |   |
| 35 | 196970   | 4     | Collection   | 10/2/1997  | 2017     | 8        | CON      | 1961        |   |
| 36 | 196971   | 4     | Collection   | 10/2/1997  | 2017     | 8        | CON      | 1959        |   |
| 37 | 196972   | 4     | Collection   | 9/17/2003  | 2023     | 8        | CON      | 1959        |   |
| 38 | 196973   | 4     | High Risk    | 11/1/2013  | 2023     | 8        | VC       | 1963        |   |


Next Video Year

Ready



# Sewer Death Spiral

## Significant Sewer Defects Identified



# Condition Assessment: Stormwater Utility




# Program Update: Stormwater System


- CCTV Pipeline Condition Assessment
- Culvert Inventory and Condition Assessment
- Storm Pipe Data Collection



# Watermain Failures




# 2010 - 2012 Watermain Failure Rates







# Water Utility Claims




# 2014 Watermain Failures (Through August 7, 2014)




# Wastewater Overflows




# Asset Responsible for Overflow (2010 - 2012)




# Wastewater Utility Claims






# Total Annual Failures vs. Storm Precipitation Average of 3 Largest Storm Events per Year



# Stormwater Utility Claims



# AC Watermain laboratory testing




**Fig. 15. Elemental Distribution through Cross Section of Pipe #2**



# AC Watermain Laboratory Testing (cont)



# Asset Management Ten Core Processes




# Remaining Life ~~Determination~~ Estimation

- Condition Assessment
  - Observation
  - Testing
  - Failure tracking
- Industry Norms
- Similar Assets

# Four Major Failure Modes (EPA)

- Capacity
- Level of Service
- Mortality
- Efficiency

# EPA (not really) Estimated Mileage



# EPA (not really) Estimated Mileage (cont)

**Table 1: Investigations of Gray and Ductile Iron Pipes in Non-Aggressive Soils**

| <b>Pipe Condition</b>                      | <b>Number of Specimens</b> | <b>Mean Deepest Pitting Rate (in./yr.)</b> | <b>Years to Penetration*</b> |
|--|----------------------------|--|------------------------------|
| As-manufactured<br>(Standard Shop Coating) | 43                         | 0.00067                                    | 373                          |
| Polyethylene Encased                       | 12                         | 0.0000                                     | ∞                            |

**Table 2: Investigations of Gray and Ductile Iron Pipes in Corrosive Soils**

| <b>Pipe Condition</b>                        | <b>Number of Specimens</b> | <b>Mean Deepest Pitting Rate (in./yr.)</b> | <b>Years to Penetration*</b> |
|--|----------------------------|--|------------------------------|
| Sand Blasted (annealing oxide layer removed) | 102                        | 0.025                                      | 10                           |
| Bare (uncoated)                              | 22                         | 0.0151                                     | 17                           |
| As-manufactured<br>(Standard Shop Coating)   | 103                        | 0.0105                                     | 24                           |
| Polyethylene Encased                         | 151                        | 0.00045                                    | 556                          |

# But Your Mileage May Vary...

**Table 5.3**  
**Estimated annual failure rates for PVC pipes**

| Water authority            | Length of PVC pipe (km) | No. of recorded failures | Recording period | Av failure rate (100km/y) | Av failure rate (100miles/y) |
|----------------------------|-------------------------|--------------------------|------------------|---------------------------|------------------------------|
| EBMUD                      | 513.4                   | 21                       | 1996–2002        | 0.6                       | 1.0                          |
| Des Moines Water Works*    | 241.263                 | 0                        | N/A              | 0.0                       | 0.0                          |
| United Water Toms River    | 336.1                   | 8                        | 2003–2004        | 1.7                       | 2.7                          |
| Louisville Water Company   | 1,012.3                 | 390                      | 1976-2004        | 1.4                       | 2.3                          |
| City of Calgary Waterworks | 1,699.9                 | 17                       | 1991–2000        | 0.1                       | 0.2                          |
| City of Richmond           | 157.9                   | 4                        | 2000-2004        | 0.5                       | 0.8                          |
| City of Ottawa             | 515.5                   | 16                       | 1992–2002        | 0.3                       | 0.5                          |
| Epcor                      | 1,098.5                 | 71                       | 1977–2004        | 0.2                       | 0.5                          |
| City West Water            | 544.7                   | 206                      | 1996–2003        | 5.4                       | 8.7                          |
| Hunter Water               | 626.1                   | 323                      | 1992–2003        | 4.3                       | 6.9                          |
| South West Water           | 250.8                   | Unknown                  | Unknown          | 1.5                       | 2.4                          |
| Yarra Valley Water         | 800.6                   | 384                      | 1995–2003        | 5.3                       | 8.5                          |
| South Australia Water      | 587.7                   | Unknown                  | Unknown          | Unknown                   | Unknown                      |
| Ipswich Water              | 250.6                   | 1                        | 2000–2001        | 0.2                       | 0.3                          |
| South East Water           | 1,778.2                 | 844                      | 1996–2002        | 6.8                       | 10.9                         |
| Gosford Water              | 24.4                    | 3                        | 2000–2001        | 6.1                       | 9.8                          |
| Sydney Water               | 1,262.0                 | 134                      | 1997–2002        | 1.8                       | 2.9                          |

\* Does not include failures for joints and/or external damage.

# Your Mileage May Vary (Part 2)...

**Table 1.4**  
**Estimated time intervals (years) for full pipe wall penetration in DI mains**

| Potential<br>corrosivity states    | Pressure<br>(class 350) | Thickness class             |            |                             |
|------------------------------------|-------------------------|-----------------------------|------------|-----------------------------|
|                                    |                         | Min thickness<br>(class 50) | (class 52) | Max thickness<br>(class 56) |
| <b>Pipe diameter: 6" (150 mm)</b>  |                         |                             |            |                             |
| <i>Very low</i> (VL)               | 125–190                 | 125–190                     | 455–540    | 1120–1240                   |
| <i>Low</i> (L)                     | 30–42                   | 30–42                       | 270–315    | 805–880                     |
| <i>Moderate</i> (M)                | 11–14                   | 11–14                       | 23–52      | 335–415                     |
| <i>High</i> (H)                    | 5–6                     | 5–6                         | 7.5–9.5    | 25–61                       |
| <i>Very high</i> (VH)              | 3–3.5                   | 3–3.5                       | 4–4.5      | 6.5–9                       |
| <b>Pipe diameter: 8" (200 mm)</b>  |                         |                             |            |                             |
| <i>Very low</i> (VL)               | 125–190                 | 235–305                     | 570–655    | 1240–1350                   |
| <i>Low</i> (L)                     | 30–42                   | 105–125                     | 355–410    | 895–975                     |
| <i>Moderate</i> (M)                | 11–14                   | 13–24                       | 46–83      | 395–485                     |
| <i>High</i> (H)                    | 5–6                     | 6–7                         | 8.5–13     | 54–97                       |
| <i>Very high</i> (VH)              | 3–3.5                   | 3.5                         | 4.5–5      | 7.5–13                      |
| <b>Pipe diameter: 10" (250 mm)</b> |                         |                             |            |                             |
| <i>Very low</i> (VL)               | 180–250                 | 345–420                     | 680–770    | 1350–1470                   |
| <i>Low</i> (L)                     | 60–78                   | 185–220                     | 445–505    | 980–1070                    |
| <i>Moderate</i> (M)                | 12–18                   | 17–36                       | 105–150    | 455–550                     |
| <i>High</i> (H)                    | 5.5–6.5                 | 6.5–8                       | 10–21      | 94–145                      |
| <i>Very high</i> (VH)              | 3–3.5                   | 3.5–4                       | 4.5–5.5    | 8–18                        |
| <b>Pipe diameter: 12" (300 mm)</b> |                         |                             |            |                             |
| <i>Very low</i> (VL)               | 290–365                 | 455–540                     | 790–885    | 1460–1590                   |
| <i>Low</i> (L)                     | 145–175                 | 270–315                     | 535–600    | 1070–1170                   |
| <i>Moderate</i> (M)                | 15–30                   | 23–52                       | 160–215    | 515–615                     |
| <i>High</i> (H)                    | 6.5–7.5                 | 7.5–9.5                     | 12–29      | 135–190                     |
| <i>Very high</i> (VH)              | 3.5–4                   | 4–4.5                       | 5–6        | 9–24                        |



# 1940's – 1960's: The Glory Days of Asbestos Cement Pipe ...



Are you taking advantage of  
**THIS BASIC ADVANCE**  
in WATER-LINE ENGINEERING?



**SAN ANTONIO, TEXAS**  
8" and 12" Class 150 Transite Pipe.

**GRANVILLE, N. Y.**  
Various sizes Class 150 Transite Pipe for water main systems.



**Johns-Manville**



**How Transite Pipe**  
keeps water clean and rust-free for every use... helps maintain full pressure, too!

protects community health at lower cost to the taxpayer

TRANSITE PIPE WATER MAINS are contributing to greater community health and safety. Transite Pressure Pipe maintains clean pure water from pumping station to consumer, helps assure pressure for fire protection at low cost to taxpayers.

Transite Pipe resists corrosion. It is non-toxic, cannot tuberculate. Since degenerative form of corrosion cannot build up, its initially high flow capacity stays high, pumping costs stay low. And, joints in a Transite system remain tight and sanitary.

Transite Sewer Pipe can cope, too, with quick assembly and high flow capacity. It is rugged, corrosion-resistant. It is easily handled, rapidly installed, minimizing annoyances of trenching, stream, tight, flexible couplings reduce treatment costs.

For more details write Johns-Manville, Dept. 60, New York 16, N. Y.; or Canada, 665 Lakeshore Road East, Port Credit, Ontario.

*The White Pipe—*  
Made of Asbestos-Cement




**Johns-Manville**  
TRANSITE PIPE  
SERVES YOU—BY SERVING YOUR COMMUNITY

**IN WATER SYSTEMS**

*Installed cost plus performance is what counts!*

That's why it pays to use Transite® Pressure Pipe with the Ring-Tite® Coupling

FOR THE CONTRACTOR who installs it... for the engineer who selects it... for the taxpayer who pays for it... Transite Pressure Pipe with the new Ring-Tite Coupling meets every requirement. For example...

**Installed Cost is Lower**—Contractors everywhere have found that Transite's light weight, easy handling and fast, accurate Ring-Tite Coupling assembly means less man and save time. May be installed even under difficult weather and terrain conditions. The Ring-Tite design automatically locks tight, forming a positive seal.

**Performance is Higher**—With Transite Pressure Pipe and the Ring-Tite Coupling, you can count on peak performance year after year because of such engineering advantages as these: Lasting strength because of Transite's asbestos content, a strong durable material, high resistance to corrosion... Designed tightness with the rubber rings of the Ring-Tite Coupling... Assured flexibility with automatic and positioning within the joint... Joints can't blow out.



For further information about Transite Pressure Pipe and Ring-Tite Coupling, write to Johns-Manville, Box 60, New York 16, N. Y.



**Johns-Manville TRANSITE PRESSURE PIPE**  
WITH NEW RING-TITE COUPLING

140 April 1951 • THE AMERICAN CITY

# Will History Repeat Itself?



There's a reason  
it's called **pumping Iron.**

## Iron = Strength.

Smart athletes know that pumping iron builds strength. And smart communities know that successful infrastructure projects begin with the strength of ductile iron pipe.

**Smart<sup>®</sup>Certified** because it's made from recycled and recyclable materials and uses less energy in pumping, ductile iron pipe is the superior choice over PVC—whose production creates toxins that have caused some cities and corporations to ban it.

But ductile iron isn't just strong on the environment, it's the strongest pipe material on the market—ten times stronger than PVC. Reliable, easy to install and without the laying and lapping headaches associated with PVC. No wonder thousands of communities choose ductile iron. It works out everytime.

Iron Pipe. It's What America Was Built On

**DUCTILE IRON PIPE**  
RESEARCH ASSOCIATION  
IronForAmerica.com

## PVC PIPE: THE SOLUTION FOR AMERICA'S UNDERGROUND INFRASTRUCTURE

Making Municipal Water and Sewer Systems Safe, Sustainable and Corrosion-Free for Over 60 Years



Two Million Miles of Unsurpassed Reliability

- Force Mains
- Reclaimed Water
- Sanitary Sewer
- Storm Water
- Trenchless
- Water

Available in Sizes  
4" – 60"

Corrosion is not sustainable. It costs U.S. water and sewer systems more than \$50.7 billion annually in repairs, replacements and lost water. PVC pipe is a cost-effective and durable investment in your community's future.


For information on design and installation, visit the PVC Pipe Association's new web site at [www.uni-bell.org](http://www.uni-bell.org).



True strength and sustainability begin with corrosion resistance.

UNI-BELL PVC PIPE ASSOCIATION | 2711 LBJ FREEWAY, SUITE 1000 | DALLAS, TX 75234  
972.243.3902 | FX: 972.243.3907

# Asset Management Ten Core Processes



# Triple Quadruple Bottom Line

- Economic
  - Capital
  - Operations and Maintenance
- Environmental
- Social
- Political

(costs, benefits and risk costs)



# Identifying the Most Cost-Effective Strategies


## Wilburton Area Wastewater Capacity Improvements Summary of Life Cycle Costs

|   | <b>Alt 1<br/>– Upsize Mains</b> | <b>Alternative 1A<br/>– Upsize Mains,<br/>Use Existing SE<br/>8<sup>th</sup> St Piles</b> | <b>Alternative 2<br/>– New P.S. to<br/>Divert Most<br/>Flows to Metro</b> | <b>Alternative 4<br/>– New P.S. to<br/>Divert All Flows<br/>to Metro</b> |
|---|---------------------------------|---|---|--|
| <b>Net Present Value of Capital Costs</b>                           | \$4,746,642                     | \$4,449,795   | \$4,111,716   | \$9,342,306  |
| <b>Net Present Value of Operations and Maintenance Labor Costs</b>  | \$0                             | \$0   | \$883,564   | \$883,564  |
| <b>Net Present Value of Operations and Maintenance Energy Costs</b> | \$0                             | \$0   | \$191,067   | \$309,414  |
| <b>TOTAL</b>  | \$4,746,642                     | \$4,449,795   | \$5,186,347   | \$10,535,284   |

# Life Cycle Cost Analysis Example

|   |   |  |  |  |  |  |
|---|---|--|--|--|--|--|
| XYZ Project   |   |  |  |  |  |  |
| Alternative 1 - Partial Demolition with Gravel Fill |   |  |  |  |  |  |
| Date  |   |  |  |  |  |  |
|   |   |  |  |  |  |  |
| <b>NET PRESENT VALUE (Net Cost)</b>                 | \$451,449   |  |  |  |  |  |
| <b>INITIAL NET COST</b>                             | \$345,677   |  |  |  |  |  |
|   |   |  |  |  |  |  |
| Discount Rate =                                     | 2.70%   |  |  |  |  |  |
| Discount Rate Basis:                                | Real Interest Rate on 30-year Treasury Bill as of December 2009 (recommended long-term discount |  |  |  |  |  |
| Year Zero =   | 2010  |  |  |  |  |  |

# Asset Management Ten Core Processes



# Service Levels

- Highest Level Performance Measure
- Stakeholder Expectations
  - Residential customers
  - Business/Industry
  - Critical needs (e.g., hospitals and fire)
  - Political Leadership
  - REGULATORY REQUIREMENTS
- Willingness to Pay



## Seattle Public Utilities Service Levels

Below are SPU's services and service levels that we will report on in 2015 to SPU employees to City Council:

### ***Focus Area: Making it Easier to Get Help and Find Answers***

| SPU Services               | Service Levels   |
|----------------------------|--|
| Effective customer service | Customers rank their satisfaction with SPU services at least 5 on a scale of 1-7                               |
|                            | % of customer issues resolved in first phone call (target TBD)   |
|                            | % of customer bills that do not require adjustment (target TBD)  |
|                            | Respond to 90% of priority drinking water, drainage, and wastewater problems within one hour                   |
|                            | Increase households enrolled in the Utility Discount Program from 17,079 in January 2015 to 19,600 by year-end |

### ***Focus Area: Better Protecting Your Health and Our Environment***

| SPU Services  | Service Levels  |
|---|---|
| Mountain fresh drinking water   | Maintain 100% compliance with Department of Health regulations  |
|   | Provide instream water for fish and meet other tribal, regional, state, and federal commitments   |
| Safe sewage transport to King County treatment plants; drainage that reduces flooding & pollution | Limit sanitary sewer overflows to no more than 4 per 100 miles of pipe per year   |
|   | Limit combined sewer overflows to waterbodies to 1 per outfall per year   |
|   | Remove 100 tons of pollutants from roads during 2015  |
| Planning for the future   | To support the Citywide goal of 700 million gallons of runoff managed using Green Stormwater Infrastructure by 2025, SPU has a 2015 target of managing 8 million gallons of stormwater via RainWise rain gardens and cisterns |
|   | Achieve goals for water conservation  |
| Effective recycling and composting  | Increase solid waste recycling to 60% by December 2015 and 70% by 2022  |
| Efficient graffiti removal  | Clean up graffiti on SPU property and SDOT structures within targeted times (10 business days for SDOT structures; 6 business days for SPU property)  |

# SPU Service Level Goals (continued)

**Focus Area: Improving How We Work to Deliver Consistent, High Quality Services**

| SPU Services                               | Service Levels  |
|--|---|
| Mountain fresh drinking water              | Limit yearly drinking water outages of more than 4 hours to less than 4% of retail customers  |
|  | Meet obligations in wholesale customer contracts for pressure, flow, and unplanned transmission system outages  |
| Drainage that reduces flooding & pollution | No critical services (e.g., hospitals) are inaccessible due to flooding, except during extreme storm events (events exceeding a 100-year, 24-hour design storm event) |
| Dependable solid waste pickup              | Provide reliable solid waste pickup with only one missed pickup for each 1,000 stops  |
|  | Limit late container deliveries to a maximum of two per 100 deliveries  |
|  | Collect at least 95% of missed solid waste pickups within one business day following notification by customers  |
| All services                               | Stay within the overall 4.6% rate path through 2020   |
|  | Meet the aspirational goals for WMBE usage in purchasing and consulting contracts   |

**NOTE:** *The Workforce Focus Area is not specifically represented here, but it indirectly affects all services levels.*

# Service Levels – Customer Reporting

**Water and Waste**

## Customer Service Standards

**mission statement**

To deliver quality and reliable water, wastewater and solid waste services that meet the needs of the community.

**customer service standards**

Cairns Regional Water & Waste is a commercialised business unit of Cairns Regional Council charged with the responsibility of providing water, wastewater and solid waste services, including recycling to the Cairns community. These services are provided to over 150,000 residential customers and tourists, in addition to over 4,000 commercial and industrial customers.

**contact details**

**Customer Service Centres:**

Council Chambers, 119-145 Spence Str., Cairns

Stockland Shopping Centre, Mulgrave Rd, Earlvile

Gordonvale Library, 88 Norman St, Gordonvale

Smithfield Library, Cheviot St, Smithfield

Mossman Offices, 64-66 Front St., Mossman

**Postal Address:**

General Manager  
Cairns Regional Council  
Water & Waste  
PO Box 389  
Cairns Qld 4870

**Business Address:**

119-145 Spence St.  
Cairns Qld 4870

**Phone:**

Cairns: 07 4044 3044  
Mossman: 07 4099 9444  
Toll-free: 1800 070 444

**Website:**

[www.cairns.qld.gov.au](http://www.cairns.qld.gov.au)


**Email:**

[council@cairns.qld.gov.au](mailto:council@cairns.qld.gov.au)

**Water Services Performance Indicators**

|  | Performance Indicator   | Performance measure   | Target           |    |
|--|---|---|------------------|----|
| <b>Day to Day Continuity</b>                 | Number of connections experiencing unplanned interruptions                        | Per 1000 connections / year   | 150              |    |
|  | Number of connections experiencing planned interruptions                          | Per 1000 connections / year   | 15               |    |
|  | Time for restoration of service   | % of services restored < 5 hrs  | 98%              |    |
|  | Response/reaction time to incidents (emergency)                                   | % of response to emergency < 30 min                                   | 98%              |    |
|  | Response/reaction time to incidents (all events)                                  | % of response to incident < 24 hours                                  | 95%              |    |
|  | Connections receiving 1 interruption per year                                     | % of connections  | 12%              |    |
|  | Average interruption duration – planned   | Hours   | 1.5              |    |
|  | Average interruption duration – unplanned   | Hours   | 1.5              |    |
|  | Relative incidence of planned and unplanned interruption water incidents (events) | Ratio   | 1:11             |    |
|  | Minimum pressure at property boundary   | kpa   | 220              |    |
| <b>Adequacy and quality of normal supply</b> | Maximum pressure at property boundary   | kpa   | 500              |    |
|  | Drinking water quality complaints   | Per 1000 connections / year   | <5               |    |
|  | E. Coli result for class C recycled water   | Less than 1000 cfu/100mL (of samples taken for a twelve month period) | 95%              |    |
|  | Drinking water quality incidents  | Number of incidents   | 15               |    |
|  | Urban / rural supplies – E. Coli  | Nil per 100mL   | 98%              |    |
|  | Urban / rural supplies – turbidity  | < 5NTU  | 95%              |    |
|  | Urban / rural supplies – pH   | 6.5 to 8.5  | 98%              |    |
|  | Urban / rural supplies – colour   | Up to 15.0  | 98%              |    |
|  | <b>Continuity in the long term</b>  | Water main breaks and leaks   | Per 100km / year | 17 |






This document provides details on the following:

- Obligations of Cairns Regional Council Water & Waste in delivering the water, wastewater and solid waste services;
- Levels of service to be provided to our customers based on performance indicators and goals;
- Expectations we have for our customers.

This is a condensed version of the complete Cairns Regional Water & Waste Customer Service Standards, available on our website. Including information on billing, new services, metering, complaints and resolution.

[www.cairns.qld.gov.au](http://www.cairns.qld.gov.au)



**Sewage Wastewater Services Performance Indicators**

|                                      | Performance Indicator                                    | Performance measure                        | Target |
|--------------------------------------|--|--|--------|
| <b>Effective transport of sewage</b> | Sewage overflows   | Per 100km / year (gravity and rising main) | <15    |
|                                      | Sewage overflows to customer properties                  | Per 1000 connections / year                | <2     |
|                                      | Odour complaints   | Per 1000 connections / year                | <2     |
|                                      | Response/reaction time to incidents (all events)*        | % of response to all events < 24 hrs       | 98%    |
|                                      | Response/reaction time to incidents (emergency)          | % of response to emergency < 1 hour        | 98%    |
| <b>Continuity in the long run</b>    | Priority one events when service restored within 5 hours | % restored within 5 hours                  | 95%    |
|                                      | Sewer main breaks and chokes                             | Per 100km / year                           | <10    |

**Waste & Recycling Services Performance Indicators**

|  | Performance Indicator   | Performance measure   | Target                                    |
|--|---|---|---|
| <b>Effective Collection of Residential Waste</b> | New bin delivery  | Response time for new bin delivery  | 100% within 48 hours                      |
|  | Missed services - kerbside waste  | Number of missed services per month                                       | Less than or equal to 1 per 1000 services |
|  | Response time to missed services - kerbside waste                           | Response time for collection of missed kerbside waste services            | 100% within 24 hours                      |
|  | Missed services - kerbside recycling  | Number of missed services per month                                       | Less than or equal to 1 per 1000 services |
|  | Response time to missed services - kerbside recycling                       | Response time for collection of missed kerbside waste services            | 100% within 24 hours                      |
|  | Response time to repair/replacement requests - kerbside waste and recycling | Response time to repair/replace requests for kerbside waste and recycling | 100% within 48 hours                      |


**Customer Assistance Performance Indicators**

|  | Performance Indicator   | Performance measure | Goal |
|--|---|---------------------|------|
| <b>Customer Assistance Performance Goals</b> | Install new residential water connection  | Working days        | 15   |
|  | Number of properties that do not receive 48 hours advance notice for planned water and sewerage works | Number              | 0    |
|  | Average time taken by Water and Waste to respond to customer calls (rings)                            | Rings               | 4    |
|  | Customer Request Management (CRM) completed within prescribed timeframe                               | 5 Working days      | 95%  |

**Emergency Assistance:** Cairns Regional Water & Waste maintains a 24-hour contact service for emergency events related to service systems, such as a burst water main or sewage overflow. Please call during and after hours on 40443044

2

# Asset Management Ten Core Processes



# Life Cycle Costs and Business Risk Exposure

- Economic
  - Capital
  - Operations and Maintenance
  - Repair
  - Loss of Business Opportunity
- Environmental
- Social



# Failure Consequence (Pipeline Example)

- Pipeline Size and System Importance
- Alignment
  - Easement
  - Residential Street
  - Minor Arterial
  - Major Arterial
- Critical Facilities
  - Police
  - Fire
  - Hospital
  - Freeways, petroleum product transmission lines, etc.

# Failure Consequence (Pipeline Example Cont.)

- Neighborhood
  - Third Party Damage
  - Business and social interruption
- Pipeline Depth
- Parks and environmentally sensitive areas
- Coordination with other CIP projects

# Risk:

## Probability of Failure X Consequence of Failure

|            |                     | Consequence  |               |                 |                 |                 |
|------------|---------------------|--|---------------|-----------------|-----------------|-----------------|
|            |                     | How severe could the outcomes be if the risk event occurred? → |               |                 |                 |                 |
|            |                     | 1  | 2             | 3               | 4               | 5               |
|            |                     | Insignificant  | Minor         | Significant     | Major           | Severe          |
| Likelihood | 5<br>Almost Certain | 5<br>Medium  | 10<br>High    | 15<br>Very high | 20<br>Extreme   | 25<br>Extreme   |
|            | 4<br>Likely         | 4<br>Medium  | 8<br>Medium   | 12<br>High      | 16<br>Very high | 20<br>Extreme   |
|            | 3<br>Moderate       | 3<br>Low   | 6<br>Medium   | 9<br>Medium     | 12<br>High      | 15<br>Very high |
|            | 2<br>Unlikely       | 2<br>Very low  | 4<br>Low      | 6<br>Medium     | 8<br>Medium     | 10<br>High      |
|            | 1<br>Rare           | 1<br>Very low  | 2<br>Very low | 3<br>Low        | 4<br>Medium     | 5<br>Medium     |



# Probability of Failure

Model with Weibull cumulative distribution function

$$F_T(t) = 1 - \exp\left[-\left(\frac{t}{\eta}\right)^\beta\right]$$

Where


$F_T(t)$  = the probability that the defect results in failure by time  $t$

$\beta, \eta$  = Weibull distribution parameters

# Assumed Probability of Failure

| Defect Severity Level | End of Year | Probability of Failure | End of Year | Probability of Failure |
|-----------------------|-------------|------------------------|-------------|------------------------|
| High                  | 1           | 0.25                   | 5           | 0.99                   |
| Medium                | 5           | 0.25                   | 10          | 0.99                   |
| Low                   | 10          | 0.05                   | 20          | 0.75                   |

# High Severity Defect Probability of Failure



## Failure Probability for Unrepaired Defects

Given that a defect has not “failed” by the end of year  $t$ , the probability of failure in the next year,  $f_T(t)$ , is

$$f_T(t) = \frac{F_T(t+1) - F_T(t)}{1 - F_T(t)}$$

Where  $F_T(t)$  and  $F_T(t+1)$  are the Weibull cumulative probabilities of failure at time  $t$  and time  $t+1$

| Length of Time Since Defect Was Identified | Probability of Failure if Failure Has Not Yet Occurred |        |       |
|--|--|--------|-------|
|  | High   | Medium | Low   |
| Less Than 1 Year                           | 0.25   | ~ 0    | ~ 0   |
| From 1 to 2 Years                          | 0.48   | 0.007  | 0.001 |
| From 2 to 3 Years                          | 0.62   | 0.03   | 0.002 |
| From 3 to 4 Years                          | 0.71   | 0.08   | 0.003 |
| From 4 to 5 Years                          | 0.77   | 0.16   | 0.005 |
| From 5 to 6 Years                          | 0.82   | 0.27   | 0.006 |
| From 6 to 7 Years                          | 0.85   | 0.40   | 0.009 |
| From 7 to 8 Year                           | 0.88   | 0.54   | 0.011 |
| From 8 to 9 Years                          | 0.90   | 0.68   | 0.014 |
| From 9 to 10 Years                         | 0.92   | 0.79   | 0.017 |




# Sewer Repair List

WO-0073

## Section: WASTEWATER

| <u>Workorder</u> | <u>Asset</u> | <u>LegacyID</u>   | <u>Pri</u> | <u>Status</u> | <u>Address</u>       | <u>Claims</u> | <u>Low</u>  |            | <u>Failure</u> |             | <u>Yr</u> | <u>Rank</u> | <u>Risk</u> |
|------------------|--------------|---|------------|---------------|----------------------|---------------|-------------|------------|----------------|-------------|-----------|-------------|-------------|
|                  |              |   |            |               |                      |               | <u>Conn</u> | <u>Div</u> | <u>Conseq</u>  | <u>Prob</u> |           |             |             |
| UT-07-16855      | 197446       | SL04-0139   | H          | APPR          | 2709 86TH AVE NE     |               | Y           | OM         | \$80,060       | 0.706354    | 4         | 31          | 56,551      |
|                  |              | Desc: Repair broken mainline pipe.                                      |            |               |                      |               |             |            |                |             |           |             |             |
| UT-10-02075      | 196947       | SL04-0242   | H          | APPR          | 9038 NE 20TH ST      |               | Y           | OM         | \$64,560       | 0.484195    | 2         | 60          | 31,260      |
|                  |              | Desc: Remove unused defective service connection.                       |            |               |                      |               |             |            |                |             |           |             |             |
| UT-10-02079      | 196947       | SL04-0242   | H          | APPR          | 2023 92ND AVE NE     |               | Y           | OM         | \$64,560       | 0.484195    | 2         | 60          | 31,260      |
|                  |              | Desc: Replace defective service connection and stub.                    |            |               |                      |               |             |            |                |             |           |             |             |
| UT-06-04542      | 197116       | SL05-0112   | M          | APPR          | 8429 NE 7TH ST       |               | Y           | OM         | \$100,340      | 0.265770    | 6         | 91          | 26,667      |
|                  |              | Desc: REPLACE FAILED MAIN LINE WYE & LATERAL TO ROW.                    |            |               |                      |               |             |            |                |             |           |             |             |
| UT-10-02092      | 201113       | SL08-0229   | H          | APPR          | 110 NORTHSIDE RD     |               | Y           | OM         | \$35,820       | 0.484195    | 2         | 136         | 17,344      |
|                  |              | Desc: Replace defective service connection and stub.                    |            |               |                      |               |             |            |                |             |           |             |             |
| UT-07-09344      | 197115       | SL05-0113   | M          | APPR          | 8436 NE 7TH ST       |               | Y           | OM         | \$100,340      | 0.156222    | 5         | 165         | 15,675      |
|                  |              | Desc: REPLACE DEFECTIVE SERVICE CONNECTION.                             |            |               |                      |               |             |            |                |             |           |             |             |
| UT-05-16954      | 206847       | SL39-0521   | M          | WINVOICE      | 4429 148TH PL SE     |               | Y           | OM         | \$57,868       | 0.265770    | 6         | 169         | 15,380      |
|                  |              | Desc: REPLACE DAMAGED MAINLINE TEE.                                     |            |               |                      |               |             |            |                |             |           |             |             |
| 15458            | 197693       | SL08-0109   | H          | APPR          | 9217 SE SHORELAND DR |               |             | OM         | \$28,000       | 0.484195    | 2         | 178         | 13,557      |
|                  |              | Desc: Replace broken root infested service stub                         |            |               |                      |               |             |            |                |             |           |             |             |
| UT-10-02015      | 206520       | SL23-0425   | H          | APPR          | 15421 SE 20TH PL     |               | Y           | OM         | \$28,000       | 0.484195    | 2         | 178         | 13,557      |
|                  |              | Desc: Replace defective service connection and stub.                    |            |               |                      |               |             |            |                |             |           |             |             |
| UT-10-02023      | 208511       | SL26-0114   | H          | APPR          | 14823 NE 14TH ST     |               |             | OM         | \$28,000       | 0.484195    | 2         | 178         | 13,557      |
|                  |              | Desc: Replace defective service connection and stub.                    |            |               |                      |               |             |            |                |             |           |             |             |
| UT-10-02027      | 215206       | SL28-0149   | H          | APPR          | 2917 165TH PL NE     |               | Y           | OM         | \$27,360       | 0.484195    | 2         | 194         | 13,248      |
|                  |              | Desc: Replace defective service connection and 8 feet of mainline pipe. |            |               |                      |               |             |            |                |             |           |             |             |
| UT-10-02040      | 215506       | SL30-0256   | H          | APPR          | 16015 NE 2ND ST      |               | Y           | OM         | \$26,560       | 0.484195    | 2         | 201         | 12,860      |
|                  |              | Desc: Replace defective service connection and stub.                    |            |               |                      |               |             |            |                |             |           |             |             |
| UT-06-12214      | 198908       | SL01-0259   | M          | APPR          | 2001 77TH AVE NE     |               |             | OM         | \$43,500       | 0.265770    | 6         | 212         | 11,561      |
|                  |              | Desc: REPLACE BROKEN MAINLINE PIPE.                                     |            |               |                      |               |             |            |                |             |           |             |             |
| UT-05-17379      | 210400       | SL16-0168   | M          | APPR          | 2422 124TH PL NE     |               | Y           | OM         | \$42,020       | 0.265770    | 6         | 221         | 11,168      |
|                  |              | Desc: REPLACE DAMAGED MAINLINE PIPE & TEE.                              |            |               |                      |               |             |            |                |             |           |             |             |
| UT-10-02032      | 208287       | SL28-0114   | H          | APPR          | 2918 165TH PL NE     |               | Y           | OM         | \$20,820       | 0.484195    | 2         | 233         | 10,081      |

# Asset Management Ten Core Processes



Now that we are done pigging out!





# Asset Management


Replace it on time or fix it on their time!



## Condition Assessment

# Field Crew buy in is critical for success!

- Engage staff early and invite them to be a part of the process to develop the various templates you use to collect the data.
- Be proactive by engaging staff so they understand why they are collecting the data.
- Field crews are there for support and to get the data into the system.
- The Asset Manager should mine their own data and understand the systems in place to do so.
- Recommend holding staff meetings annually to show field crews how their efforts affect the big picture.



# Optimize Operations and Maintenance

## Asset inventory – what are your assets?


- Fire Hydrants
- Valves
- PRVs
- Pumps
- Motors
- Generators
- Water Meters
- Reservoirs
- Water Mains
- Service lines
- Air Vacs
- Blow Off assemblies
- Water Quality analyzers



# Where do you store all of the information?

Important to understand the capabilities of the software you have available.

- Does the software work for you or do you work for it?
- Is it static or easily customizable?
- Does it interface with other software systems?
- Who supports it? IT Department, third party vendor, in-house.
- Who will be using it vs having access? What permissions will you establish to maintain “clean” data.
- User training, who enters changes, who mines the data?
- Accept that it will never be perfect and that it will evolve and change over time.



Assets Filter 1 - 20 of 13072

| Asset  | Legacy ID | Description                      | Department | Division | Section | Class | Status         |
|--------|-----------|----------------------------------|------------|----------|---------|-------|----------------|
| 103369 | WV07140   | CUTOFF VALVE : 508 172ND PL NE   | UTIL       | OM       | WATER   | WV    | DECOMMISSIONED |
| 104961 | WV06329   | CUTOFF VALVE : 2537 166TH AVE NE | UTIL       | OM       | WATER   | WV    | DECOMMISSIONED |
| 105512 | WV04870   | CUTOFF VALVE : 14809 NE 14TH ST  | UTIL       | OM       | WATER   | WV    | OPERATING      |
| 105513 | WV04875   | CUTOFF VALVE : 1503 151ST AVE NE | UTIL       | OM       | WATER   | WV    | OPERATING      |
| 105514 | WV04832   | CUTOFF VALVE : 1800 154TH AVE NE | UTIL       | OM       | WATER   | WV    | OPERATING      |
| 105515 | WV04833   | CUTOFF VALVE : 1700 153RD AVE NE | UTIL       | OM       | WATER   | WV    | OPERATING      |
| 105516 | WV04834   | CUTOFF VALVE : 1700 153RD AVE NE | UTIL       | OM       | WATER   | WV    | OPERATING      |
| 105517 | WV04835   | CUTOFF VALVE : 15216 NE 16TH PL  | UTIL       | OM       | WATER   | WV    | OPERATING      |
| 105518 | WV04836   | CUTOFF VALVE : 15200 NE 16TH PL  | UTIL       | OM       | WATER   | WV    | OPERATING      |
| 105519 | WV04842   | CUTOFF VALVE : 1919 152ND PL NE  | UTIL       | OM       | WATER   | WV    | OPERATING      |
| 105520 | WV04856   | CUTOFF VALVE : 15300 NE 15TH PL  | UTIL       | OM       | WATER   | WV    | OPERATING      |
| 105521 | WV04840   | CUTOFF VALVE : 15027 BEL RED RD  | UTIL       | OM       | WATER   | WV    | DECOMMISSIONED |

# Asset inventory details.

## What do you want to know about your inventory?

**Specifications** - Every asset has a few common characteristics that should be known.

- Make - Who made it?
- Model – Which one do you have in your system.
- Manufacture year – Important over time as designs change.
- Install date (year) – This is when “service life” begins from an O&M perspective.
- Location – Physical address is important, Latitude/Longitude is good for mapping
- Asset ID # - Important to know for tracking, many methods for assigning a #.




## Asset inventory details.

# What do you want to know about your inventory?

**Specifications** – After the common traits there are details to track that are unique to certain assets.

- Fire Hydrants – aesthetics, length of run, foot valve location, port threads, etc...
- Valves – size, gate, butterfly, check, underground or in station, op nut vs wheel, etc...
- Water main – depth, material: DI, AC, CI – lined/unlined, HDPE, PVC, Size, wrapped, etc...
- Service line – saddle, direct tap, size, material, length, corp stop, curb stop, setter, resetter, etc...
- Pumps – gallons per minute, seal type, pump type, total dynamic head
- Motors - rotations per minute, horse power, amperage, VFD information if applicable, amperage
- PRV – valve sizes, pressure, supply zone, service zone, epoxy coated y/n, elevation
- Meters – serial #, size, commercial/domestic/irrigation, min/max flow rate detection, touch read, etc...



The screenshot shows a software interface for asset management. The title bar reads "Assets" and "Bulletins: (0)". Below the title bar is a search bar with a "Find:" label and a magnifying glass icon, and a "Select Action" dropdown menu. The main content area has a tabbed interface with tabs for "List", "Asset", "Child Assets", "Meters", "Specifications", and "Work". The "Specifications" tab is active. Below the tabs, there are input fields for "Asset: 100250" and "Classification: FH". A blue highlighted box contains the text "FIRE HYDRANT ASSEMBLY: 4160 128TH AVE SE". A double arrow icon is visible at the bottom right of the input fields.

## Asset inventory details.

# What do you want to know about your inventory?

There's a lot you can track, balance what's important and think about what you will use the information for.

Patience is important if you have a lot of assets and many people that you rely on to document all of the details, it will not be perfect.

Asset: 100250    FIRE HYDRANT ASSEMBLY: 4160 128TH AVE SE    Site: MAINT

Classification: FH    Class Description: Fire Hydrant

Specifications: Filter 1 - 13 of 13

| Attribute        | Description                   | Data Type | Alphanumeric Value | Numeric Value |
|------------------|-------------------------------|-----------|--------------------|---------------|
| SIZE             | Size (Inches)                 | NUMERIC   |                    | 5.25          |
| PRES             | Actual pressure (PSI)         | NUMERIC   |                    | 64.0          |
| PORTTHREAD       | Port Thread Type              | ALN       | Seattle (SEA)      |               |
| NUMPORTS         | Number of Ports               | NUMERIC   |                    | 3.0           |
| MODEL            | Model Name/Number             | ALN       |                    |               |
| MFGYEAR          | Manufacture Year              | ALN       |                    |               |
| MANUFACTURER     | Name of Manufacturer of Equip | ALN       | Mueller            |               |
| LOWPRESS         | Low Pressure                  | NUMERIC   |                    |               |
| HIPRESS          | High Pressure                 | NUMERIC   |                    |               |
| FTVALVELOC       | Foot Valve Location           | ALN       | 50' EAST           |               |
| FTVALVE_NUMTURNS | Foot Valve - Num of Turns     | NUMERIC   |                    |               |
| FTVALVE_LEAK     | Foot Valve Leaks              | ALN       |                    |               |
| EARLYMORN        | Early morning?                | ALN       |                    |               |

## Condition Assessment

### How do you gather the information?

- **Above ground assets** – Fire Hydrants, pumps, motors, assets inside pump stations, reservoirs (internal & external). Easy to see and inspect on regular intervals.
- **Vaults** – PRVs, commercial meters, inlets.
- **Buried assets** – *these are unknown until they are known.* Buried assets are the most challenging. We rely on moments of opportunity to inspect and document their condition.





# Water Main and Service/Saddle Observation Report

(circle appropriate answer or fill in blank)

## Condition Assessment

**Main Observation Report (MOR)**- A premade form to populate anytime field crews expose a water main.

Field crews should fill one of these out each time we get eyes on a watermain.

We often have to remind them to fill one out when the watermain is in GOOD condition as well as bad.

**Opportunities:** A lot of this information can be migrated into GIS and plotted onto map layers for better planning and long range forecasting.

### GENERAL INFORMATION

Name of Observer: Barry Thompson Date: 4-22-15  
Address: 9928 SE 7th CT Grid: D8 Work Order No. 540493  
Notes: Asset # 145437

Pipe Depth: less than 3 ft. \_\_\_\_\_ 3 feet \_\_\_\_\_ more than 3 ft. 40"  
Observation includes an existing service line connection: Yes No *(If yes, fill out reverse side)*  
Observation is associated with a facility failure or break: Yes No *(If yes, fill out reverse side)*

### PIPE INFORMATION

Diameter: 4" 6" 8" 10" 12" 14" 16" 18" 24" Other OD 13.94  
Material: AC (Simplex? Yes No Unknown) DI CI PVC Other \_\_\_\_\_  
*If pipe is DI* is exterior covered with plastic? Yes - bagged Yes - wrapped No  
*If pipe is metal* is the interior lined? Unknown Yes - mortar Yes - composite No

### CONDITION INFORMATION

Was a Tapping Coupon saved and labeled with the address on this report: Yes No  
*If pipe is AC* surface condition is: Hard Punky Soft Other \_\_\_\_\_  
*If pipe is metal* any external corrosion: None Slight Moderate Extensive  
*If pipe is metal* any internal corrosion: Unknown None Slight Moderate Extensive

### SOIL INFORMATION

Type: Sand Peat Clay Loam Hard Pan Cinder Pit Run Gravel  
Other \_\_\_\_\_  
Moisture: Unknown (due to pipe break) Dry Wet Saturated

### FAILURE CONSEQUENCES

Runoff Impacts: None One Structure Exposed Multiple Structures Exposed  
Critical/Sensitive Facility Potentially Impacted? Yes No

If this main observation included a service line connection and/or is associated with a facility failure, Please fill out the appropriate information on the reverse side of this report.

# PCR


**P**roblem- What is the observable problem that we are responding to?

**C**ause – What caused the problem we are responding to?

**R**emedy – What are we doing to fix the problem?

Each asset will have it's own unique set of PCRs. Be mindful of the strategies. If you try to be too granular you risk GiGo. (Garbage In Garbage Out)

Problem: **BREAK** - Break




## Asset Inventory

# What do you do with all of the

- **Document history** – when was it repaired/maintained, who worked on it, why was it worked on.
- **Track cost of ownership** – using a unique asset # allows us to view costs for each individual asset or we can easily expand to track costs for an asset class, we can be very granular; is there a particular make and model that requires more attention than others?
- **Identify trends for future planning** – water mains are a good example, an asset assumed to be young and have a long service life might develop a trend based on the type of backfill material that is causing corrosion and accelerated degradation. Good asset management gives us the opportunity to be proactive and do something before failure occurs.
- **Preventive Maintenance scheduling** – Established industry standards allows us to use the software to predict and produce automatic scheduling for assets. Examples: Fire Hydrants every two years, water valves every three years, reservoir cleaning every five years, commercial meter calibration/maintenance, fluid changes and other routine maintenance on pump motors and pumps.
- **Asset/ component replacement** – Example: bearing/packing replacement on pumps, PRV components; is it really necessary to replace the diaphragm rubber on a PRV every 5 years or does it vary based on other external factors like water quality or use? Asset management allows us to manage things better so we are getting the longest use out of expensive components as opposed to just replacing them because we happen to be there.



# Asset Management Ten Core Processes



# CIP Optimization - Example




# Identify, Analyze and Selection Options (example)

Assumption: Pump station with a collapsing floor


- Option 1 – Do Nothing
- Option 2 – Rebuild existing floor
- Option 3 – Upgrade entire structure to current standards
- Option 4 – Replace entire pump station with new above ground pump station
- Option 5 – Replace entire pump station with prefabricated below ground pump station

# AC Main Replacement Schedule




# Asbestos Cement Watermain Five Year Replacement Plan

- Replacement based on risk
  - Probability of failure
  - Consequences of failure
- Focus is primarily on 4-inch and 6-inch mains





# Asset Management Ten Core Processes



# AM Long-Term Financial Planning: Context

- Substantial portions of the utility systems were constructed in 1950's and 1960's
- Current estimated replacement value of \$3.5 Billion
- Recognize that utility systems are exceptionally long-lived
- Long term financial planning and a viable funding strategy is needed to properly position the City to protect its investments

# Guiding Principles

- A comprehensive long-term financial management strategy is needed to assure that future financial needs are met
- Recognize that utility assets will benefit more than one generation, therefore need for intergenerational equity and fairness
- Assets should be replaced when needed but before it fails
- Achieve acceptable service levels at lowest life-cycle costs


# Renewal and Replacement Funding program

- Established in 1995
- Accumulate funds for future replacement of utility facilities
  - Policy guidance from Utility comprehensive plans and CIP
- Each utility has its own R&R account
- City Council determines how much will be designated for the R&R account

# R&R Program Funding Policies

- Sufficient to meet projected costs over 75 year horizon
- Intergenerational equity will be achieved by making contributions to R&R which produces smooth rate transitions over planning period
- Funding should not fall below the current depreciation, less any debt principal payments
- Use of debt to provide financial flexibility

# Sources of R&R Funding



# Rates

- Primarily used to fund operations
- Generate resources to contribute to R&R
  - Gradual and uniform to avoid rate spikes
  - Contributions determined in conjunction with long-term 75-year planning horizon
  - Contributions levelized to assure intergenerational equity and consistency with long-term financial planning

# One Time Revenues

- Unplanned transfers from operations or other sources
- CIP funds above current capital needs



# Capital Facility Charges

- Facility connection charges
  - Charges to pay for equitable share of system costs at time of connection
    - Capital recovery charges
    - Direct facility connection charges


# Interest Earnings

- R&R funds expected to accumulate tens of millions of dollars over time
- Interest earnings will become a significant source of income


# Restrictions on the use of R&R funds

- Used for system renewal and replacement only
- May be loaned for other purposes, but must be repaid consistent with City financial policies and with interest


# City of Bellevue – 75 Year Annual Asset Replacement Needs




# Water Utility – Funding vs Need



# Sewer Utility – Funding vs Need




# Stormwater Utility – Funding vs Need



Values escalated to year of construction


# Asset Management Ten Core Processes





# Improving the Asset Management Program

- New Technologies
  - Condition Assessment
  - Software
- Organizational
- Constant Review
  - What's working
  - What's not working
  - What could be done better







**QUESTIONS?**