

Removal of 1,4-Dioxane from Groundwater Using Advanced Oxidation

Lynn Stephens, PE

Co-authors:

Erin Mackey, PhD, PE

Bill Persich, PE



2018 TACOMA PNWS-AWWA



Presentation Roadmap

What's
1,4-Dioxane?



Project
Introduction

Bench-scale and
Pilot-scale testing

Findings and
Next steps

What is 1,4-Dioxane?

- $C_4H_8O_2$
- Classified as an ether
- Solvent, found at many federal facilities
- Widespread use as a stabilizer in certain chlorinated solvents, paint strippers, greases and waxes
- A likely contaminant with certain chlorinated solvents, such as TCE or TCA



1,4-DIOXANE

FOUND IN Products that create suds (such as shampoo, liquid soap, bubble bath), hair relaxers, others	HEALTH CONCERNS Cancer, organ-system toxicity, irritation
WHAT TO LOOK FOR ON THE LABEL Sodium laureth sulfate, PEG compounds, chemicals that include the clauses xynol, cetareth and oleth	REGULATIONS Banned/found unsafe for use in cosmetics in Canada

The Campaign for Safe Cosmetics

Where is 1,4-Dioxane?




Figure 1. 1,4-dioxane public water supply sampling results from USEPA Unregulated Contaminant Monitoring Rule 3 (UCMR 3) (EPA 2015). Based on results reported through June 2015, nearly 7% of public water supplies tested showed exceedances of the health advisory levels for 1,4-dioxane.

Why do we care?

- Increasingly regulated because it is carcinogenic
 - Found to have fetal effects on rats
 - Chronic exposure may result in dermatitis, eczema, drying and cracking of skin and liver and kidney damage
- Various states adopting regulations
 - California: notification level of 1 $\mu\text{g}/\text{L}$ for drinking water
 - Colorado: interim groundwater quality cleanup standard of 0.35 $\mu\text{g}/\text{L}$
 - Florida: health advisory goal of 0.35 $\mu\text{g}/\text{L}$
 - Massachusetts: drinking water guideline level of 0.3 $\mu\text{g}/\text{L}$
 - New Hampshire: reporting limit of 0.25 $\mu\text{g}/\text{L}$ for all public water supplies

Key Project Goals

- Design a treatment system that reliably treats 1,4-Dioxane and meets regulations
- Treat what the City currently pumps
- Develop a system that can be managed/operated by City WTP staff after training



Key Design Criteria

Design Flow	7,500 gallons per minute (gpm), expandable to 10,000 gpm
Avg. Daily Flow	3 million gallons per day (mgd) ~2000 gpm
Meet Primary and Secondary Drinking Water Standards	

Raw Water

1,4-Dioxane max.	10 µg/L
1,4-Dioxane avg.	1 µg/L
Bromide	20 to 108 µg/L
Total Organic Carbon (TOC)	~1 mg/L

Finished Water Goals


1,4-Dioxane HAL	0.35 µg/L
1,4-Dioxane target	0.20 µg/L
Bromate	< 7 µg/L
TTHMs	≤60 µg/L
HAA5	≤40 µg/L

Raw Water Quality Data


Wellfield/WTP Raw Water Quality Average (Range)					
Parameter	1	2	4	5	6
Capacity (gpm)	1,285	1,540	1,900	2,750	2,525
1,4-D (µg/L)	0.11 (0.11-0.16)	0.89 (0.54-1.38)	1.38 (1.00-1.70)	7.1 (5.60-8.70)	0.29 (0.11-0.68)
TOC (mg/L)	1.33	0.79	0.53	0.66	1.00
Bromide (µg/L)	38.3	37.6	102	41.8	40.3
UV absorbance at 254 nm (cm-1)	0.044	0.0260	0.014	0.028	0.034

Feasibility Study Overview

- Studied the connectivity of aquifer within and around the City wellfield
- Examined the feasibility of potential new well locations and supporting test data
- Evaluated impact of bringing new well online
- Analyzed effectiveness of advanced oxidation process (AOP)
- Reviewed potential byproduct formation by AOP treatment



Advanced Oxidation Process (AOP)




Compared to other oxidants, OH radicals have a considerably higher oxidation potential

Source: Xylem, Wedeco MiPro brochure

Bench Test Summary


Confirmed ozone/peroxide efficacy and narrowed the pilot testing dose range

Ozone/Peroxide only without UV




Bromate formation is related to ozone dose and can be managed with a higher peroxide to ozone molar ratio

Ozone/Peroxide only without UV




Confirmed UV/peroxide efficacy and narrowed the pilot testing dose range

UV/Peroxide only



GAC bench-scale testing demonstrated efficient quenching at low EBCTs




Pilot Testing

Pilot Test Objectives

- Refine understanding of source water treatability by hybrid $O_3/H_2O_2 + UV/H_2O_2$ process
- Evaluate all typical well combinations
- Confirm ability to control DBP formation for the range of expected operating conditions
- Refine GAC empty bed contact time (EBCT)
- Confirm peroxide quenching and DOC removal



Pilot Configuration



MiPRO™ System



Figure 4: MiPRO™ (UV, Ozone, AOP) pilot interior.



Figure 2: MiPRO™ (UV, Ozone, AOP) pilot delivered to site.



Figure 3: MiPRO™ (UV, Ozone, AOP) pilot installed at site.


- O_3 generated from air
- All internal controls tied into a PLC
- Flow range = 8 – 25 gpm

GAC Testing


- Calgon preconstructed system
- Three GAC types




More variability in log removal at higher ozone dosages




Bromate formation can be controlled if ozone dosages remain below 4 mg/L




UV-AOP can reduce 1,4-D if dose is high enough




S-AOP worked well to reduce 1,4-D




Average total trihalomethanes formation potentials increased through UV-AOP



Average haloacetic acids formation potentials had a dramatic increase through UV-AOP




Catalytic GAC reacted quicker to hydrogen peroxide concentrations



Conclusions

- Removal of 1,4-D to below 0.2 µg/L target concentration
- Ozone-AOP alone could not meet treatment goal due to bromate production
- Sequential AOP vs. UV-only AOP is still being evaluated
- Peroxide quenched by all three GACs tested
 - Two catalytic carbons consistently produced water with peroxide below detection limits at EBCTs of 2.5 minutes.
 - Non-catalytic carbon peroxide quenching rates were slightly less relative to the catalytic carbons, and were below the detection limit at EBCTs of up to 4.2 minutes
- No increase in DBPs with ozone-AOP, increase in DBPs from UV-AOP, especially with higher UV dosages



Thank you. Questions?

Lynn Stephens

LStephens@brwncald.com