


Non-Potable Water Supply Program Development in Beaverton, Oregon

Jason Melady, RG, CWRE
Principal Hydrogeologist
GSI Water Solutions, Inc.

David Winship, PE
Principal Engineer
City of Beaverton




In Association with  CleanWater Services

Introduction


- South Cooper Mountain Development Area
 - 540 acres
 - Urban reserve 6B— additional 1,200 acres
 - Planned 7,000 residential units for both areas
- Offset potable water supply
- Leverage infrastructure development opportunity
- Stormwater management
- Streamflow enhancement



Project Location




Project Location




Columbia River Basalt Group


15 to 17 million years ago





14 to 15 million years ago



6 to 14 million years ago



1980 BEAVERTON JOINS JWC – 100% SURFACE WATER SUPPLY



1980 BEAVERTON POPULATION - 31,962

JWC Water Supply System (75% of City's summer water) ASR (25% summer water)



USBR Springhill Pumping Plant



Fern Hill 20 MG Reservoir
Nos. 1 & 2




JWC Water Treatment Plant



Hagg Lake/Loggins Reservoir





Barney Reservoir



2019 Beaverton Population: 97,000

Beaverton ASR Program



City of Beaverton
Total City Population:
97,000

2018 Population Served:
71,000
2019: 87,000

2018 Total Water Meters:
19,000
2019: 23,000

- Second municipality in Oregon to develop ASR, and have been successfully operating ASR wells since 1998.
- Two active ASR wells (ASR2, ASR4), 5 mgd capacity
- Currently in ASR expansion phase on a path for up to three future facilities to serve growth, emergencies and create resiliency.
 - Potable ASR 5 – 2 mgd
 - Potable ASR 7 - 1.4 mgd
 - Non-potable ASR 3A – 1 mgd


Recharge Well – ASR 3 – 0.75 mgd





2001 - ASR No. 2
2 mgd



2007 - ASR No. 4
3 mgd




South Cooper Mountain




**544 Acre Annexation to The City of Beaverton in 2013
3,500 New Homes, a 2,200 Student High School, and a Future Elementary School**

South Cooper Mountain Heights Subdivision


Mountainside High School



Cooper Mountain Reservoir No. 2 and Transmission Mains: Concept Plan



- 1 Construction of a new gravity supply system for the City in the South Cooper Mountain Service area: Cooper Mt. Reservoirs, ASR 7, and the future Upper Pressure Zone booster pump station.
- 2 Shown in red, the remaining 6,550 linear feet (LF) of new 24-inch dia. restrained ductile iron (DI) water main along SW Kemmer Rd & SW 175th Ave to supply the 675 and 550 Zones.
- 3 New master pressure reducing valve (PRV) station at SW 175th Ave south of SW Alword Ln, currently under construction (designed by Murraysmith).
- 4 1,600 LF of new 16-inch dia. restrained DI water main along SW Weir Rd. (looped connection for 794 zone)



- Water Supply (SCM, URA 6B, City wide)
- Resiliency
- Fire Flow
- Redundancy





Non-potable Water System

Why a Non-Potable Purple Pipe System




- Summer raw water source up to 40 miles away in Barney Reservoir
- Raw water highly treated then chlorinated and pumped to JWC reservoirs
- Potable water travels 20 miles from the JWC Water Treatment Plant to COB
- Summer potable water demand is 60% higher than winter demand due to irrigation and outdoor use
- High am/pm peaking from irrigation on the potable system are reduced by a non-potable system in the summer
- Reducing am/pm irrigation peaking frees up capacity in reservoirs & pump stations for drinking water, fire protection, emergency pump station outages, and potential JWC supply interruptions.
- A non-potable system directly offsets potable supply, reducing or postponing new supply— Avoided Cost of \$14M/mgd
- **Turf, plants and trees don't need chlorinated/fluoridated drinking water**



A New Type of Source Non-Potable




South Cooper Mountain Sterling Park Subdivision






Stormwater Recharge

Project Concept




ASR 3 groundwater well

Project Concept: Winter



Project Concept: Summer



Oregon ASR Regulations

- Multi-agency consultation
- Source water quality – twice as stringent as drinking water standards
- Authorization for use of water – water rights
- Limited license
- Water quality testing and aquifer response monitoring
- Annual reporting

Regional Stormwater Quality

Analytes Detected in Oregon Municipal Stormwater Above MCLs

Analyte	EPA MCL (mg/L)	Total Number of Samples		Percent of Total Samples Exceeding the MCL	
		Kennedy/ Jenks Study (2009)	DEQ Municipal Database (2015)	Kennedy/ Jenks (2009)	DEQ Municipal Database (2015)
Antimony	0.006	347	277	0.3	0.0
Arsenic (total)	0.01	846	1,183	0.2	0.08
Benzo(a)pyrene	0.0002	740	1,284	0.3	0.93 ^b
Cadmium	0.005	1,609	1,183	0.5	0.0
Chromium	0.1	1,226	1,183	0.8	0.0
DEHP	0.006	641	1,284	4.7	5.5
Lead (total)	0.015 ("Action level")	1,782	1,284	12.7	13.3
Nitrate-Nitrogen	10	633	1,136	0.3	0.0
PCP	0.001	675	1,279	11.7	14.5
Zinc (total)	5 ^c	1,661	1,284	0.1	0.0


Feasibility Study

OWRD Grant with CWS: 2016-2018

- Stormwater Flow
 - Radar/ultrasonic automated flow measurement in both basins
- Stormwater Quality Sampling
 - 4 sampling events in each basin (2 time series samples and 2 grab samples). First flush targeted in time series.
 - Samples analyzed for comprehensive list of stormwater contaminants of interest (COIs)
 - Over 300 analytes – pathogens, inorganics, DBP's, emerging urban contaminants, metals, SOC's, VOC's, radionuclides. Every constituent for which there is an MCL, SMCL, or TT.



Stormwater Quantity



Stormwater Quality

Just over 60 COIs detected above reporting limit in one or more sample(s), and only 8 COIs exceeded their respective screening level value (i.e. ½ MCL or SMCL)

Analytes Detected Above Respective Screening Level

Analyte	Units	Regulatory Requirements		Location	Geometric Mean	Percent of Total Samples Exceeding the MCL
		1/2 MCL	SMCL			
Fecal Coliform	MPN/100 mL	--	--	WS-1A	408	100
				WS-1B	255	100
Total Coliform	Presence or Absence	--	--	WS-1A	present	100
				WS-1B	present	100
E. Coli	P or A	--	--	WS-1A	present	100
				WS-1B	present	100
Culturable Cytopathic Enteric Viruses, Primary Value	IU MPN	0	--	WS-1A	1	100
				WS-1B	1	50
Culturable Cytopathic Enteric Viruses, Secondary Value	IU MPN	0	--	WS-1A	1	100
				WS-1B	2	50
Apparent Color	Color Units	--	15	WS-1B	23	100
Turbidity	NTU	0.15 - 0.25	--	WS-1A	9	100
				WS-1B	7	100
Aluminum	ug/L	--	200	WS-1A	320	100
				WS-1B	200	100
Iron	mg/L	--	0.3	WS-1B	0	50

Stormwater Quality and Treatment Options

<i>Data Source</i>			<i>Treatment Options</i>
Sterling Park Site-Specific Stormwater Data (2017)	Oregon Municipal Stormwater Studies (Kennedy/Jenks, 2009; DEQ Municipal Database, 2015)	DEQ Municipal Database (2015)	
<i>Metals</i>			
Zinc (total), Aluminum (total), Iron (total)	Antimony, Arsenic (total), Cadmium (total), Chromium (total), Lead (total), Zinc (total)	Antimony, Arsenic (total), Cadmium (total), Chromium (total), Lead (total)	Total metals are often associated with particulates that can be removed through a filtration step (e.g. sand filter). Concentrations of dissolved metals may be removed through activated carbon/biochar adsorption , ion exchange processes, ultra or membrane filtration, precipitation, electrodialysis, and distillation. Removal may often depend upon pH and influent concentrations.
<i>Solids, Nuisance, Odor</i>			
Turbidity, Apparent Color, Odor	Not Analyzed	Not Analyzed	Turbidity may be removed with flocculants/coagulants, filtration , adsorption or some combination of all of these processes. Water quality issues associated with color and odor may be greatly reduced after water clarification/filtration processes. Color is often a result of dissolved material (Fe, Cu, NOM, Mn) or suspended solids and will resolve with treatment processes that eliminate these underlying constituents.
<i>PAHs, phthalates, and other organics</i>			
No COIs above screening levels	Benzo(a)pyrene, DEHP	Benzo(a)pyrene, DEHP, Benzene	Activated carbon is effective in removing concentrations of dissolved organics such as PAHs, phthalates, and benzene. DEHP is often associated with water pipes and can be readily removed with activated carbon.
<i>Nitrate-Nitrogen</i>			
No COIs above screening levels	Nitrate-Nitrogen	No COIs above screening level	Nitrates are difficult to remove from water sources with passive treatment options and would likely require ion exchange units, reverse osmosis, or distillation. Some nitrate-nitrogen may be removed through filtration and adsorptive treatment steps
<i>Pesticides</i>			
No COIs above screening levels	PCP	PCP	Activated carbon and other adsorptive media such as organoclay are often effective in removing pesticides such as PCP. PCP is also readily degraded in the environment at lower concentrations.
<i>Potential Pathogens</i>			
Fecal Coliform, Total Coliform, E. Coli, Enteric Viruses	Not Analyzed	Not Analyzed	Coliform bacteria, E. Coli, and culturable viruses are often ubiquitous in the environment. Various effective means of disinfection are readily available including chlorine, chloramines, ozonation, ultraviolet irradiation , etc.

Key Findings

- Stormwater volume 57 MG
- Recharge rates 400 gpm
 - 35 MG at rates of 400 gpm or less
- Recovery rates 500 gpm
- Water quality compatibility
- Stored water cooler than native groundwater (9°C vs 15°C)

What's Next

- OWRD implementation grant – CWS and City
 - Awarded \$860,000 in November 2018
- Pilot testing phase – 2019-2020
- Full scale implementation – 2020-2021
- Non-Potable Water System Program Management – 2019



Questions?

Jason Melady, RG, CWRE
jmelady@gsiws.com

David Winship, PE
dwinship@beavertonoregon.gov

Acknowledgments

OREGON




WATER RESOURCES
DEPARTMENT

CleanWater  Services

Conceptual Stormwater Treatment


Treatment System Design Parameters:

- Flow Rate = 400 gpm
- Water Quality Characteristics
 - Consistent with results of site-specific and local/regional water quality data



Stormwater Flow

2016-2017 Stormwater Volume and Precipitation



Treatment Performance Summary of Pilot System for some Key COIs at Sterling Park

Parameter	Sample Location	Median, (Range ³) Number of Samples	Removal Efficiency ⁴ Median (Range ³)
<i>E.coli</i> (mg/L)	Influent	2420, (770 - 2420) n = 7	99 (99 - 99)
	Effluent	0.5, (0.5 - 0.5) n = 7	
<i>Turbidity</i> (mg/L)	Influent	60.4, (36.3 - 118) n = 16	72.5 (57 - 95)
	Effluent	11.39, (2.7 - 26) n = 16	
<i>Tot Zn</i> (mg/L)	Influent	0.6825, (0.26 - 2.1) n = 98	85.5 (73 - 94)
	Effluent	0.0985, (0.035 - 0.29) n = 98	
<i>Tot Al</i> (mg/L)	Influent	2.5, (0.77 - 4.75) n = 29	75 (61 - 91)
	Effluent	0.236, (0.06 - 1.02) n = 29	
<i>Tot Fe</i> (mg/L)	Influent	4.28, (1.12 - 8.1) n = 30	77 (61 - 90)
	Effluent	0.376, (0.172 - 1.93) n = 30	

1 - Sampling from inlet and outlet of Aquip SBE full-scale filtration systems (Purus V for E.coli).

2 - All chemical analysis by third party certified analytical testing laboratory.

3 - The inlet, outlet, and removal efficiency ranges provided are the 25th to the 75th percentile of all results.

4 - The removal efficiencies based on inlet and outlet pairs.

5 - Median values may include non-detections; for the purposes of these calcs, the non-detected values are presented at half the DL.

Proposed Treatment System Layout

