


# Like New! – Renewal and Operation of Auburn's Wells

**PNWS 2016**

Susan Fenhaus – City of Auburn

Dan Reisinger – Carollo Engineers



# Introductions

- Susan Fenhaus – Water Utility Engineer, City of Auburn
- Dan Reisinger – Lead Water Resources Engineer, Carollo


# Agenda

- Auburn's Supply Sources
- Supply Renewal Projects
- Water Quality
- Cost-effective Operation
- Questions



# Auburn's Wells


- 10 Wells
- 2 Springs
- 1 Regional Supply



# Many supplies are not reliable

Source	Reliable
Coal Creek Springs	★
West Hill Springs	★
Well 1	
Well 2	
Well 3A and 3B	
Well 4	
Well 5, 5A, and 5B	★
Well 6	
Well 7	
RWSS	★


# Source reliability and O&M issues spurred supply renewal program



# Regional Supplies allowed City to initiate a supply renewal program

Year	Supply Improvement	Improved Capacity (gpm)
2016	<u>Well 1</u> On-site Improvements Project	2,200
2016	<u>Well 4</u> Emergency Power Improvements Project	2,600
2017	<u>Fulmer Field</u> Project	4,000

# Supply renewal projects will provide reliable supply next 20 years



# Well #4 Improvements Project

- Switch from gas to liquid chlorine
- Provide emergency power generator



# Well #1 Improvements Project

- New building
- Add chlorination, emergency power
- Pumps to Howard Road facility for corrosion control
- Blends with Coal Creek Springs
- Lesson learned – transmission main needs a hydrant to flush



# Fulmer Field Project

- Corrosion
- Bacterial growth
- Iron and manganese
- Clean and rehabilitate
- Pump tests for capacity



# Before and after Well 2 cleaning



Notes:  
-Pre-rehab video dated May 7, 2013  
-Post-rehab video dated May 2, 2014


FIGURE **A-3**  
**WELL NO. 2 SCREEN - 245 TO 247 FEET BGS**

City of Auburn/Fulmer Wellfield/WA

# Minimum flows required to maintain water quality

- Minimum continuous flow of 600 gpm at both Well 2 and 6 (1,200 gpm total)
- Well 2 and 6 are same building.
  - Long term City will redrill Well 2 at new location
- Fulmer Field CCTF is not able to pump at low flows

# Fulmer CCTF Operation



# Operational changes has decreased “Dirty” water calls

- Well 7 use suspended
  - High levels of manganese
- Implemented Unidirectional Flushing (UDF) Program

**Table 12.7 Summary Customer Requests  
Water System Plan  
City of Auburn**

Category	2009	2010	2011	2012	2013	2014
Appearance	26	11	16	19	11	5
Odor	2	2	8	5	2	2
Pressure	19	18	5	17	13	17
Taste	3	6	2	4	4	2
Water Quality	3	0	1	3	0	1
<b>Total</b>	<b>53</b>	<b>37</b>	<b>32</b>	<b>48</b>	<b>30</b>	<b>27</b>

2015:  
23 Total  
Requests

# How can supplies be operated cost effectively?

- Sufficient supplies to meet its demand using multiple source combinations.
- Evaluated use using total costs:
  - Future Capital Costs
  - Fixed O&M Costs
  - Variable O&M Costs
- Operational needs were considered.

# Supply Renewal CIP Costs from 2015 Water System Plan

Source	Capital Costs (\$ million)
Coal Creek Springs	\$10.93
West Hill Springs	\$1.36
Well 1	\$0.08
Well 2	\$0.08
Well 3A and 3B	\$19.64
Well 4	\$0.08
Well 5, 5A, and 5B	\$7.10
Well 6	\$0.08
Well 7	\$20.85

# Calculated O&M costs based on past bills and usage

From City - Received on 12/11/2014 - "Chlorine costs for 2014. xlsx"

Month	Well 4	Coal Creek Springs	West Hill Springs
<b>Chlorine Gas</b>			
January	\$1,035.00	\$1,414.18	\$1,235.00
February	\$0.00	\$1,614.18	\$0.00
March			
April			
May			
June			
July			
August			
September			
October	\$0.00	\$1,513.58	\$0.00
November	\$0.00	\$1,512.98	\$0.00
December	\$0.00	\$1,611.95	\$0.00

**Chemical Costs**

Installation:

Business Partner - Long T Device		Move-Out Date																									
CITY OF AUBURN 4091666509		12/31/9999																									
Billing Month	From Date	To Date	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	W	X	Y	Z	
										Degree Days	Avg Ambient Temperature	Billed Quantity	UOM														
11/2014	10/9/2014	11/6/2014	2							329	53.65517241	2137	Kilowatt h														
10/2014	9/10/2014	10/8/2014	2							120	61.10344828	1801	Kilowatt h														
09/2014	8/8/2014	9/9/2014	2							46	66.15151515	1965	Kilowatt h														
08/2014	7/10/2014	8/7/2014	2							22	68.65517241	1883	Kilowatt h														
07/2014	6/10/2014	7/9/2014	2							100	63.26666667	2047	Kilowatt h														
06/2014	5/8/2014	6/9/2014	2							187	59.81818182	2409	Kilowatt h														
05/2014	4/9/2014	5/7/2014	2							376	52.31034483	2312	Kilowatt h														
04/2014	3/11/2014	4/8/2014	2							529	46.75862069	2974	Kilowatt h														
03/2014	2/7/2014	3/10/2014	2							711	42.78125	3171	Kilowatt h														
02/2014	1/8/2014	2/6/2014	2							742	38.4137931		Kilowatt h														

**Electric Usage and Charge**

12/22/2014 - "Labor and Maintenance Records"


Coal Creek Springs		Well SA	
Labor	Equipment	Labor	Equipment
17,371.00	\$40	16.00	\$1,94
9,630.00	\$21	16.00	\$1,94

**City Labor and Maintenance Records**

# How can supplies be operated cost effectively?

- The least total cost sources to operate are:
  1. *Coal Creek Springs.*
  2. *Well 4.*
  3. *Fulmer Field (Wells 2 and 6).*
  4. *West Hill Springs.*
  5. *Upland Wellfield (Wells 5 and 5A).*
  6. *Well 1 and RWSS supplies provide redundant capacity when preferred sources are offline.*
- Operating costs largely driven by level of water quality treatment.

# City's Sources can cost-effectively provide supply in future



# Next Steps

- Construction completion expected:
  - Well 1 and 4 – now
  - Well 2 and 6 on line by end of year with all improvements by 2017
- Unknown – Well 1 blending with Coal Creek Springs and corrosion control treatment – any quality concerns?
- Operate and monitoring manganese levels at Fulmer

# Questions?