




# Award Winning Technology for Cleaning Water and Wastewater Mains

Jeff Austin  
Water System Consultant  
Advanced Solutions

# Overview

1. Introduction
2. Current Problems
3. Cleaning water mains
4. What is Ice Pigging
5. Ice Pigging in practice
6. Projects and Case Studies
7. Summery
8. Questions

# Current Problems Cleaning Options




# Current Problem

Regulations require systems to operate cleaner and more efficient.

Risks include:

- **Sediments**
  - Taste & Odor
  - Customer Complaints
- **Deposits**
  - Loss of Capacity
  - Increased Pumping Costs
- **Biofilms**
  - Increased Disinfectant Byproducts
  - Higher Chlorine Dosing
- **Iron and Manganese**
  - Emerging Manganese Risks and Concerns



# Traditional Cleaning Techniques

## Flushing / UDG



### Operational Challenges:

- Inefficient Scouring
- High velocity flow rates needed
- High Water Waste

# Traditional Cleaning Techniques

Operational Challenges  
Foam Swabs Poly Pigs



## Operational Challenges:

- Bends, changes in diameter or butterfly valves
- Excavation to launch and receive pigs
- Disinfection required post clean
- Interruptions to supply
- Aggressive could lead to pipe damage

What is Ice Pigging?




ICE PIGGING

# How Does It Work?



- Ice Pigging harnesses the characteristics of a semi-solid material
- Semi-solid material that can be pumped like a liquid .....
- But behaves like a solid once the pig is formed in the pipe



# Controlling the semi-solid state



To maintain the correct consistency of the Ice Pig during an operation a freezing point depressant is used

## Proportion Blend

- Tap Water
- Dry Ice Monoxide
- Sodium Chloride
  - Food Grade, NSF
  - Typically 5%
- 75% to 90% ice
- 24-27°F



## Ice Pigging in Practice:



## Flushing Comparison:



# Cleaning Capabilities

- Iron
- Manganese
- Sediments
- Biofilms
- Fats, Oils, Greases (FOG)



# Ice vs. Mayonnaise



## Ice Pigging in practice



# The Equipment: 10T – 2700 Gallons

## 10T Ice Delivery Rig (2,700 gallons)



## Ice Generator



## Ice Production



# The Equipment

## 2.2T Demo Unit & 5T Ice Machine




# The Equipment

## Flow Analysis System

- Flow
- Pressure
- Conductivity
- Turbidity
- Water temperature



# Site Schematic: Potable Water



# Primary Insertion: Hydrant



# Other Insertion Options: via Tapping

- **Tapping**



- **Meter Vault**



- **Air Release Valve**



- **Pig Launch**





# Extraction Point



# Discharge



# Site Schematic: Sewer



# Results of the process:

PVC:

Before

After



Cast-Iron  
Before



After



Tuberculation  
untouched but  
biofilm and  
sediment removed

## Results: What Comes Out?



① Sample from front of pig

② Sample from middle of pig as it carries through sediment

③ Sample at end of pig where water is clean again

# Project Consideration



**JOB INFORMATION:**  
Client City of Longview  
Date 22-Jul-13  
Location 26th Ave  
Insertion Point 8102  
Discharge Point 8102  
Pipe Length 3600 Lft  
Pipe Diameter 8 & 6"  
Material CI  
Usage Domestic Water Distribution  
Volume of Ice 2600 Gallons  
Ice Fraction 90%  
Total Water Used 18823 Gallons




Pre-Clean Readings		Immediate Post-Clean Readings		Change
Turbidity (NTU)	15	Turbidity (NTU)	7	-8
Temperature (°F)	66.8	Temperature (°F)	60.3	-6.5
Pressure (PSI)	40	Pressure (PSI)	42	2
Conductivity (mS/cm)	0.4	Conductivity (mS/cm)	0.4	0



Comments:


Maximum Flow Rate (gpm)	205	Lowest Temperature Reached (°F)	35.9	Ambient Air Temperature (°F)	75
-------------------------	-----	---------------------------------	------	------------------------------	----




SEDIMENT DATA:						
#	Time (s)	Flow Rate (gpm)	Temperature (°F)	Conductivity (mS/cm)	Sample Mass (g)	Sed. Mass (g/gal)
1	60	202.00	61.0	0.1	1.00	0.0000
2	90	211.07	61.0	0.1	0.00	0.0000
3	120	204.63	61.0	0.0	1.00	0.0000
4	150	205.43	61.0	0.0	0.00	0.0000
5	180	204.23	61.0	0.0	0.00	0.0000
6	210	207.09	61.0	0.0	0.00	0.0000
7	240	209.15	60.0	0.0	0.00	0.0000
8	270	208.23	60.0	0.0	0.00	0.0000
9	300	208.23	60.0	0.0	0.00	0.0000
10	330	207.63	59.0	0.0	0.00	0.0000
11	360	206.43	58.0	0.0	0.00	0.0000
12	390	205.00	57.0	0.0	0.00	0.0000
13	420	203.00	56.0	0.0	0.00	0.0000
14	450	201.00	55.0	0.0	0.00	0.0000
15	480	200.00	54.0	0.0	0.00	0.0000
16	510	200.00	53.0	0.0	0.00	0.0000
17	540	200.00	52.0	0.0	0.00	0.0000
18	570	200.00	51.0	0.0	0.00	0.0000
19	600	200.00	50.0	0.0	0.00	0.0000
20	630	200.00	49.0	0.0	0.00	0.0000
21	660	200.00	48.0	0.0	0.00	0.0000
22	690	200.00	47.0	0.0	0.00	0.0000
23	720	200.00	46.0	0.0	0.00	0.0000
24	750	200.00	45.0	0.0	0.00	0.0000
25	780	200.00	44.0	0.0	0.00	0.0000
26	810	200.00	43.0	0.0	0.00	0.0000
27	840	200.00	42.0	0.0	0.00	0.0000
28	870	200.00	41.0	0.0	0.00	0.0000
29	900	200.00	40.0	0.0	0.00	0.0000
30	930	200.00	39.0	0.0	0.00	0.0000
31	960	200.00	38.0	0.0	0.00	0.0000
32	990	200.00	37.0	0.0	0.00	0.0000
33	1020	200.00	36.0	0.0	0.00	0.0000
34	1050	200.00	35.0	0.0	0.00	0.0000
35	1080	200.00	34.0	0.0	0.00	0.0000
36	1110	200.00	33.0	0.0	0.00	0.0000
37	1140	200.00	32.0	0.0	0.00	0.0000
38	1170	200.00	31.0	0.0	0.00	0.0000
39	1200	200.00	30.0	0.0	0.00	0.0000
40	1230	200.00	29.0	0.0	0.00	0.0000
41	1260	200.00	28.0	0.0	0.00	0.0000
42	1290	200.00	27.0	0.0	0.00	0.0000
43	1320	200.00	26.0	0.0	0.00	0.0000
44	1350	200.00	25.0	0.0	0.00	0.0000
45	1380	200.00	24.0	0.0	0.00	0.0000
46	1410	200.00	23.0	0.0	0.00	0.0000
47	1440	200.00	22.0	0.0	0.00	0.0000
48	1470	200.00	21.0	0.0	0.00	0.0000
49	1500	200.00	20.0	0.0	0.00	0.0000
50	1530	200.00	19.0	0.0	0.00	0.0000
51	1560	200.00	18.0	0.0	0.00	0.0000
52	1590	200.00	17.0	0.0	0.00	0.0000
53	1620	200.00	16.0	0.0	0.00	0.0000
54	1650	200.00	15.0	0.0	0.00	0.0000
55	1680	200.00	14.0	0.0	0.00	0.0000
56	1710	200.00	13.0	0.0	0.00	0.0000
57	1740	200.00	12.0	0.0	0.00	0.0000
58	1770	200.00	11.0	0.0	0.00	0.0000
59	1800	200.00	10.0	0.0	0.00	0.0000
60	1830	200.00	9.0	0.0	0.00	0.0000
61	1860	200.00	8.0	0.0	0.00	0.0000
62	1890	200.00	7.0	0.0	0.00	0.0000
63	1920	200.00	6.0	0.0	0.00	0.0000
64	1950	200.00	5.0	0.0	0.00	0.0000
65	1980	200.00	4.0	0.0	0.00	0.0000
66	2010	200.00	3.0	0.0	0.00	0.0000
67	2040	200.00	2.0	0.0	0.00	0.0000
68	2070	200.00	1.0	0.0	0.00	0.0000
69	2100	200.00	0.0	0.0	0.00	0.0000
70	2130	200.00	-1.0	0.0	0.00	0.0000
71	2160	200.00	-2.0	0.0	0.00	0.0000
72	2190	200.00	-3.0	0.0	0.00	0.0000
73	2220	200.00	-4.0	0.0	0.00	0.0000
74	2250	200.00	-5.0	0.0	0.00	0.0000
75	2280	200.00	-6.0	0.0	0.00	0.0000
76	2310	200.00	-7.0	0.0	0.00	0.0000
77	2340	200.00	-8.0	0.0	0.00	0.0000
78	2370	200.00	-9.0	0.0	0.00	0.0000
79	2400	200.00	-10.0	0.0	0.00	0.0000
80	2430	200.00	-11.0	0.0	0.00	0.0000
81	2460	200.00	-12.0	0.0	0.00	0.0000
82	2490	200.00	-13.0	0.0	0.00	0.0000
83	2520	200.00	-14.0	0.0	0.00	0.0000
84	2550	200.00	-15.0	0.0	0.00	0.0000
85	2580	200.00	-16.0	0.0	0.00	0.0000
86	2610	200.00	-17.0	0.0	0.00	0.0000
87	2640	200.00	-18.0	0.0	0.00	0.0000
88	2670	200.00	-19.0	0.0	0.00	0.0000
89	2700	200.00	-20.0	0.0	0.00	0.0000
90	2730	200.00	-21.0	0.0	0.00	0.0000
91	2760	200.00	-22.0	0.0	0.00	0.0000
92	2790	200.00	-23.0	0.0	0.00	0.0000
93	2820	200.00	-24.0	0.0	0.00	0.0000
94	2850	200.00	-25.0	0.0	0.00	0.0000
95	2880	200.00	-26.0	0.0	0.00	0.0000
96	2910	200.00	-27.0	0.0	0.00	0.0000
97	2940	200.00	-28.0	0.0	0.00	0.0000
98	2970	200.00	-29.0	0.0	0.00	0.0000
99	3000	200.00	-30.0	0.0	0.00	0.0000
100	3030	200.00	-31.0	0.0	0.00	0.0000
101	3060	200.00	-32.0	0.0	0.00	0.0000
102	3090	200.00	-33.0	0.0	0.00	0.0000
103	3120	200.00	-34.0	0.0	0.00	0.0000
104	3150	200.00	-35.0	0.0	0.00	0.0000
105	3180	200.00	-36.0	0.0	0.00	0.0000
106	3210	200.00	-37.0	0.0	0.00	0.0000
107	3240	200.00	-38.0	0.0	0.00	0.0000
108	3270	200.00	-39.0	0.0	0.00	0.0000
109	3300	200.00	-40.0	0.0	0.00	0.0000
110	3330	200.00	-41.0	0.0	0.00	0.0000
111	3360	200.00	-42.0	0.0	0.00	0.0000
112	3390	200.00	-43.0	0.0	0.00	0.0000
113	3420	200.00	-44.0	0.0	0.00	0.0000
114	3450	200.00	-45.0	0.0	0.00	0.0000
115	3480	200.00	-46.0	0.0	0.00	0.0000
116	3510	200.00	-47.0	0.0	0.00	0.0000
117	3540	200.00	-48.0	0.0	0.00	0.0000
118	3570	200.00	-49.0	0.0	0.00	0.0000
119	3600	200.00	-50.0	0.0	0.00	0.0000

**RESULT:** Sediment Removed (lb) 29.63 Sediment Removed per mile (lb) 43.53

The above values are calculated from samples taken every 60 seconds on site. For each sample the flow rate, and the sediment densities are assumed to remain constant within that 60 second period. From this we can calculate the total amount of water/ice and therefore can estimate the total mass of sediment over the sampling period



# Main Cleaning Comparative Summary




# Ideal Applications

## Where to Utilize Ice Pigging?

- **Ground water: Iron & manganese**
- **Surface water: sediments & biofilm**
  - Disinfectant residual drop in areas of the system?
- **Flushing too often**
- **Pipes that can't be cleaned with traditional techniques:**
  - Multiple diameter changes, bends, etc.
  - Mainline butterfly valves or other possible obstructions
  - High Risk Pipe: Railroad crossing, creek crossings, force mains
- **Critical pipe / Minimal time to complete project**

## Estimate ice quantities



# Capabilities

Ice Pigging with 10T Rig				
	6"	8"	10"	12"
	Max/Day (FT)	Max/Day (FT)	Max/Day (FT)	Max/Day (FT)
PVC/AC	12000'	7000'	4500'	3000'
CICL/DI	9300'	5280'	3300'	2300'
CI Unlined	6300'	3500'	2200'	1500'

# Barriers

## Is Ice Pigging Expensive?

- Consider the cost difference of cleaning once every 5-10 years compared to operational and non-revenue water of flushing regularly.

## Will Ice Pigging work in my system?

- Several hundred projects across the nation
- 2"-24" diameter pipe cleaned
- Removed over 700 lbs./mile of sediment
- Numerous case studies and references available.

## Budgeting?

- Options available for multi-year projects to take advantage of lower mobilization costs, economies of scale, and flattened annual fee.

# ICE PIGGING - Summary

- **Efficient rapid and environmentally friendly**
- **Combines operational benefits of flushing with the impact of solid pigging**
- **Ice Slurry injected through existing hydrants**
- **System pressure pushes ice through complex water networks**
- **Suitable for pipes of all size and material**
- **Exceptionally low risk**
- **Produces quantifiable results**
- **Harmless to public**


# Questions?




For Additional information:  
**Jeff Austin**  
**503-713-8823**  
**[jaustin@utilityservice.com](mailto:jaustin@utilityservice.com)**  
**[www.utilityservice.com](http://www.utilityservice.com)**

# Longview, WA

- 12,200ft of 6 & 8 inch cast iron
- Ongoing pipe scale destabilization problem resulting in the release of accumulated materials
- Average sediment removal of 312 lbs per mile of pipe



# Longview, WA



- Although more aggressive than unidirectional flushing, ice pigging did not appear to disrupt existing tubercles, thus supporting the on-going re-stabilization process and allowing for rapid recovery of the system post-pigging.
- There is no doubt that the City of Longview benefited significantly from ice pigging, especially when compared to the effectiveness of flushing alone within this flow-constricted section of the distribution system.

# Middlebury, VT

- 12,000' of 18" PVC Sewer Force Main - 9 runs



**“traditional pigging proved to carry too many potential issues of catastrophic failure which we were not willing to gamble with”**


**“Flows returned to design spec – An increase of 445 gallons per minute”**

**Robert Wells, Town of Middlebury Wastewater Superintendent**



# Middlebury, VT

- 11% Increase in flow rates
- Returned pipe to original design capacity
- 2014 ACEC/Vermont Grand Award Winner



# Western Hills, CA

## Delta Mendota Aqueduct

- Type of Main: Gravity sewer siphon
- Length of main: 2 x 1,400Ft
- Diameter and material: 12" & 14" HDPE

## California Aqueduct

- Type of Main: Gravity sewer siphon
- Length of main: 2 x 3,151 Ft



"We have been **consistently flushing** these lines but it was having little to no effect.

The ice pigging technology was **quick, efficient** and very effectively cleaned out the siphons. We now have a **flow rate consistent with the design spec.**"

I consider ice pigging to be a superior, exceptionally low risk method to clean sewer mains that otherwise could not be cleaned without risk of major disruption to the system.


We are now looking towards a **regular cleaning program using ice pigging** to ensure we do not suffer large sludge build-ups in the future"

*Jerry Phillips – Western Hills Water District Manager*



# Ice Pigging

1. Introduction
2. Current Problems
3. Cleaning water mains
4. What is Ice Pigging
5. Ice Pigging in practice
6. Projects and Case Studies
7. **Summery**
8. Questions





# Project Planning

## Needed Info:

- Main diameter, material, & length
- Sewer/Raw/Potable?
- Water temperature in main
- Operating flows & pressures

## Maps/Sketch/Drawings

- Location of:
  - Valves hydrants, or other access
  - Diameters and changes
- Lengths between locations



# Project Reporting

## Visual Evidence of Cleaning



# Filtering



# Project Reporting



JOB RECORD/REPORT/SUMMARY



## JOB INFORMATION:

Client City of Longview  
Date 22-Jul-13  
Location Balt/19th  
Insertion Point 26th Ave  
Discharge Point B102  
Pipe Length 3600 Lft  
Pipe Diameter 8 & 6"  
Material CI  
Usage Domestic Water Distribution  
Volume of Ice 2600 Gallons  
Ice Fraction 90%  
Total Water Used 18823 Gallons



## ONSITE PROCEDURE:


Pre-Clean Readings		Immediate Post-Clean Readings		Change
Turbidity (NTU)	15	Turbidity (NTU)	7	-8
Temperature (°F)	66.8	Temperature (°F)	60.3	-6.5
Pressure (PSI)	40	Pressure (PSI)	42	2
Conductivity (mS/cm)	0.4	Conductivity (mS/cm)	0.4	0

## Timeline:



## Comments:

Maximum Flow Rate (gpm) 205 | Lowest Temperature Reached (°F) 35.9 | Ambient Air Temperature (°F) 75



JOB RECORD/REPORT/SUMMARY



## SEDIMENT DATA:

#	Time (s)	Flow Rate (gal/hr)	Temperature (°F)	Conductivity (mS/cm)	Sample Mass (g)	Sed. Mass (g/gal)	Sediment (lb/gal)
1	30	202.85	62.8	6.1	1.28	203.53	1.95
2	40	113.87	62.8	6.1	0.83	765.32	1.48
3	130	184.61	62.3	36.8	1.08	1086.38	3.75
4	230	185.42	61.4	819.8	0.80	937.88	2.88
5	270	184.61	58.3	45.8	0.88	1086.27	1.58
6	320	187.88	52.9	38.8	0.68	1076.39	1.38
7	360	188.15	54.9	35.7	0.54	862.31	1.48
8	400	188.65	58.8	38.8	0.47	765.51	1.40
9	510	188.62	58.8	38.8	0.38	653.76	1.38
10	570	187.82	58.8	45.8	0.38	576.29	1.34
11	630	200.42	58.0	49.2	0.41	657.39	1.46
12	690	202.02	57.7	42.1	0.48	686.47	1.43
13	750	201.88	58.8	48.8	0.52	518.88	1.54
14	810	204.57	58.8	52.0	0.18	284.58	0.46
15	870	204.80	58.8	57.3	0.18	342.92	0.51
16	930	205.17	58.7	24.8	0.14	226.79	0.58
17	990	203.82	58.8	22.2	0.15	284.58	0.58
18	1050	205.08	58.8	18.0	0.12	284.57	0.63
19	1110	204.64	58.2	14.3	0.08	147.34	0.54
20	1170	204.71	58.1	11.4	0.18	311.38	0.68
21	1230	204.48	58.1	8.4	0.08	81.75	0.58
22	1290	203.69	58.1	7.8	0.02	32.59	0.07
23							
24							
25							
26							
27							
28							
29							
30							
31							
32							
33							
34							
35							
36							
37							
38							
39							
40							

RESULT: Sediment Removed (lb) 29.63 | Sediment Removed per mile (lb) 43.53

The above values are calculated from samples taken every 60 seconds on site. For each sample the flow rate, and the sediment densities are assumed to remain constant within that 60 second period. From this we can calculate the total amount of water/ice and therefore can estimate the total mass of sediment over the sampling period



# **Case Study – Sharpsville, IN**

## **Sewer Force Main**

- **7 miles of 6-inch PVC**
- **5 x 10T loads of ice**

### **Before ice pigging;**

Two pumps ( 20Hp & 15HP  
running with a flow of 45-50 gpm

### **Post ice pigging;**

One pump flowing 120 gpm

**“ Plans to build a second lift station  
at mid point of force main, at an  
estimated cost of \$300K shelved”**

# Case Study – City of Cambridge, Ontario

## Statistics

**King St. Force main;  
327 LF x 6" PVC Force Main**

**Preston St. Siphon:  
3 barrels – 12", 18" & 20"**

**Todd St. Siphon:  
2 barrels – 12" & 22"**

**Grand Ave, Siphon:  
2 barrels – 20" & 28"**

**Length of siphons all approximately 400 LF**

“the build-up accumulated over the course of the 40 to 50 years since their original installation”



# Case Study – City of Cambridge, Ontario



“With this new method of maintenance, we are ensuring that the pipes will perform at full capacity”

metrolandmedia  
Connected to your community®

— Your Hometown Newspaper —  
**CAMBRIDGE TIMES**

*“City of Cambridge first in Canada to try innovative sewer siphon cleaning technique”*

“The City saw positive results from this process at all three chosen locations, in some cases seeing pipes go from 60% capacity to 100%”  
Hardy Bromberg, Deputy City Manager



# Case Study – Danbury NC

## Problem:

- Water system 30 years old
- Build up of Manganese and iron
- Discolored water complaints
- Heavy sediment build up
- Insufficient water storage for other cleaning techniques
- Flushing not an option



# Case Study – Danbury NC

***“Water quality has been greatly increased and customer complaints have all but disappeared”***


**Mark Delehant – Director of Public Works Stokes County NC**

# Chilling Questions?


**Jeff Austin**

**(503) 713-8823**

**[jaustin@utilityservice.com](mailto:jaustin@utilityservice.com)**



# FAQ – Thermal Shock



**Photos of the one exposed section and the attached Strain Gauges and Temperature Sensors**



# Waste Water Results



# Service Lines

