





City of Othello

Aquifer Storage and Recovery (ASR) Program: Phase 2 Test



Presented by

Andrew Austreng, LHG, RG

Tim Flynn, LHG, CGWP




Presentation Outline

- Background/Intro
- Treatment System Overview
- Results
- Lessons Learned
- Next Steps




City of Othello, WA



Othello Water Supply Background

Othello Relies on 8 Wells in Wanapum Basalt

- Significant loss in wellfield capacity
- Diminishing return on new sources
- Water Rights Constraints




Demonstration-Scale Test

- Follow-up to FS and Phase 1 Test
- Divert up to 500 a-f from BoR Canal
- Treat with Mobile MF System
 - Assess Water Quality
- Recharge Deep Basalt Aquifer
- Store Water, Monitor, then Recover


City Wells


ASR Phase II Pilot Test Injection Site



Treatment System

- 1.06 MGD, Leased from Pall Water
- Backwash every 20 to 40 minutes
- EFM every 48 hours
- CIP every 30 days (or after event)
- Monthly Chemical Demand:
 - 60 gallons NaOCl (12.5%)
 - 25 gallons NaOH (25%)
 - 43 gallons Citric Acid (50%)
 - 6 gallons NaHSO₃ (38%)





Diversion Pump

EL-68 Canal

Raw Water Influent Line
(buried)

Raw Water Feed Tank

ASR
Control

Well 8

Hydrant

Treatment Trailer

Treated Water Pipeline


Neutralization Skid

Pond

Backwash & Neutralization




Remote Dashboard



Lessons Learned....



Watch the Weather...



Communication Protocols...



Weed Control....



Organic Debris




Pre-Treatment Strainer



Test Results

- Recharge: May 11 to Oct 21 (*163 days*)
- 141 days of Recharge
- Average Rate: 493 gpm
- Max Daily Rate: 674 gpm
- **Total Recharge: 330 acre-feet**

Summer Water Level Trends



- **78% Reduction in Declining Trend in 2021**


Water Quality

- No SVOCs ever detected in EL-68 source water or background
- Source Water Generally Better Quality than Groundwater
 - Lower TDS and Temperature
- Treatment System Met All Performance Criteria
 - Bacteria Filtered
- Successful Coordination with ECBID on Weed Control
- Spike in Al, Fe, Mn, Pb, Cu During Storage


Filtration Performance

Analysis	Result	Flag
2105210-01: Raw Canal Water (Potable)		
E. Coli	Present	U
Total Coliform	Present	U
Analysis	Result	Flag
2105218-01: Recharge (Potable)		
E. Coli	Absent	U
Total Coliform	Absent	U

- Bacteria non-detect
- Recharge water: 0.07 ntu
- 4-log reduction at 3 μm




Copper Sulfate



- Modeling does not support increase in Cu

Iron



- Dissolved fraction consistent with background
- Suggests “slug” of suspended iron


Water Quality

- All Constituents below:
 - MCL/SMCL
 - Groundwater Quality Criteria
- Storage Results Still Coming In
 - Sampling next week

Next Steps

- DOH Approval for Direct Reuse
(disinfection plan)
- Recovery (May 2022)
- Pilot Test Report
- Pursue Future Funding for Treatment

Questions?



Andrew Austreng, LHG

aaustreng@aspectconsulting.com

206.838.5843

www.aspectconsulting.com


Tim Flynn, LHG, CGWP

tflynn@aspectconsulting.com


206.780. 7730

www.aspectconsulting.com

Well Performance



- Specific capacity remains slightly elevated during storage
- No indications of well fouling



PhreeqC Water Quality Modeling

- 2018 FS model updated
- Model predicted low to moderate dissolution of iron-oxide and manganese-oxide minerals (e.g., goethite, hematite, birnessite) and low-to-moderate precipitation of aluminum-oxide and iron-sulfide minerals (e.g., gibbsite and pyrite).
- Observed metal concentrations in stored water could not be replicated by modeling.