

# Seeing Purple: Design and Construction of the City of Beaverton's Non-potable Water System for Municipal Irrigation May 5, 2023 AWWA PNWS 2023 Section Conference



# **BEAVERTON PURPLE PIPE**

Connecting the right water with the right uses.













$\square$	

PIONEER DESIGN GROUP







A Geo-Logic Company





involvement





# **Topics**

- 1. Overview of Purple Pipe Program
- 2. Distribution system and developers
- 3. Design of stormwater treatment and pump station
- 4. Bidding and construction progress
- 5. Closing




## **Overview: Goals of Purple Pipe Program**

- Use <u>non-potable</u> water to irrigate community green spaces in the South Cooper Mountain area of Beaverton and provide stream recharging.
- City's goals:
  - Create a sustainable and reliable source of water
  - Be environmentally responsible and conserve natural resources
  - Be financially responsible




### **South Cooper Mountain**

Annexed in 2013: 544 acres, 3,500 new homes, 2,200-student high school and future elementary school; approximately 9,000 population




### South Cooper Mountain


Annexed in 2013: 544 acres, 3,500 new homes, 2,200-student high school and future elementary school; approximately 9,000 population



### JWC Water Supply System: 75% of summer water Aquifer Storage and Recovery (ASR): 25% summer water



### **Beaverton Purple Pipe Implementation Timeline**



### Benefits Key to City Council and Stakeholder Support

- Component of City's Climate Action Plan
- Puts available water to use that would otherwise be a waste
- Reduces stormwater flow into the storm system
- Provides summer streamflow benefits (for habitat and fish)
- Reduces unnecessary use of chlorinated, fluoridated drinking water for irrigation



### **Components of the Purple Pipe System**

- Source of water:
  - Groundwater from aquifer
  - Stormwater collected, treated and stored inside the aquifer
  - Potable water augment to meet demand
- Pump station, ASR wells, and stormwater treatment
- Non-potable distribution system



• Purpose: Input for Council decision to proceed with stormwater source


### • Alternatives:

No further investment (potable source only, partial distribution)
Full implementation (stormwater + GW source, full distribution, streamflow release)
Limited implementation (potable + GW source, full distribution)


### • Methodology:

- Preliminary engineering cost estimates (capital and operations)
- Present-value analysis (2020) over 20-year period with discounted annual costs

#### **Full Implementation**



#### Limited Implementation




	Factor	Baseline	Full (Alt. 1)	Limited (Alt. 2)
	Greater system resiliency		+	+
Ŀ	Consistency with sustainability goals		+	+
Reduced cost for potable supply use			+	
ă	Improved environmental amenities		+	
Opportunity for cost savings			+	+
	Purple pipe distribution system		\$	\$
Cost	Stormwater treatment system		\$	
ပိ	Pump station facility		\$	\$
	Operation and maintenance		\$	\$

### **BCA Summary**

Although Baseline is the least expensive (no further investment), the Full/Limited implementation generates desired benefits to City and residents that outweigh the costs


Cost



## Maintaining City Council Support

- System Development Charge Methodology (Jul. 2020)
- SDC Impact Reductions (Aug. 2020)
- Non-potable Water Utility Ordinance (Sep. 2020)
- Contracts to design purple pipe distribution system (Oct. 2020)
- Approve stormwater treatment source (May 2021)
- Developer construction contract agreements (first phases) (Sep-Nov. 2021)
- Portions funded by EPA (WIFIA) and OWRD grant
- Council elections and transitions, changes with staff (including PWD)

### **Development Community and Distribution System**



## Purple Pipe Installation is On-going in South Cooper Mountain

Total 2" Installation as of April 2023 ~24,000 LF of 2" pipe ~412 SFH Connections

Various greenspace meters Agreements in place ~14,000 LF ~235 SFH Connections



#### Coordination with other development construction is critical

.











## **Cross-Connection & Design Standards**

Table 42	
High Hazard Table	
(Premises Requiring Isolation* by an Approved Air Gap or a Reduced Pressure Principle	
Type of Assembly Health Hazard)	
Agricultural (for example, farms, dairies)	
Beverage bottling plants**	
Car washes	
Chemical plants	
Commercial laundries and dry cleaners	
Premises where both reclaimed and potable water are used	
Film processing plants	
Food processing plants	
Medical centers (for example, hospitals, medical clinics, nursing homes, veterinary	
clinics, dental clinics, blood plasma centers)	
Premises with irrigation systems that use the water supplier's water with chemical	
additions (for example, parks, playgrounds, golf courses, cemeteries, housing estates)	
Laboratories	
Metal plating industries	
Mortuaries	
Petroleum processing or storage plants	
Piers and docks	
Radioactive material processing plants and nuclear reactors	
Wastewater lift stations and pumping stations	
Wastewater treatment plants	
Premises with piping under pressure for conveying liquids other than potable water and	
the piping is installed in proximity to potable water piping	
Premises with an auxiliary water supply that is connected to a potable water supply	
Premises where the water supplier is denied access or restricted access for survey	
Premises where the water is being treated by the addition of chemical or other additives	

\* Refer to OAR 333-061-0070(8) premises isolation requirements.

\*\* A DC could be used if the water supplier determines there is only a non-health hazard at a beverage bottling plant.

- OAR 333-061-0070
  - Tables 42 and 43
- Water purveyor can require RP
- Building department & plumbing code

Backsiphonage or Backpressure
Air Gap
Reduced Pressure Principle Backflow
Prevention Assembly (RP)
Reduced Pressure Principle-Detector Backflow
Prevention Assembly (RPDA)
1





## Source of Water for Purple Pipe Program

- The Beaverton Purple Pipe will carry nonpotable water:
  - Groundwater from an aquifer.
  - **Stormwater** that will be collected, treated and stored inside the aquifer.
  - Potable water augment to meet demand.
- The system will NOT carry:
  - "Recycled" water (treated effluent) or graywater.



# Sterling Park Non-potable Water Facility Source Water




ASR 3/3A (Native Ground Water)


**Treated Storm Water** 

# **Stormwater to Augment Non-potable Supply**

- City partnered with Clean Water Services to conduct a feasibility study with OWRD grant in 2016-2017
- Benefits of the concept:
  - Enhanced groundwater supply
  - Reduced stormwater runoff
  - Increase capacity to stormwater infrastructure




- -- Mitigate flow an temperature issues to local streams
- -- Reduce surface water demand



# **Project Permitting, Stormwater Quality & Quantity**

### **State Regulatory Agencies**

- Oregon Water Resources Department (OWRD)
- Oregon Health Authority (OHA)
- Oregon Department of Environmental Quality (DEQ)



#### **OWRD**

- Leads permit issuance process
- Verifies that water use is allowed under OWRD rules, sets conditions on use (OAR 690-350)

#### OHA

• Verifies that AR meets requirements for drinking water systems, if applicable (OAR 333-061)

#### DEQ

- Verifies that AR well is authorized by DEQ (1200-U permit) OAR 340-044
- Verifies that Limited License meets water quality requirements (<u>anti-degradation</u>, MCLs, protect human health) OAR 340-040, 340-044

# Stormwater Quality – Bacteriological, General Chemistry, and Metals COI's

			Concentrations				
Analyte Class	Analyte	Units	n-=	Sterling Park Stormwater Average Concentration	Background Groundwater		
Bacteriological	Total Coliform	MPN/100 mL	25	>2420	< 1		
	Turbidity	NTU	25	9.6	ND		
Gen. Chem.	Nitrate + Nitrite	mg/L	20	0.27	ND		
	Sulfate	mg/L	7	2.99	1.6		
	Manganese	ug/L	8	126	48		
Metals	Iron	ug/L	11	810	110		
	Aluminum	ug/L	12	215	ND		
	Zinc	ug/L	28	322	22		

### **Stormwater Quality – Anthropogenic Compound COI's**


			Concentrations				
Analyte Class	Analyte	Units	n=	Sterling Park Stormwater Average Concentration	Background Groundwater		
PAHs	Di-n-octylphthalate	ug/L	20	0.85	ND		
	2,4-D	ug/L	9	1.32	ND		
	Paraquat	ug/L	7	2.6	ND		
Pesticides	MCPP-p	ug/L	2	0.26	ND		
	Diuron	ug/L	7	0.08	ND		
	Triclopyr	ug/L	7	0.11	ND		
	PFHxA	ug/L	2	0.0035	ND		
	PFOA	ug/L	2	0.0048	ND		
PFAS/PFOA	Perfluorononanoic acid	ug/L	2	0.0010	ND		
	Perfluorodecanoic acid	ug/L	2	0.0012	ND		
	PFOS	ug/L	2	0.0064	ND		
Petroleum Hydro	Toluene	ug/L	23	0.88	ND		

# **Sterling Park - Stormwater Quantity**

Diminishing returns on treatment rates above 200 gpm Volume range between 13.3 to 26.2 MG


High precipitation year in 2016-2017 and low 2017-2019

Average precipitation – volume estimated at 22 MG/yr



**Estimated Annual Volumes Treated at Various Flow Rates** 

## **Stormwater Treatment Pilot/Bench Testing**



### Water Quality – Bacteriological, General Chemistry, and Metals

NOTE: Table only shows analytes with concentrations in raw stormwater above background in native basalt groundwater

			Concentrations						
Analyte Class	Analyte	Units	Raw Stormwater Pilot Testing	Treated Stormwater Package System <b>A</b>	Treated Stormwater Coagulant/Pressure Filter/GAC B	Treated Stormwater SS/Package/GAC <b>C</b>	Background Groundwater		
Bacteriological	Fecal Coliform	MPN/100 mL	> 2,420	< 1	< 1	< 1	< 1		
Gen. Chem.	Nitrate + Nitrite	mg/L	0.26-0.46	0.32	0.21	0.28	ND		
	Sulfate	mg/L	2.3-3.9	48	19	59	1.6		
	Manganese	ug/L	29-170	130	41	15	48		
Metals -	Iron	ug/L	460-530	250	180	120	110		
	Aluminum	ug/L	140-430	110	1100	330	ND		
	Zinc	ug/L	130-690	29	130	ND	22		

BLUE = Treatment reduces analyte concentration to below background

ORANGE = Treatment reduces analyte concentration, but not to below background

BLACK = Treatment raises analyte concentration, or analyte not significantly affected by treatment


### Water Quality – Anthropogenic Compounds

NOTE: Table only shows anthropogenic compounds that were detected in stormwater

			Concentrations					
Analyte Class	Analyte	Units	Raw Stormwater Pilot Testing	Treated Stormwater Package System <b>A</b>	Treated Stormwater Coagulant/Pressure Filter/GAC <b>B</b>	Treated Stormwater SS/Package/GAC <b>C</b>	Background Groundwater	
PAHs	Di-n-octylphthalate	ug/L	ND-0.85	0.14	ND	ND	ND	
	2,4-D	ug/L	1.7-2	0.63	0.14	ND	ND	
- Pesticides	Paraquat	ug/L	ND-2.6	ND	ND	ND	ND	
	MCPP-p	ug/L	0.11-0.6	ND	ND	ND	ND	
	Diuron	ug/L	ND-0.08	ND	ND	ND	ND	
	Triclopyr	ug/L	0.094-0.13	0.087	ND	ND	ND	
- PFAS/PFOA -	PFHxA	ug/L	0.0027-0.0046	0.0021	0.00355	ND	ND	
	PFOA	ug/L	0.0045-0.0051	0.0031	0.0038	ND	ND	
	Perfluorononanoic acid	ug/L	ND-0.002	ND	ND	ND	ND	
	Perfluorodecanoic acid	ug/L	ND-0.0024	ND	ND	ND	ND	
	PFOS	ug/L	0.0044-0.0093	0.0044	0.0044	ND	ND	
Petroleum Hydro	Toluene	ug/L	ND-0.88	ND	ND	ND	ND	


### Sterling Park Stormwater Treatment








#### **Original Sterling Park Conditions (with Stormwater Ponds and ASR 3 Test Well)**








Rendering of Sterling Park ASR 3 Pump Station and Stormwater Treatment Facility




### ASR 3 Mechanical Building Layout




**©** consor

88









**Consor** 

Operations: Recovery for irrigation and stream discharge

**Consor** 



ASR 3 **Facility** Recovery **Operations** 



#### **O&M** at Sterling Park ASR 3 Pump Station and Stormwater Treatment Facility





## **Project Construction – Bidding and Pricing**

- Economic climate
- 2 contractor bids received
- Winning bid 26% above Engineers Estimate
  - Generally aligned with BLS Construction Sector cost increases/Producer Price Index
- Material shortages increased costs
- Electrical
- Complex project 4 Addendums

## **Project Construction – Procurement Challenges**

- Long lead time items
  - Electrical transformers 50 to 100 weeks
  - Ductile iron, fittings, and valves 30 weeks
  - Instrumentation and controls equipment 20 to 50 weeks
  - Treatment equipment 20 to 30 weeks
  - Purple Pipe supply

### **Project Construction – Site Challenges**

- Very constrained site
  - Overall site ~ 2.5 acres
  - Building site ~ 8,600  $ft^2$
- Construction season
  - Work in existing stormwater basin delayed

## **Project Construction – Remaining Work**


- In-basin water treatment construction to start May/June
- Pump station building construction
- Stormwater treatment installation
- Pump and downhole valve installation
- Site access paving
- Landscaping
- Instrumentation and controls installation and programing
- System startup

#### November 2022





#### January/February 2023













## Key Lessons

- Find the right opportunity the benefit-cost can be site-specific
- Master plan and try to stay ahead
- Engage development community and stakeholders early and often
- Committed champion with the backing of a diverse team
- Develop a sound funding plan
  - Leverage grants and loans
- Be flexible and plan for change
- Bid timing/flexibility in schedule
- Alternative delivery options



## Beaverton's Opportunity: Expansion into Cooper Mountain





## **Opportunities for the Water Industry**

# Beaverton's "proof of concept" will help utilities and water industry:

- Build on lessons learned
- Establish permitting framework
- Improve on treatment technologies
- Criteria to find the right site/project and its scalability
- Leverage stormwater reuse for funding opportunities
  - Federal, state, and county



## **Questions?**

Jason Melady, RG, CWRE jmelady@summitwr.com

Alex Bargmeyer, PE Alex.Bargmeyer@Consoreng.com

Priya Dhanapal, PE pdhanapal@beavertonoregon.com

> Brian Diaz, PE bdiaz@beavertonoregon.com

> > Ronan Igloria, PE, CWRE rigloria@gsiws.com

David Winship, PE dwinship@beavertonoregon.com