

3 MAY 2023

# When PFAS is Only Half the Battle: Treating Multiple Contaminants with a Series of Media

---

Stephen Timko, PhD  
Kennedy Jenks

# AGENDA

- Treatment Plant Overview and Water Quality
- Pilot Testing Overview and Findings
- Design Overview

# Plant Overview and Water Quality

# Canyon Lake Water Treatment Plant Overview

- Surface Water Treatment Plant with source water managed by Canyon Lake Property Owners Association and EVMWD
- Constructed as a conventional water treatment facility, 10% of water supply portfolio
- Previous design capacity 7 MGD
- Variable source water quality





# Project Drivers

- Aging infrastructure requiring replacement
- Contaminants of Emerging Concern
  - PFAS
  - Cyanotoxins




# WATER QUALITY ISSUES

- Nutrients (algal blooms)
- TOC
- Manganese
- PFAS
- Algal toxins (potential)

# Water Quality

Constituent	Units	Average	Range	MCL/SMCL
TOC	mg/L	5.9	4.3-9.6	-
Color	units	15.7	3-45	15
Odor	TON	2.4	1-8	3
Manganese	µg/L	65	0.4-880	50
TDS	mg/L	430	46-1,000	500
Turbidity	NTU	5.3	0-83	-
Sulfate	mg/L	133	48-220	250
Iron (total)	µg/L	100	10-620	300
Alkalinity	mg/L as CaCO <sub>3</sub>	96	11-165	-


# Historical Process Flow Diagram





# Historical Process Flow Diagram

## Nutrients




# Nutrients in Canyon Lake

- Nutrient input from runoff
- Seasonal algal blooms
- Phosphorus main limiting nutrient
- Alum application to sequester P seasonally



# Historical Process Flow Diagram



# PFAS Detections

Abbreviation	Average (ng/L)	Range (ng/L)	California NL	California RL
<b>PFOA</b>	25	24 – 26	5.1	10
<b>PFOS</b>	15	14 – 16	6.5	40
<b>PFBS</b>	12	8.8 – 14	500	5,000
<b>PFDA</b>	5.8	5.0 – 6.6	--	--
<b>PFHpA</b>	9.9	8.1 – 11	--	--
<b>PFHxS</b>	8.6	8.0 – 9.1	2*	20*
<b>PFHxA</b>	21	16 – 24	--	--
<b>PFNA</b>	5.1	4.7 – 5.3	--	--

# Water Quality and Process Selection

## CHALLENGES

- High TOC, T&O
- No permitted surface water treatment application for PFAS removal in CA
- High manganese and pre-oxidation requirements
- Competing surface water quality goals with turbidity, DBPs, and others

## MARKET SOLUTIONS

- GAC
- IX
- Specialty Adsorbents
- Reverse Osmosis

## SELECTION

- Dual-Barrier Treatment approach
- Further confirmed by evaluating treatment configurations with pilot testing





# Dual-Barrier Approach

- Reduce fouling
  - Turbidity
  - Manganese
  - TOC
- Meet water quality goals



# TOC Removal by Media



**Need to maximize TOC removal prior to PFAS removal media**




# Dual-Barrier Approach

- GAC before IX
  - TOC removal
  - Dechlorination
- IX/novel adsorbent for PFAS removal




# Alternatives Evaluated

## Alternative 1



★ Post-Filtration dual-barrier treatment configuration

## Alternative 2



★ Configuration 2 evaluated to see if any beneficial O&M impacts of replacing filters with GAC rather than post-filtration solution

# Pilot Testing Overview



# Pilot Testing Overview

- 1 Continuously operated over a duration of 9 months
- 2 Treatment trains located under a covered canopy, located in the existing parking lot




# Pilot Testing Objectives

- Evaluate and validate the performance of the two treatment trains
- Compare the performance of alternative PFAS adsorbents, and to provide input to the process design criteria
- Evaluate performance of GAC when treating high TOC surface water
- Determine if use of Pyrolusite under GAC in Alternative 2 adequately controls manganese at CLWTP

# Treatment Train Overview


## TRAIN 1

- ★ F400- Calgon
- ★ AV 1240 (Aqueous Vets)
- ★ PSR2+ (Dupont/Dow)
- ★ FS 200 (CETCO)




## TRAIN 2

- ★ F816- Calgon
- ★ AV 816 (Aqueous Vets)
- ★ PSR2+ (Dupont/Dow)



# Pilot Testing Parameters



## Pretreatment Performance Goals

Parameter	Goal
Settled Water Turbidity	<2NTU (preferably <1NTU)
TOC Removal	>40%
Filtered Water Turbidity	<0.1 NTU
Filter Runtime (@ 4.5 gpm/sf)	>28 hours
Filtered Water Manganese	<15 µg/L





# Pilot Testing Findings



# Manganese Impacts

- Approximately half of the manganese in CLWTP source water can be removed by pre-treatment ( $>5 \mu\text{m}$ )
- The other half of manganese removed by oxidation ( $<0.45 \mu\text{m}$ )
- Permanganate dose optimization: chlorine application pre-filtration effective at maintaining manganese in filter effluent below treatment goal


# PFAS Removal- Train 1



## CONCLUSIONS:

- All 8 PFAS broke through first barrier
- PFOA breakthrough at week 26 in IX/FS

# TOC Removal- Train 1







**Figure 4.13 – TOC Profiles at Multiple Locations in Train 1 (Anth/Sand Filters)**

## CONCLUSIONS:

- ~45% removal of TOC through pre-treatment and media filtration, and GAC
- Steady rise of TOC throughout pilot operation in GAC effluent
- No impact of IX/FS on TOC removal

# PFAS Removal- Train 2



## CONCLUSIONS:


- All 8 PFAS broke through
- PFOA breakthrough at week 24 in IX

# Conclusions and Recommendations

- 1 Train 1 recommended for implementation at CLWTP. Train 2 had less effective manganese removal through GAC/pyrolusite filters, and filter run times were shorter than A/S run times in Train 1
  - a) Train 1 configuration included in design
- 2 Dual barrier (GAC followed by IX/FS200) achieved reliable PFAS removal.
  - a) GAC contributed to less than 20% of removal of PFOA throughout pilot duration, but provided DBP and T&O reduction.
- 3 Manganese control optimized during the pilot, new chlorine addition points are recommended at the raw water line and sedimentation basin effluent, with chlorine analyzer installed at filter influent
  - a) These elements incorporated in design
- 4 Combination of permanganate and chlorine use sufficient and reliable for destruction of five cyanotoxins
  - a) Both chemicals incorporated in design



# Process Flow Diagram



Q

&

A

---

Stephen Timko, PhD

[StephenTimko@KennedyJenks.com](mailto:StephenTimko@KennedyJenks.com)




# IX OR FS?

# IX vs. FS: Non-Cost Factors (1/2)

Key Factors	Fluorosorb	Ion Exchange
Capital Cost	<ul style="list-style-type: none"> <li>• Same number of vessels</li> </ul>	
	<ul style="list-style-type: none"> <li>• Backwash waste tank required, already included in design, provisions for backwash included on valve tree</li> </ul>	
O&M Costs	<ul style="list-style-type: none"> <li>• <b>Lower</b> head loss &amp; lower pumping costs.</li> </ul>	<ul style="list-style-type: none"> <li>• <b>Higher</b> head loss through vessels &amp; higher pumping costs. Design incorporates higher head conditions for conservative pump sizing</li> </ul>
	<ul style="list-style-type: none"> <li>• Similar frequency of media changeouts.</li> </ul>	
O&M Considerations	<ul style="list-style-type: none"> <li>• Low O&amp;M, Similar to IX. <b>Reduced</b> flow capabilities during vessel media changeout due to lower maximum HLR</li> </ul>	<ul style="list-style-type: none"> <li>• Low O&amp;M, similar to FS</li> </ul>
Pre-Treatment Considerations	<ul style="list-style-type: none"> <li>• Elevated levels of iron and manganese can cause fouling on media</li> </ul>	

# IX vs. FS: Non-Cost Factors (2/2)

Key Factors	Fluorosorb	Ion Exchange
PFAS Treatment	<ul style="list-style-type: none"> <li>• <b>Less effective</b> than ion exchange for removing some PFAS with Canyon Lake water quality</li> </ul>	<ul style="list-style-type: none"> <li>• <b>More effective</b> than FS for removing smaller chain PFAS with Canyon Lake water quality</li> </ul>
Permitting Considerations <sup>(1)</sup>	<ul style="list-style-type: none"> <li>• Lead-lag configuration not previously permitted by DDW for PFAS removal in CA</li> </ul>	<ul style="list-style-type: none"> <li>• Lead-Lag configuration DDW approved for PFAS removal in CA</li> </ul>
Constructability/Contracting 	<ul style="list-style-type: none"> <li>• Unknowns in warranty and production at large scale</li> </ul>	<ul style="list-style-type: none"> <li>• Widely installed for PFAS removal, several full -scale installations across CA</li> </ul>
Waste Disposal	<ul style="list-style-type: none"> <li>• Spent resin hauled off-site for disposal and incinerated</li> </ul>	

(1) NSF certification limits FS installation at 4-foot bed depth currently. Design parameters for FS possibly subject to change in the future.



# IX vs. FS: Cost Factors

## Life Cycle Costs

- Recent budgetary costs for FS at \$193/cf, and IX at \$295/cf, with similar disposal costs (\$110/cf)
- Lifecycle costs comparison indicate FS is more cost effective overall compared to IX, at **\$4.1 M over 20 years**

 EVMWD decided to incur risks associated with FS and intends to bid FS in one vessel

