



Desalination North of the Arctic Circle: Reverse Osmosis System in Remote Alaska

Sanyukta Gokhale, PE

May 9, 2025





Point Hope, Alaska

- North Slope Borough, above Arctic Circle
- Today's high = balmy 33 °F (0.5°C)
- Sunset today – 12:34 AM
- Near continuous occupation since 500 BC
- ± 0 cars per household, 3.3 min walk to work
- Roughly 800 villagers
- Whaling, Whaling, Whaling!



Distances from Major Population Centers


Point Hope

Russia: 172 miles

Fairbanks: 570 miles

Anchorage: 700 miles

Boise, ID
2,500 miles



Chukchi Sea

Marryat Inlet

Point Hope

Qagiaq Lake



Point Hope Water Supply

- Water thaws and ice damns form lakes from mid-summer to early fall
- 2 – 3 months/year of flowing water
- Water pumped from lakes and treated
- Multiple above ground, heated, recirculating storage tanks to supply 9 – 10 months
- Class II WTP





Point Hope Water Issues

- Operations vulnerable
 - Inability to resupply for most of the year
 - Any fire flow is risk of later water shortage
- Frequent risk of severe water rationing, prolonged water outages
 - Emergency bottled water flown in
 - Potential village evacuation
 - Extremely difficult in winter/continuous darkness
- Climate change
 - Qagiaq Lake in jeopardy
 - New well drilled for supply



Plant challenges

- If there are any issues, operators need to try and fix with the spare parts available at the plant.
- Extra boxes, hoses, piping.
- Temporary measures put in place
- Labor
- Keeping water circulating in the winter
- Equipment Maintenance




Current Water Treatment

- Built in 1999
- Raw water storage: 3.8 MG
- Two stage treatment:
 - Microfiltration
 - Nanofiltration – TOC removal
- Finished water storage: 5.9 MG
- Plant staffed with 2-3 operators' year round
- Max. production ~ 30,000 GPD



Current Water Treatment



Design Requirements

- Sampling June 2021 and May 2022
- Groundwater connected to an underground brine pool/lens
- Such pools common to the Arctic
- 58% more saline than typ. seawater
- Very cold water
- Salinity inhibits freezing in the well
- Flowable water even during spring/fall
 - Not certain about coldest winter

| Parameter | Unit | 2022 Value |
|------------|---------------------------|------------|
| TDS | mg/L | 55,500 |
| TSS | mg/L | 96 |
| Hardness | mg/L as CaCO ₃ | 11,000 |
| Alkalinity | mg/L as CaCO ₃ | 322 |
| pH | s.u. | 7.0 |
| Ammonia | mg/L | 3.8 |
| Iron | mg/L | 21.7 |
| Manganese | mg/L | 2.44 |
| Color | PCU | 10 |
| TOC | mg/L | 5.9 |
| Temp. | deg C | -3 |

Existing WTP Building

- Equipment must fit inside existing bldg
- Any work very expensive
 - Labor flown in
 - Equipment supplied by barge or airplane
 - Freezing temperatures most of the year
- Existing backwash/brine disposal is small on-site infiltration basin (not suited for year-round use)



Approach


- Replace heat exchanger
- Precipitate iron
- Increase MF cleaning capabilities
- Reverse osmosis
- Replace CIP pump, reuse rest of existing
- New ocean outfall







Proposed Treatment

- TDS (Lake vs Well)
 - Very different RW quality
 - Ability to treat either(2x 175 GPM Units)
 - 2 units on 1 skid
 - 1 unit nanofiltration
 - 1 unit reverse osmosis
- Precipitate Iron



Proposed Treatment





OXIDATION TANK

Iron

- New chlorine dosing pump
- New oxidation tank
- Existing feed water tank
- MF filtration

NF Unit

- Limited to 3 months until lake is gone completely
- Designed to be converted to 2nd RO unit
- Continuous water production during summer window
- Incident response more of a challenge

RO Unit



- Well frozen is not frozen as long, thus water production window is close to year round
- Plant can operate 8-10 hours a day
- Incident response is easier
- 100 HP maximum design requirement. Using energy recover on feed pumps

Projections

| | Lake Source | Well Source |
|---------------------|-------------|-------------|
| Pressure vessels | 8 | 8 |
| Elements per vessel | 4 | 4 |
| Feed flow (gpm) | 290 | 175 |
| Permeate flow (gpm) | 130 | 53 |
| Recovery (%) | 45 | 30 |
| Feed Pressure (psi) | 75 | 1,000 |
| Booster Pump HP | 20 | 20 |
| Energy Recovery | Bypass | Yes |
| Feed Pump HP | Bypass | 100 |

Training

- Operators will receive training on new system.
- Older equipment is replaced and will be under warranty





Installation

- Limited footprint available
- Constrained by size of door
- Single skid is split for entry then reassembled
- Make sure everything is available
- Demolish in winter / clear a path
- Get done by spring






Cost Estimate

- Rates
 - 60 hours / week
 - 20% premium time
 - Subcontractors markup 35%
 - 3 Months to complete
- Equipment = \$1.3M
- Contingency = \$500K
- Total = \$4M



Schedule

- ROM design of skid - summer 2025
- Equipment fabrication and shipping – 1 year
- Delivery to Point Hope – after ice, summer 2026
- Construction – winter 2026
- Startup – Spring 2027



Questions?

